
From: James Zanotelli <Jimmy.Zanotelli@fire.ca.gov>
Sent: Thursday, February 01, 2018 9:40 AM
To: Bill Walker
Subject: Fountain Wind Project

Bill,

I looked over the info on the county website. I have a few comments. I did not see the info below listed in the report. I'm not sure if this is the point to make these request, or wait to add the comments to the official conditions for the project.

1. There isn't any mention in their fire protection plan of fire hydrants, fire systems or fire water on-site for firefighting purposes.
2. The O&M building for the Hatchet project had fire sprinklers, I would assume the O&M building for this project would require the same.
3. SCFD would like 5000 gallon water tanks placed in strategic locations throughout the wind farm for firefighting.

Jimmy Zanotelli

Fire Marshal

Shasta County Fire Department

530-225-2425

jimmy.zanotelli@fire.ca.gov