

## Notice of Determination

**To:**

Office of Planning and Research  
 U.S. Mail: Street Address:  
 P.O. Box 3044 1400 Tenth St., Rm 113  
 Sacramento, CA 95812-3044 Sacramento, CA 95814

Clerk of the Board  
 County of: San Bernardino  
 Address: 385 North Arrowhead Avenue, Second Floor  
San Bernardino, CA 92415-0130

**From:**

Public Agency: San Bernardino County, LUSD  
 Address: 385 North Arrowhead Ave, First Floor San Bernardino, CA 92415-0187

Contact: Steven Valdez

Phone: 909-387-4421

Lead Agency (if different from above): \_\_\_\_\_

Address: \_\_\_\_\_

Contact: \_\_\_\_\_

Phone: \_\_\_\_\_

**SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.**

State Clearinghouse Number (if submitted to State Clearinghouse): 2018041029

Project Title: Chino Groundwater Remedial Action Plan

Project Applicant: San Bernardino County, Land Use Services Department

Project Location (include county): 34° 14'49.6"N 117°12'27.8"W

Project Description: The project as evaluated in 2018 (MND adopted in January 2019) is currently proposed, however an Addendum has been prepared to evaluate requested modifications to well locations, piping and treatment facilities. See Table 1 (attached).

This is to advise that the San Bernardino County has approved the above ( Lead Agency or  Responsible Agency)

described project on \_\_\_\_\_ and has made the following determinations regarding the above described project.  
 (date)

1. The project [  will  will not] have a significant effect on the environment.
2.  An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.  
 A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures [  were  were not] made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan [  was  was not] adopted for this project.
5. A statement of Overriding Considerations [  was  was not] adopted for this project.
6. Findings [  were  were not] made pursuant to the provisions of CEQA.

This is to certify that the final and record of project approval are the Mitigated Negative Declaration are available to the General Public at: 385 N. Arrowhead Ave., San Bernardino, CA 92415

Signature (Public Agency): Steven Valdez Title: Senior Planner  
 Steven Valdez

Date: March 4, 2022 Date Received for filing at OPR: \_\_\_\_\_

**Table 1 - Changes to Project Description Included in IRAP and CEQA Initial Study/MND Chino Airport Groundwater Remediation Project - Updated**

**9/8/21**

| Item | Description          | IRAP/CEQA IS            | Design  | Notes  |
|------|----------------------|-------------------------|---|--|
| 1    | Conveyance Piping    | 28,000 LF               | 23,528  | Reduced due to CDA tie-in at Bickmore and not bringing offsite wells to on-site treatment plant.                                       |
| 2    | Well Locations       |                         |   |  |
|      | EW-4                 |                         |   | Moved 2,000 feet southwest, still on the Airport   |
|      | EW-7                 |                         |   | Moved 250 feet west  |
|      | EW-9                 |                         |   | Moved 220 feet north   |
|      | EW-10                |                         |   | Moved 450 feet southwest   |
| 3    | GAC Vessels          | 2 - dual 10K-lb vessels | 6 - dual 20K-lb vessels   | Increased GAC due to flow and additional compounds being treated   |
| 4    | Extraction Volume    |                         |   |  |
|      | County wells         | 900 gpm                 | 1,700 gpm   | Increased flow due to model update   |
|      | CDA wells            | 180+ gpm                | 615 gpm   | I-16, I-17, and I-18 included in IS. I-20 and I-21 added in to the design.   |
| 5    | Treatment Facilities | < 5,000 sq ft           | < 2,500 sq ft   | Smaller footprint due to GAC system being added to existing CDA treatment plant.   |
| 6    | Well Facilities      |                         |   | 20' antennas added to offsite well facilities. <a href="#">Additional FO cable being installed in City ROW &amp; SBC FCD property.</a> |
| 7    | Work Hours           | 7 AM to 8 PM            | Drilling and well installation needs to be 24/7 <a href="#">until well casings are installed.</a> | Page 13 of 58. All construction activities would occur during daylight hours, between 7 AM and 8 PM.                                   |