

From: Benitez, Ernesto I
To: [George Galvan, AICP](#)
Cc: [Lopez, Joel F](#)
Subject: RE: Holtville Substation
Date: Wednesday, November 1, 2017 10:39:14 AM
Attachments: [image002.png](#)


Good morning George,

The location of the substation serving Holtville is at the southeast corner of Melon Rd. and 6th St. The substation has 1-18 mva transformer with 3-distribution circuit feeders and 1-14 mva transformer with 3-distribution circuit feeders.

IID Energy has an existing distribution circuit feeder (H-14 circuit) along the west side of Melon & Underwood Rd. that our planning engineering group will need to perform distribution circuit analysis to verify capacity to serve your project.

Developer needs to submit service request application and all required plans to allow for an IID distribution circuit analysis.

Thank you,



Ernesto I. Benitez
Project Manager
Customer Project Development
Energy Department
Office No. : 760-482-3405
Cell Phone: 760-427-7381
Fax: 760-482-3401
Email: eibenitez@iid.com

From: George Galvan, AICP [mailto:jgalvan@theholtgroup.net]
Sent: Monday, October 30, 2017 8:19 AM
To: Benitez, Ernesto I <eibenitez@IID.com>
Subject: Holtville Substation

Good Morning Ernie,

Can you tell me the location and capacity of the substation serving Holtville? I'm working on a 152-unit apartment project at the southeast corner of Melon and Underwood in Holtville.

Sincerely,

George Galvan, AICP
Project Manager



The Holt Group

Engineering ■ Surveying ■ Planning

1601 North Imperial Avenue
El Centro, CA 92243

P: 760.337.3883

F: 760.337.5997

www.theholtgroup.net