

TO: Office of Planning and Research
 State Clearinghouse
 P.O. Box 3044, Room 113
 Sacramento, CA 95812-3044

FROM: Central Valley Flood Protection Board
 3310 El Camino Avenue, Suite 170
 Sacramento, CA 95821

SUBJECT: Filing of Notice of Determination pursuant to Public Resources Code § 21108.

State Clearinghouse Number (SCH No.): 2010024001

Project Title: Permit 19651: Yuba River Basin, California Project - Marysville Ring Levee Project Phases 2B and 3
 Utility Relocation: Segment B Power Pole and Electrical Facility Relocation

Project Applicant: Pacific Gas & Electric Company

Lead Agency/Address: Central Valley Flood Protection Board (CVFPB), 3310 El Camino Ave, Ste 170, Sacramento, CA 95821

Lead Agency Contact Person: Kalia Schuster c/o Department of Water Resources (916) 574-1429

Project Location/City/County: The project is located in Marysville, east of Highway 70, along the right (north) bank of the Yuba River at waterside locations in the proximity of 14th Street northeast to 17th Street in Yuba County.

Project Description: Approval of Permit No. 19651, under the California Code of Regulations, Title 23, Article 3, Section 6, for work within an adopted plan of flood control: To relocate the Smartville-Marysville 60 kV and Pease-Marysville-Harter 60kV electric transmission lines with overhead distribution lines along the waterside embankment of the right (north) bank of the Yuba River as part of Phase 3, Segment B of the USACE Marysville Ring Levee Project. Work includes installing 12 transmission poles (10 light-duty steel and 2 tubular steel), removing 12 transmission poles, removing a streetlight, and installing one wood distribution pole along with overhead electrical facilities.

This is to advise that the CVFPB, as the **Lead Agency**, approved the above described project on 11/7/2022 and made the following determinations regarding the above described project:

1. The project [will / will not] have a significant effect on the environment.
2. [An Environmental Impact Report / A Mitigated Negative Declaration] was prepared for the project.
3. Mitigation measures [were / were not] made a condition of approval of the project.
4. A Mitigation Monitoring and Reporting Plan [was / was not] adopted for this project
5. A Statement of Overriding Considerations [was / was not] adopted for this project.
6. Findings [were / were not] made pursuant to the provisions of CEQA.

Lead Agency Statement: The Supplemental Environmental Assessment/Initial Study/Mitigated Negative Declaration, with comments and responses, and record of approval is available to the general public at the CVFPB's office at the address listed above.

ORIGINAL SIGNED BY:

NOVEMBER 7, 2022

Signature Sarah C. Backus, Executive Officer

Date

Date Received for filing at OPR: