

State Water Resources Control Board

July 22, 2019

Governor's Office of Planning & Research

JULY 22 2019

STATE CLEARINGHOUSE

Monte Vista Water District
Attn: Van Jew
10575 Central Avenue
Montclair CA, 91763

RE: MONTE VISTA WATER DISTRICT (MVWD), MITIGATED NEGATIVE DECLARATION (MND) FOR THE MONTE VISTA WATER DISTRICT PLANT 30 WELLHEAD TREATMENT PROJECT (PROJECT); SCH # 2019079009

Dear Ms. Jew:

Thank you for the opportunity to review the MND for the proposed Project. The State Water Resources Control Board, Division of Drinking Water (State Water Board) is responsible for issuing water supply permits administered under the Safe Drinking Water Act and will require a new or amended water supply permit for the above referenced Project. A project requires a permit if it includes water system consolidation or changes to a water supply source, storage, or treatment. The State Water Board is a responsible agency pursuant to the California Environmental Quality Act (CEQA) and considers the above referenced document as adequate to meet water supply permit CEQA requirements.

The proposed Project includes installing a wellhead treatment facility that would provide groundwater treatment for Wells 30, 32, and 33. The proposed project consists of development of a Wellhead Treatment Plant within the existing Well 30 site to treat water delivered from MVWD Wells 30 and 32, and from Well 33, which is co-owned by both MVWD and the City of Chino. Phase 1 of the project will provide the capacity to treat up to 4,000 gallons per minute (GPM) and Phase 2 will facilitate the treatment of up to 6,000 GPM. The anticipated extraction rate from each well is about 2,000 GPM.

When the review process has ended, please forward the following items with your permit application to the San Bernardino District Office:

- Copy of the draft and final MND with any comment letters received and the lead agency responses as appropriate;
- Copy of the Resolution or Board Minutes certifying and adopting the MND;
- Copy of the stamped Notice of Determination (NOD) filed at the San Bernardino County Clerk's Office or Governor's Office of Planning and Research, State Clearinghouse.

Please contact Eric Zuniga at San Bernardino District Office, at (909) 383-4328) or Eric.Zuniga@waterboards.ca.gov if you have any questions regarding permitting requirements.

E. JOAQUIN ESQUIVEL, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

Sincerely,

Nikolas Storm
Scientific Aid
1001 I Street, 16th Floor
Sacramento CA, 95814

A handwritten signature in blue ink, appearing to read 'N Storm', is positioned to the right of the typed name and address.

cc: Office of Planning and Research, State
Clearinghouse

Eric Zuniga
San Bernardino District