

NOTICE OF DETERMINATION

TO: Governor's Office of Planning and Research FROM: State Water Resources Control Board
State Clearinghouse DDW Hollywood District, Southern CA
Office P.O. Box 3044 500 N. Central Avenue Suite 500
Sacramento, CA 95812-3044 Glendale, CA 91203

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 of the Public Resources Code

SCH#:

WATER SYSTEM #: 1910041 Three Valleys Municipal Water District (TVMWD)

PROJECT TITLE: TVMWD Grand Avenue Groundwater Well and Pipeline

LEAD AGENCY: Three Valleys Municipal Water District, 1021 E. Miramar Ave, Claremont, CA 91711

CONTACT PERSON: Ben Peralta Jr., P.E. (Project Manager)

PHONE NUMBER: 909-621-5568 Ext 109

RESPONSIBLE AGENCY: State Water Resources Control Board (Division of Drinking Water)

CONTACT PERSON: James Ko P.E.

PHONE NUMBER: 818-551-2007

PROJECT LOCATION: Grand Avenue and Padua Avenue, Claremont CA, (34.120437, -117.702737)

PROJECT DESCRIPTION: The proposed is located on property owned by TVMWD and involves constructing a new production well and associated pipeline within the City of Claremont in order to increase TVMWD's capability to extract groundwater. The Project would pump groundwater from the upper Claremont Heights Basin and would discharge it into an 8-inch diameter untreated water main that would be routed along Grand Avenue and Baseline Road to its intersection with Padua Avenue. A 12-inch diameter pipe would be proposed from this intersection to the Miramar Treatment Plant, for a total of 6,100 linear feet of ductile iron pipe.

PUBLIC AGENCY APPROVING PROJECT AND CARRYING OUT PROJECT: This is to advise that the State Water Board has issued a drinking water supply permit **1910041 PA-004** for the above described Project on **8/14/2020**, and has made the following determinations regarding the Project:

1. The Project **will not** have significant effects on water quality.
2. A **Mitigated Negative Declaration (MND)** was prepared for this Project pursuant to the provisions of the California Environmental Quality Act (CEQA).
3. Mitigation measures were made a condition of the **TVMWD's** approval of the project.
4. A mitigation monitoring and reporting plan **was** adopted by the **TVMWD** for this Project.
5. A Statement of Overriding Considerations **was not** adopted by the **TVMWD** for this Project.
6. Determinations were made pursuant to the provisions of CEQA.

This is to certify that the record of permit issuance for the Project is available to the general public at the State Water Board, Division of Drinking Water District Office noted above. The **MND** is available from the lead agency.

Signature:  Date: 08/14/2020

Name: Dmitriy Ginzburg, P.E. Title: District Engineer

Governor's Office of Planning & Research

Aug 14 2020

STATE CLEARINGHOUSE