

Notice of Determination

Appendix D

To:

Office of Planning and Research
 U.S. Mail: Street Address:
 P.O. Box 3044 1400 Tenth St., Rm 113
 Sacramento, CA 95812-3044 Sacramento, CA 95814

County Clerk
 County of: Monterey
 Address: 168 West Alisal Street #1
Salinas, California 93901

From:

Public Agency: Carmel Area Wastewater District
 Address: 3945 Rio Road
Carmel, California 93922

Contact: Rachel Lather
 Phone: (831) 624-1248

Lead Agency (if different from above):
(same as above)

Address: _____

Contact: _____

Phone: _____

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 2020080552

Project Title: Rancho Cañada Sewer Replacement Project

Project Applicant: Rachel Lather, Carmel Area Wastewater District, 3945 Rio Road, Carmel, CA 93922

Project Location (include county): Rancho Canada Park, Via Mallorca Rd, Via Petra Rd, Monterey County

Project Description:

Project consists of replacing an existing sewer main, that currently experiences capacity issues and surcharging because of current flows, with installation of a total of 4,240 linear (LF) of new 15-inch diameter gravity sewer main and 790 LF of 8-inch diameter sewer main will be replaced with polyvinyl chloride (PVC) pipe, the majority of which would be located alongside the existing alignment.

This is to advise that the Carmel Area Wastewater District has approved the above
 Lead Agency or Responsible Agency

described project on 10/29/2020 and has made the following determinations regarding the above
 (date)
 described project.

1. The project [will will not] have a significant effect on the environment.
2. An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.
 A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures [were were not] made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan [was was not] adopted for this project.
5. A statement of Overriding Considerations [was was not] adopted for this project.
6. Findings [were were not] made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the negative Declaration, is available to the General Public at:

3945 Rio Road, Carmel, CA 93922 and online at www.cawd.org

Signature (Public Agency): Rachel Lather Title: Principal Engineer

Date: 10/29/2020 Date Received for filing at OPR: _____