
Appendix IS-10

Utility Memorandum



M E M O R A N D U M

Date: October 16th, 2020
To: Gruen Associates
From: Kimley-Horn and Associates, Inc.
Subject: Cheval Blanc Beverly Hills – 449 (Inclusive of 451 and 453), 456, and 468 N. Rodeo Dr., 461 (Inclusive of 463 and 465) N. Beverly Dr. -- Utility Memorandum

Introduction

Kimley-Horn and Associates, Inc. is providing this utility investigation technical memorandum based on our review of the proposed Project's Entitlement Submittal Package dated July 17, 2020, and our understanding of the existing utilities surrounding the site in coordination with the Plumbing Engineer, Dry Utility Consultant, and the City of Beverly Hills. A summary of our utility analysis for the Project is provided below.

Sanitary Sewer:

a. Existing Improvements: Existing sewer lines within Beverly Hills are maintained by the City's Public Works Department. The existing sewer system for the street frontage is described further below:

- **Alley:** There is an existing 8" sewer main line that flows southeast, located at the centerline of the alley that exists within the boundaries of the proposed development. The 8" sewer main connects to an 18" sewer main at an existing manhole within Wilshire Boulevard. See Attachment D – City of Beverly Hills Existing Sewer Main Map for additional information.

The existing commercial building at the north side of S. Santa Monica Blvd. has an existing sewer lateral service which connects to the existing 8" sewer main within the alley after the terminal manhole. This line will likely need to be relocated to tie into the main line several hundred feet to the east on S. Santa Monica Blvd in coordination with the City. See Attachment C – Existing Sewer Plan and Attachment F – Existing Composite Utility Plan for additional information.

b. Proposed Improvements: The following are based on the Entitlement Submittal Package dated July 17, 2020:

Proposed Project Development Programming: The Proposed Project is a mixed-use development with hotel, private club, restaurant, spa, and retail uses and related amenities. See the table on page 2 for detailed development programming and page 3 for specific plan maximum allowances.

PD Table 1 – Development Program		
	Subtotals	Totals
Total Floor Area		(212,034 sf on the conceptual Architectural Plans submitted with the Specific Plan, dated 10/19/20)
Hotel Rooms		Up to 115
Hotel Floor Area, including:		
Rooms (with adjoining circulation)	120,129 sf	
Hotel Lobby and circulation (ground floor)	6,609 sf	
Wellness Center excluding deck	4,924 sf	
Spa	12,226 sf	
Central Kitchen/Employee Facilities/Office/BOH	14,638 sf	
Member’s Club Floor Area, including:		
Meeting and Screening Rooms, Lounge (Level 3)	7,001 sf	
Member’s Club Lobby (ground floor)	1,197 sf	
Total Hotel, Club and Appurtenant Uses		166,724 sf*
Restaurant Floor Area, including:		
Ground Floor/Level 2 Restaurant, Lounge, Bar, and Kitchen (indoor)	8,085 sf	
Levels 6 and 7 Restaurant, Lounge, Bar, and Kitchens (indoor)	12,249 sf	
<i>Outdoor Dining/Bar (not included in floor area)</i>	<i>4,760 sf*</i>	
Total Restaurant		20,334 sf
Total Retail		24,976 sf
Parking Spaces Provided		178
Site Area (Total)		55,608 sf or 1.277 ac
Site Area (exclusive of alley) for FAR calculations		52,607 sf or 1.208 ac
Floor Area Ratio (FAR) on Plans*		4.03
Above Grade FAR on Plans*		3.75
Maximum FAR Ratio*		4.20
Maximum Above-Ground FAR*		3.91
* Exterior walls, stair shafts, elevators, elevator lobbies less than 100 sf per cab, parking spaces and access, mechanical equipment/machinery rooms, outdoor dining areas, decks and balconies, and 2,000 sf of storage per below grade parking level are not included in floor area calculations.		

Specific Plan Table 1 – Development Program¹			
	Number of Hotel Rooms	Floor Area (SF)	Max. Floor Area Ratio (FAR)
Above Grade Maximum Floor Area and FAR		205,700	3.91
Below Grade Floor Area and FAR		<i>varies</i>	<i>varies</i>
Total Maximum Floor Area and FAR		220,950	4.2
Floor Area By Use ²			
• Hotel Rooms, Club and Appurtenant Uses	Up to 115	166,720	
• Restaurants/Bars/Lounges ³		20,330	
• Retail		24,980	
<p>1. The Development Program sets forth the maximum allowed above grade and total floor area and FAR. Below grade floor area and FAR may vary based on actual above grade floor area and FAR, subject to the total maximum floor area and FAR. Site area for FAR purposes is 52,607 square feet. Floor area excludes exterior walls, stair shafts, elevators, elevator lobbies less than 100 square feet per cab, parking spaces and access, maintenance equipment/machinery rooms, outdoor dining areas, decks and balconies, and 2,000 square feet of storage per below grade parking level.</p> <p>2. The Development Program includes the maximum number of hotel rooms and the approximate amount of space that may be allocated to each general use in the building. The floor area by use may be decreased or increased by up to 5% pursuant to Section 6.3; however, the maximum floor area of the Project may not exceed 220,950 square feet.</p> <p>3. Excludes 4,720 square feet of outdoor dining on private property</p>			

Proposed Sewer Demand:

Based on the summary below, the Project will generate 0.24 cfs (155,138 gpd) of sewer discharge to the existing 8" sewer line within the Alley. Based on the existing development areas of 33,436 square feet of commercial space and 23,351 square feet of institutional space, we estimate the existing sewer generation for the site to be 0.022 cfs (14,200 gpd). Thus, the net increase of sewage demand for the proposed project is 0.22 cfs (142,209 gpd).

Our detailed analysis based on the Los Angeles County sewer loading per unit or usage is summarized in the tabulation provided below. It should be noted that the restaurant use includes the ground floor/level 2 restaurant, 6th floor/7th floor restaurant, and the outdoor dining and bar area. The spa use includes the spa and wellness center. The office use includes the central kitchen/employee facilities/office/ BOH, member's club, and hotel and member's club lobbies as described in the table on page 2. See Attachment I – LA County Sewage Generation Table for average daily flow factors.

EXISTING FLOW - Cheval Blanc Beverly Hills

UNIT TYPE	SIZE	AREA (SF)	NUMBER	Unit of Measure	FLOW GPD*	TOTAL FLOW (GPD)
COMMERCIAL	Retail	33436	1	1000 sf	100	3344
COMMERCIAL	Institutional	23351	1	1000 sf	100	2335

TOTAL GPD= 5679

*GPD TAKEN FROM COUNTY OF LOS ANGELES SEWAGE GENERATION TABLE

TOTAL CFS = 0.009

TOTAL PEAK CFS= 0.022

PEAK FACTOR =2.5

TOTAL PEAK GPD= 14197

PROPOSED FLOW - Cheval Blanc Beverly Hills

UNIT TYPE	SIZE	AREA (SF)	NUMBER	Unit of Measure	FLOW GPD*	TOTAL FLOW (GPD)
COMMERCIAL	Hotel	-	115	Rooms	150	17250
COMMERCIAL	Retail	24976	-	1000 sf	100	2498
COMMERCIAL	Restaurant	25094	-	1000 sf	1000	25094
COMMERCIAL	Office	29445	-	1000 sf	200	5889
COMMERCIAL	Spa	17150	-	1000 sf	600	10290

TOTAL GPD= 61021

*GPD TAKEN FROM COUNTY OF LOS ANGELES SEWAGE GENERATION TABLE

TOTAL CFS = 0.094

TOTAL PEAK CFS= 0.24

PEAK FACTOR =2.5

TOTAL PEAK GPD= 152552

Two new 8" sewer laterals will likely be proposed. One will connect to the existing 8" sewer line in the Alley, and the other to the new 8" line extension in S. Santa Monica Blvd. See Attachment E – Proposed Sewer Plan for additional information. Size, location, and number of laterals is subject to design development and coordination with the Project's Plumbing Engineer.


Will Serve Letter & Sewer Capacity:

The City of Beverly Hills does not provide a Will Serve Letter for sanitary services. Thus, we have calculated the existing sewer capacity based on estimated commercial acreage and Los Angeles County zoning coefficients for estimated average daily sewage flow (0.015 cfs for commercially zoned properties).

Based on the estimated 14.0 acres of commercial development between N. Rodeo Drive and N. Beverly Drive that discharge to the existing 8" sewer main in the alley, we assume that the total peak flow currently within the pipe is 0.48 cfs (310,200 gpd). With the proposed development, we would assume this flow would increase to 0.70 cfs, which would make the pipe run about 41.5% full. Therefore, we assume the existing 8" sewer pipe in the alley has adequate capacity to serve the proposed development. See image below for sewer capacity calculation.


Cross Section for Circular Pipe - 1

Project Description	
Friction Method	Manning Formula
Solve For	Normal Depth
Input Data	
Roughness Coefficient	0.012
Channel Slope	0.022 ft/ft
Normal Depth	3.3 in
Diameter	8.0 in
Discharge	0.70 cfs



V: 1
H: 1

See image below for location of existing 8" sewer main and 14.0 acres existing commercial properties that are assumed to be currently discharging into the pipe.



Based on the existing sewer information provided by the City on 9/29/2020, we can assume for the wet condition for the 8" existing sewer main consists of a d/D of 0.06 and existing flow of ~0.02 cfs downstream at the intersection of the alley and Brighton Way. Our analysis based on the land use of the surrounding properties contributing to the flow of the 8" sewer main assumed an existing d/D of 0.34 and an existing flow of ~0.48 cfs. Thus, we can confirm based on our conservative analysis and the additional information provided by the City that there is sufficient capacity in the existing 8" sewer main to handle our proposed development. See image below for existing d/D and flow capacity information as provided by the City.



Our conclusion based on the analysis is that there is sufficient capacity to serve the project based on the development programming in PD Table 1 on Page 2 and the Specific Plan Table 1 on Page 3.

Sewer Relocation:

The commercial properties to the north of S. Santa Monica Blvd. are served by a sewer lateral which is assumed to connect to the existing 8" main in the alley after the terminal manhole. Since this service will be impacted by the proposed development, it will be rerouted in order to continue providing service to these neighboring properties. Based on email correspondence from Samer Elayyan, PE, Project Manager for City of Beverly Hills Public Works Department on February 5th, 2020, a sewer line relocation concept has been preliminarily approved. Engineering plans will be prepared and submitted to the City showing plan and profile views of the new sewer line which will travel east on S. Santa Monica Blvd. to tie into the existing sewer manhole between N. Beverly Drive and N. Canon Drive. The new sewer line will be designed to flow at a maximum capacity of 50% full. See Attachment E – Proposed Sewer Plan for preliminary routing.

Domestic/Fire Water

- a. **Existing Improvements:** Existing water lines within the City of Beverly Hills are operated by the Beverly Hills Water Department within Public Works. The information summarized below is based on the ALTA/Topographic Survey prepared by Calvada Surveying, Inc. dated 4/28/2020, Entitlement Submittal Package, Preliminary Fixture Counts prepared by tk1sc, and the Preliminary Meeting with Public Works staff on 12/19/2019.

1) **Water Mains:**

- S. Santa Monica Blvd: There is a 12" water line along S. Santa Monica Blvd. located approximately 5' from the southern curb underneath the eastbound lanes. An existing electrical line will be crossed to connect to the existing 12" water line.
- Alley: There is an 8" water line within the existing alley located on the eastern edge which connects to the 12" line in S. Santa Monica Blvd. and the 16" line in Brighton Way.

This line will likely be removed and rerouted where it is in conflict with the proposed development. It has been proposed to the City that the water line be looped within the alley to tie back into the main line on Brighton Way. The City has reviewed the proposed relocation and performed preliminary hydraulic calculations. Initially they take no exception to the design based on the email from Greg Ripperger dated 2/6/2020. Once the Project receives preliminary conditions from the Planning Department and the Fire Department, the City will move forward with preparing a technical memorandum and continue the Will Serve process for the Project. Engineering Plan and Profiles for the proposed loop and relocation will also be prepared and submitted to the City for approval. See Attachment A – Water Will Serve Letter and Availability Request for additional information.

- Brighton Way: There is a 16" water line located within Brighton way.

See Attachment B – Proposed Water Plan and Attachment F – Existing Composite Utility Plan for additional information.

- 2) **Fire Hydrants:** The existing site has one fire hydrant near the northwestern corner of the property line along South Santa Monica Blvd. based on the ALTA/Topographic Survey.
- 3) **Water Meters:** There are 7 existing water meters shown around the site based on the ALTA/Topographic Survey. All 7 meters are located within the alley and are serviced by the existing 8" water main line.

The Project should consider reusing the meters and laterals to the extent necessary and feasible based on the locations noted on the ALTA/Topographic Survey and in coordination with the City. The presence of these meters gives an indication that the existing sanitary sewer, gas, and telecommunication lines can be crossed over from the site for the proposed water and fire services.

- b. **Proposed Improvements:** The following are based on the Preliminary Fixture Counts dated August 21, 2019, prepared by tk1sc:

Proposed Domestic Water Demand: The Estimated Potable Water Demand has an average daily demand of 300 GPM. The domestic water service will likely connect to the existing 8" main in the alley south of the Project. Existing water meter(s) will be utilized if deemed feasible by the City. The plumbing engineer will assess the need for any booster pump for the Project in coordination with the City. If needed the booster pump will be located within the building footprint.


See Attachment A – Water Will Serve/Availability Request and Attachment B – Proposed Water Plan for additional information.

Proposed Fire Service Connection & Water Pressure: The proposed demand for fire water will be determined by a fire water consultant. Based on required service size and location of firewater infrastructure within the building, the firewater service will connect to either the 8" water line in the Alley or the 12" water line in S. Santa Monica Blvd.

Water Conservation Features: The Project will comply with the City's Low Impact Development (LID) guidelines, which require implementation of a stormwater treatment system that captures a required runoff treatment volume. The required runoff treatment volume is based on the 85th Percentile of rainfall per Los Angeles County Department of Public Works Requirements. LID for the Project will need to consider infiltration, rainwater capture and reuse and a combination of treatment systems approved by the City. If infiltration on the site is not feasible due to soil conditions or other limiting factors, the Project will analyze implementation of a rainwater harvesting system such as a cistern/underground detention tank, which would treat and capture rainwater before metering it out to the City's storm drain system. See page 7 for a sample rainwater harvesting system. Additional LID information is available in the Preliminary Hydrology and Hydraulics Report prepared for the Project.

The Project's Plumbing Engineer will limit indoor water use by requiring plumbing fixtures to meet or exceed the water use limits as prescribed by the 2013 California Green Building Standards Code (CALGreen). 2013 CALGreen sets a 20% reduction of water use as compared to previous editions of CALGreen and sets a nationwide standard in green building and water conservation.

Sample Rainwater Harvesting System



Our conclusion based on the analysis is that there is sufficient capacity to serve the project based on the development programming in PD Table 1 on Page 2 and the Specific Plan Table 1 on Page 3.

Electrical:

- a. **Existing Improvements:** Existing electric lines within Beverly Hills are maintained by Southern California Edison (SCE). The existing electrical system for the street frontage is described further below:
 - **S. Santa Monica Blvd:** There is an existing main line distribution system located along S. Santa Monica in the eastbound lanes that consists of vaults, transformers, switches and cable. SCE maintains a 16kV system that services the surrounding area with multiple circuits connecting in the vault that is in the eastbound lanes.
 - **Alley:** There is an existing main line distribution system located within the alley that consists of vaults, pull boxes, transformers and cable. The distribution system connects to the vault that is in the eastbound lanes of S. Santa Monica Blvd.

Existing SCE conduit and structures within the Project boundaries will be capped and/or removed. SCE has completed a preliminary relocation design that will allow for the properties bordering the alley to be served from the circuit on Brighton Way. SCE is currently moving towards a final design for the electrical relocation portion of the Project. See Attachment G – SCE Preliminary Design for additional information.

- **Brighton Way:** There is an existing main line distribution system located along the south side of Brighton Way that consists of vaults, transformers, switches and cable. SCE maintains a 16kV system that services the surrounding area with multiple circuits connecting in the vault that is in the on Brighton Way.
- b. **Proposed Improvements:** The following are based on the Preliminary Design dated August 21, 2019, prepared by tk1sc (Electrical Engineer):

Proposed Project Development Programming: The proposed Project is a mixed-use development with hotel, private club, restaurant, spa, and retail uses and related amenities. See the table on page 2 for the development programming.

Proposed Electric Demand:

Based on the development program, the Project will generate 5.69MVA of electrical demand. The new service will be a 16kV service fed from a new SCE vault on Beverly Drive approximately 175' south of S. Santa Monica Blvd.

SCE engineering has reviewed the proposed new load and has agreed the Project can be served by their existing circuits. The new service will connect from the vault on Brighton Way to a new vault on Beverly Dr. New conduit will be installed along the west side of Beverly Dr between vaults.

This report will be updated with the results of a Will Serve Letter once it has been received from SCE.

Our conclusion based on the analysis is that there is sufficient capacity to serve the project based on the development programming in PD Table 1 on Page 2 and the Specific Plan Table 1 on Page 3.

Natural Gas

- a. **Existing Improvements:** Existing gas lines within Beverly Hills are maintained by Southern California Gas Company (SCG). The existing gas system for the street frontage is described further below:

- S. Santa Monica Blvd: There is an existing 2" main line distribution system located along S. Santa Monica in the eastbound lane.
- Alley: There is an existing 3" main line distribution system located within the alley that connects S. Santa Monica Blvd and Brighton Way.

Existing SCG pipe within the site boundaries will be capped in the alley and removed. SCG is completing additional engineering to confirm if additional upgrades are necessary to feed the Project and surrounding properties.

- Brighton Way: There is an existing 3" main line distribution system that crosses Brighton Way and continues south in the Alley.

See Attachment H – SCG Existing Facility Map for additional information.

- b. **Proposed Improvements:** The following are based on the Preliminary Design dated August 21, 2019, prepared by tk1sc (Plumbing Engineer):

Proposed Project Development Programming:

The Proposed Project is a mixed-use development with hotel, private club, restaurant, spa, and retail uses and related amenities. See the table on page 2 for detailed development programming.

Proposed Natural Gas Demand:

Per the Project MEP Standards, we will be researching alternatives to gas-fired water and space heating equipment in an effort to reduce the Project's environmental impacts and CO2 emissions. Natural gas may still be used as a back-up to the alternative water heating systems.

There are multiple kitchens in the Project and some retail space that may require natural gas for cooking. If the Project processes laundry in-house, gas may be required for water heating due to the high temperature hot water supply that is required for commercial laundry applications. Thus, estimated natural gas demands require further analysis.

If the Project is not designed around natural gas restrictions (i.e., does not implement natural gas alternatives), the total gas demand would likely be in the range of 5,000,000 to 6,000,000 btuh. Alternate water heating concepts may cut that number by 40%.

SCG engineering has reviewed the proposed new load and has agreed the Project can be served by their existing system. SCG is continuing with its engineering analysis to determine if additional upgrades to their system are necessary.

This report will be updated with the results of a Will Serve Letter once it has been received from SCG.

Our conclusion based on the analysis is that there is sufficient capacity to serve the project based on the development programming in PD Table 1 on Page 2 and the Specific Plan Table 1 on Page 3.

Attachments:

Attachment A – Water Will Serve Letter and Availability Request

Attachment B – Proposed Water Plan

Attachment C – Existing Sewer Plan

Attachment D – City of Beverly Hills Existing Sewer Main Map

Attachment E – Proposed Sewer Plan

Attachment F – Existing Composite Utility Plan

Attachment G – SCE Preliminary Design

Attachment H – SCG Existing Facility Map

Attachment I – LA County Sewage Generation Table

Attachment A: Water Will Serve Letter and Availability Request



Vince Damasse, Water Resources Manager
Department of Public Works Services

December 26, 2019

BFKN
200 W. Madison Street, Suite 3900
Chicago, Illinois 60606

Attention: Dennis Farrazzano

Subject: Deposit Request for Water System Analysis
456-468 N. Rodeo Drive, Beverly Hills
Charge Code: HYDANL
Customer No. 14495

Dear Mr. Farrazzano,

In regards to your request for new water service connections for the proposed new Mixed Use project at 456-468 N. Rodeo Drive. In the City of Beverly Hills, the project is within the service boundary of the City of Beverly Hills water system.

The estimated cost to complete the hydraulic analysis for the project is \$15,000. This is only an estimate. Should the actual cost be less than this amount, the difference will be returned to you. Should the actual cost exceed this amount or if the account balance is less than 10 percent of the original deposit, an additional deposit letter will be sent. The City will prepare a technical memorandum indicating the results of our analysis and hydraulic modeling of the new development and will conform to the criteria as included in the City's 2009 Water Master Plan. The City will issue you a finalized copy of the memorandum.

The City will need as much of the following items as soon as possible in electronic format (PDF) to complete the planning phase:

- ◆ Site Improvement Plans
- ◆ Street Improvement Plans
- ◆ Sanitary Sewer Plans and Profile
- ◆ Fire Department Requirements and New Fire Hydrant Location map
- ◆ Domestic Water Demand Calculations
- ◆ Fire Service Requirements and Demand
- ◆ Fire Hydrant Flow Testing (if available)

To begin the hydraulic analysis portion of the project, please send a check in the amount of \$15,000. In order to verify your understanding of the above conditions, please sign a copy of this letter and return it along with your deposit check. If you have any questions regarding the above required information, please feel free to contact Greg Ripperger of Civiltec Engineering, Inc. at (626) 357-0588 or gripperger@civiltec.com. We are looking forward to working with you on this important new project.


All checks should be made payable to the City of Beverly Hills referencing your customer number, payable at:

(TO EXPEDITE PAYMENT PLEASE DO NOT MAIL CHECK)

City Hall Cashier's Office
City of Beverly Hills
455 N. Rexford Drive
Beverly Hills, CA 90210

Sincerely,

CITY OF BEVERLY HILLS



Vince Damasse, P.E.
Water Resources Manager

Agreed and Accepted:

Date



City of Beverly Hills Public Works Services

345 Foothill Road, Beverly Hills, CA 90210

310-285-2467 ■ 310-278-1838 (fax) ■ www.beverlyhills.org

Water Will-Serve/Availability Request

DATE: 12/17/19

Delivery of Will-Serve Notice: Mail Pick-up Email Fax#

SECTION I

4343016002, 4343016001, 4343016023, 4343016019
 APN: _____ Property Address: 456 N Rodeo, 461 N Beverly, 468 N Rodeo, 437 N Beverly
 Lot No: 1,2,3,21,22,23,24 Tract or Block: 2
 Is there existing service to this parcel? Yes No If so, Account Number: Unknown

PLANNED USE: Multiple Units: # of Units _____
 Single-Family Residential Apartments
 Multi-Family Residential Condos
 Commercial Fire line Landscape Hotels/Motels

Type (restaurant, car wash, etc.) _____

Total number of meters requested: 1 **Size of Meter(s) Requested:** 4"

Name/Company: 456 N Rodeo Drive LLC, 461 N Beverly Drive LLC, 468 N Rodeo Drive LLC
 Mailing Address: 200 West Madison St, Suite 3900, Chicago, Illinois 60606
 Primary Phone: 312-984-3180 Secondary Phone: 951-536-2092
 Email Address: julie.rademaker@bfkn.com & dkanowsky@scelectricalfirm.com

SECTION II

Estimated Potable Water Demand*					
Average Day Demand* (ADD):		Maximum Day Demand* (MDD):		Peak Hour Demand* (PHD):	
Domestic:	300 GPM	Domestic:	GPM	Domestic:	GPM
Irrigation:	unk GPM	Irrigation:	GPM	Irrigation:	GPM
Fire:	unk GPM	Fire:	GPM	Industrial:	GPM
Total:	300+ GPM	Total:	GPM	Total:	GPM

*ATTACH REFERENCES USED AND CALCULATIONS FOR TOTAL WATER DEMAND (INCLUDING SITE PLAN SHOWING PROPOSED CONNECTIONS).
 Comments:
Note: This request is based on previous development programming and is currently being updated to reflect current programming.

FOR CITY PERSONNEL USE ONLY

COBH Service Area? Yes No
Main upsizing required? Yes No

Capacity & Groundwater Supply and Connection Fee paid? Yes No
Existing Main Location & Size _____

Comments: _____

APPROVAL:

Signature: _____ Date: _____

I understand that the City of Beverly Hills is willing to supply water to the subject property with the following conditions: **(Conditions are subject to change without notice.)**

1. This Water Will-Serve Request is not a guarantee of service. All conditions of approvals must be met prior to connection to the public water system.
2. This water will serve letter is only valid for the approved services that were submitted to and approved by the City. Should additional water services be requested, additional analysis, plan check, and fees may apply.
3. Applicants for Will Serve Letters shall be responsible for payment or reimbursement to the City as provided in the City's adopted rates, charges, and fees in existence on the date that a request by the applicant for connection to the City's water system is made. These fees may include but are not limited to processing, plan check, permit, inspection, capacity, supply, and other related impact fees as adopted by or in effect by the City at the time of applicant's water will serve request.
4. This determination of water availability will remain valid for two (2) years from the date of this letter. If the installation of these water improvements has not been completed within this two (2) year time frame, the City is under no obligation to serve the project and this letter becomes null and void. After the availability period has expired, the applicant must re-apply for this water will serve / availability letter unless an extension of the water will serve letter has been requested and approved by the City. Additional processing, plan-checking, and associated fees may apply.
5. Exact location of the water meter is to be determined by owner and approved by the City of Beverly Hills.
6. Detailed calculations and plans may be required for City approval prior to installation of water services.
7. Owner should confirm that mainline pressure is sufficient to serve the planned elevation of any improvements. In some cases, pressure-reducing valves or booster pumps may be required.
8. Developer or Applicant shall abide with the City's ordinances, codes, applicable laws and regulations including but not limited to water conservation, water contingency, water supply, or related ordinances in effect at the time of this Will Serve request, or as modified from time to time by the City Council.
9. If the above-referenced project includes commercial, industrial, landscaping, or fire services, all such services shall require backflow prevention devices installed and tested in accordance with the City's policy, requirements, and specifications prior to being constructed.
10. If a proposed project and/or development requires the construction of new or additional City water infrastructure improvements in order to provide the water services requested, the applicant will be required to enter into a Water Services Conditions Agreement between the applicant and the City.
11. The Water Services Conditions Agreement ("WSCA") will set forth all terms and conditions of water service for the applicant by the City and will describe in detail the responsibilities of the applicant and the City with respect to the construction of and payment for any required City water infrastructure improvements. Unless otherwise noted or agreed upon, the applicant as a result of his developer impacts to the City's water system shall be responsible for the planning, design, and construction of the additional water infrastructure improvements required to serve his new Development and/or project.
12. In the event that a WSCA is required for the applicant's proposed development or project, the applicant will be responsible to execute and deliver the WSCA prior to approval of project improvement plans by the City and to pay or to reimburse the City for fees and expenses incurred by the City for its preparation of the WSCA.

Signed: David Kanowsky
 Owner Agent

Printed Name: David Kanowsky

FOR CITY PERSONNEL USE ONLY

COBH Service Area? Yes No
Main upsizing required? Yes No

Capacity & Groundwater Supply and Connection Fee paid? Yes No
Existing Main Location & Size _____


Comments: _____

APPROVAL:

Signature: _____ Date: _____

Attachment B: Proposed Water Plan

BH WATER - PROPOSED



BH WATER TO CAP EXISTING WATER MAIN

BH WATER TO CAP EXISTING WATER MAIN

ENGINEERING NEEDED TO DETERMINE IF CURRENT WATER SYSTEM CAN SUPPLY NEW BUILDING. CITY TO DETERMINE REQUIREMENTS.

LOOPED SYSTEM WITH WATER RELEASE MAY BE REQUIRED

LEGEND

EXISTING	-----
RELOCATION	—————
SERVICE	—————


SITE PLAN
NOT TO SCALE

3				FUNCTION	CONTACT	PHONE NO	DATE
2				PROJECT MGR	D. KANOWSKY	951.536.2092	12.17.19
1				ENGR - POWER			
REV#	DATE	BY	DESCRIPTION	ENGR - GAS			
COUNTY				DRAWN BY			
LOS ANGELES				CHECKED BY			
				APPROVED BY			

CHEVAL BLANC					
RELOCATION OF UTILITIES					
RODEO DR & SANTA MONICA BLVD & BEVERLY DR, BEVERLY HILLS					
DESIGNED BY SOUTHERN CALIFORNIA ELECTRICAL FIRM				SCALE	PAGE
				N/A	10 OF 12

Attachment C: Existing Sewer Plan

BH SEWER - EXISTING




LEGEND

EXISTING	-----
RELOCATION	-----
SERVICE	-----

SITE PLAN
NOT TO SCALE

3				FUNCTION	CONTACT	PHONE NO	DATE
2				PROJECT MGR	D. KANOWSKY	951.536.2092	2.5.20
1				ENGR - POWER			
REV#	DATE	BY	DESCRIPTION	ENGR - GAS			
COUNTY				DRAWN BY			
LOS ANGELES				CHECKED BY			
				APPROVED BY			
CHEVAL BLANC							
RELOCATION OF UTILITIES							
RODEO DR & SANTA MONICA BLVD & BEVERLY DR, BEVERLY HILLS						SCALE	PAGE
DESIGNED BY SOUTHERN CALIFORNIA ELECTRICAL FIRM						N/A	11 OF 12

Attachment D: City of Beverly Hills Existing Sewer Main Map



Legend

Connections to Other Systems

Entering System

- City of LA

Leaving System


- City of LA
- City of West Hollywood
- LACSD
- Manholes

Sewerlines

- <15"
- 15"
- 18"
- 21"
- 24"
- 27"
- 30"
- 32"
- 33"
- 36"

City of Beverly Hills

City Boundaries



Source:
City of Beverly Hills, 2009

City of Beverly Hills
Existing Large Diameter Mains



Exhibit 2-2

Attachment E: Proposed Sewer Plan


BH SEWER - PROPOSED



NEW SEWER PIPE TO BE INSTALLED TO CONNECT WITH EXISTING SEWER EAST OF BEVERLY

EXISTING SEWER MANHOLE

NEW SEWER MANHOLE



LEGEND


EXISTING	-----
RELOCATION	—————
SERVICE	—————

SITE PLAN
NOT TO SCALE

3				FUNCTION	CONTACT	PHONE NO	DATE
2				PROJECT MGR	D. KANOWSKY	951.536.2092	2.5.20
1				ENGR - POWER			
REV#	DATE	BY	DESCRIPTION	ENGR - GAS			
COUNTY	LOS ANGELES			DRAWN BY			
				CHECKED BY			
				APPROVED BY			


CHEVAL BLANC RELOCATION OF UTILITIES RODEO DR & SANTA MONICA BLVD & BEVERLY DR, BEVERLY HILLS DESIGNED BY SOUTHERN CALIFORNIA ELECTRICAL FIRM				SCALE	PAGE
				N/A	12 OF 12

Attachment F: Existing Composite Utility Plan



LEGEND

	EXISTING AT&T
	EXISTING CITY FIBER OPTIC
	EXISTING CITY ST. LT./TR. SIGNAL
	EXISTING SOCAL GAS
	EXISTING SCE
	EXISTING SEWER
	EXISTING STORM DRAIN
	EXISTING WATER
	EXISTING CITY ST. LT./TRAFFIC SIGNAL ELECTROLIERS
	EXISTING SCE VAULT
	EXISTING AT&T/COMM/SEWER MANHOLE



GENERAL NOTE:
 ALL UTILITIES PLOTTED PER UTILITY/CITY DRAWINGS
 ALL FACILITIES TO BE FIELD VERIFIED BEFORE
 CONSTRUCTION

1 COMPOSITE UTILITY PLAN
 1" = 30'

PROJECT NAME
 CB-EX COMPOSITE UTILITY

STATUS
 PRELIM

OWNER INFORMATION:

**SANTA MONICA BLVD.
 RODEO TO BEVERLY**
 RODEO DR., BEVERLY HILLS, CA
 90210

PROJECT MANAGER/PLANNER
 D. KANOWSKY



EX. COMPOSITE UTILITY PLAN

REVISIONS



NO.	REVISION	DATE

DATE
 10/16/19

SHEET NO.

1 OF 1


Attachment G: SCE Preliminary Design



SINGLE LINE LEGEND

- CIRCUIT 1 = BUNNY 16KV % BEVERLY SUB
- CIRCUIT 2 = DANIELS 16KV % BEVERLY SUB
- CIRCUIT 3 = LUCKMAN 16KV % BEVERLY SUB
- CIRCUIT 4 = DAYTON 4KV % BEVERLY SUB
- CIRCUIT 5 = TRIANGLE 4KV % BEVERLY SUB
- CIRCUIT 6 = CORD 4KV % BEVERLY SUB

UNDERGROUND SERVICE ALERT
Dial 811
Call USA
For Underground Locating
2 Working Days Before You Dig



DATE	REVISION DESCRIPTION	APPROVED	DRAWN	CHECKED
3/6/20	MINOR REVISION	BR	ET	ET

DISTRICT 42-SANTA MONICA	PROJ. MGR. CARMEN HARTE 805-231-0128	PLANNER BRADLEY RICHMOND 626-862-0128	SR NO. 2795493
FOREMAN	TRUCK NO. / P/E	INVENTORY MAP NO. / THOMAS GUIDE	GRID NO. / DESIGN NO. 1220930
CSD 140 Y N	BY-PASS CODE	EXISTING CHANGE TO	TLM CHECKED
PRODUCT/SAP NO. TD 1633878 - LINE EXTENSION		PRODUCT/SAP NO.	
PROPOSED CONSTRUCTION (LOCATION) SANTA MONICA BLVD RODEO DR TO BEVERLY DR BEVERLY HILLS			ASSOCIATED DESIGN NO.
B/P	02/20/20	V. TROWBRIDGE	E. TAYLOR
TYPE	APPROVED BY	DATE	CHECKED BY
Southern California Edison Company			SHEET 1A OF 3
			JOB NO. 1220930



Save Date: Mar 06, 2020 - 5:27 by TAYLOREB

T.L.M. DATA: V5037618

SIZE	KVA	CUST	% LOAD
EXIST. 400	284.5	26	71.1%
PROP. 0	0	0	0%

VOLTAGE DROP: _____
FLICKER FACTOR: _____
PRI. CIRCUIT: _____

T.L.M. DATA: V5039641

SIZE	KVA	CUST	% LOAD
EXIST. 0	0	0	0%
PROP. 100	121	15	121.0%

VOLTAGE DROP: _____
FLICKER FACTOR: _____
PRI. CIRCUIT: _____

T.L.M. DATA: V5039641

SIZE	KVA	CUST	% LOAD
EXIST. 0	0	0	0%
PROP. 50	31.8	2	63.6%

VOLTAGE DROP: _____
FLICKER FACTOR: _____
PRI. CIRCUIT: _____

T.L.M. DATA: V5440828

SIZE	KVA	CUST	% LOAD
EXIST. 300	226.6	1	75.5%
PROP. 0	0	0	0%

VOLTAGE DROP: _____
FLICKER FACTOR: _____
PRI. CIRCUIT: _____

T.L.M. DATA: V5304476

SIZE	KVA	CUST	% LOAD
EXIST. 750	353.6	5	47.1%
PROP. 750	353.6	5	47.1%

VOLTAGE DROP: _____
FLICKER FACTOR: _____
PRI. CIRCUIT: _____

NOTE: RELOCATE ALL NECESSARY EQUIPMENT FROM V5037618 TO V5039641 TO RE-FEED EXISTING SERVICES

4 CR: V5037618 VAULT
8'x14'x9'4"
RM: 2-OIL FUSE CABINET
1-150 KVA 4KV 120/240 1P (1947)
1-100KVA 4V 120/240V 1P (1955)
1-150 KVA 4KV 240/480V 3P (1972)

NOTE: RELOCATE EXISTING VENT/VENT PIPE SOUTHWEST, OUT OF PROPOSED DRIVEWAY FEED BURD BANK OFF POS.2

3 EX: V5039641 VAULT
8'x22'x9'4"
EX: 1-4W RAM 4KV (CS0374)
IN: 2-25 KVA 4KV BURDS 240/480V 3P
1-100 KVA 4KV BURD 120/240V 1P
1-2W FBS 4KV (BS...)

2 CR: V5440828 VAULT
6'x12'x7" TUB STYLE
RM: 1-2W 3P BURD SW (BS1183)
3-100KVA 16KV BURDS

1 EX: V5039626 VAULT
7'x20'x8" TUNNEL STYLE

6 CR: M5038015 MANHOLE
4'x5'x7'

11 EX: V5304476 VAULT
EX: 1-2W 3P BURD SW (BS1182)
3-250KVA 16KV SUBWAYS


5 EX: X5040629 PULL BOX
2'x3'x3" CONCRETE PKWY

EX: M5038874 MANHOLE
4'x6'x7" 7

CR: X5041399 PULL BOX
2'x3'x3" CONC LT TRAF
RM: 3-2WAY SPLICES 8


CR: V5041398 VAULT
9'6"x20'x10'6"
RM: 1-2W 3P BURD SWITCH
3-100KVA 16KV BURDS
1-2W FBS 4KV (BS0929)
3-100KVA 4KV 277/480V 1P (1995) 9

EX: X PULL BOX
2'x3'x3" CONCRETE PKWY 10



MATCH LINE
SEE SHEET 3

UNDERGROUND SERVICE ALERT
Dial 811
Call USA
For Underground Locating
2 Working Days Before You Dig



DATE	REVISION DESCRIPTION	APPROVED	DRAWN	CHECKED
3/6/20	MINOR REVISION	BR	ET	ET

DISTRICT	42-SANTA MONICA	PROJ. MGR.	CARMEN HARTE	PLANNER	BRADLEY RICHMOND	SR NO.	2795493
FOREMAN		TRUCK NO.	P/JE	INVENTORY MAP NO.	THOMAS GUIDE	GRID NO.	DESIGN NO. 1220930
CSD 140 Y		BY-PASS		TLM		J.P.A. NO.	ASSOCIATED DESIGN NO.
N		CODE	CHANGE TO	CHECKED	%LOAD		
PRODUCT/SAP NO.	TD 1633878 - LINE EXTENSION		PRODUCT/SAP NO.		PRODUCT/SAP NO.		
PROPOSED CONSTRUCTION (LOCATION)							
SANTA MONICA BLVD							
RODEO DR TO BEVERLY DR							
BEVERLY HILLS							
B/P	02/20/20	V. TROWBRIDGE	E. TAYLOR	52822	SHEET		2 OF 3
TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #	JOB NO. 1220930	
Southern California Edison Company							

MATCH LINE
SEE SHEET 2

NOTE: SAFE END EX. 3-2/0 4KV
IN M5038014.

EX: M5038014 MANHOLE 12
4'x5'x7'
RM: SPLICES/J-BARS/UTILCOOS
IN: 3-2WAY SPLICES

T.L.M. DATA: V5485215

SIZE	KVA	CUST	% LOAD
EXIST. 225	142.2	1	63.2%
PROP. 225	142.2	1	63.2%

VOLTAGE DROP: _____
FLICKER FACTOR: _____
PRI. CIRCUIT: _____

EX: V5485215 VAULT 13
6'x12'x7' TUB STYLE
EX: 1-2WAY 3P BURD SWITCH
3-75KVA 16KVA BURDS

T.L.M. DATA: V5038280

SIZE	KVA	CUST	% LOAD
EXIST. 167	165.1	20	98.8%
PROP. 167	199.2	21	119.3%

VOLTAGE DROP: _____
FLICKER FACTOR: _____
PRI. CIRCUIT: _____

EX: V5038280 VAULT 14
5'6"x8'x9'4"
EX: 1-167KVA 4KV BURD

EX: M5038013 MANHOLE 15
4'x5'x7'

EX: V5465074 VAULT 16
7'x16'x8' TUNNEL STYLE
EX: 1-2W 3P BURD SWITCH
3-75KVA 16KV BURDS

CI: X0000004 PULL BOX 17
3'x5'x4' CONC LT TRAF
IN: 3-200A 2W T-SPLICE

+/-1.5%
VOLTAGE DROP: _____
FLICKER FACTOR: _____
PRI. CIRCUIT: _____

18 EX: P5440676 PAD
72'x94"
EX: 150KVA 16KV

19 EX: V5037694 VAULT
8'x14'x9'4"
EX: 1-3W 3P GAS SWITCH
2-167KVA 4KV BURDS
1-100KVA 4KV BURD

20 EX: V5304226 VAULT
8'x22'x9'
EX: 1-6WAY RAM
3-100KVA 16KV BURDS

EX: 1-5" (50')
M8014 TO V5215
EX: 3-1/0 16KV

EX: 4-3 1/2" (148')
M8014 TO V8250
RM: 3-2/0 4KV
700
3-250 & 1-2/0

EX: 4-3 1/2" (192')
M8013 TO V7694
EX: 3-4/0 4KV
3-700 & 1-350
2-350 & 1-4/0

EX: 1-5" (6')
X0004 TO V5074
IN: 31' 3-1/0 1/0 JCN 16KV
EPL (TENSION) OK BOTH DIRECTIONS

INTERCEPT EX. 1-4"
& EXTEND W/

EX: 1-4" (10')
X0004 TO INT. PT.
IN: 208' 3-1/0 1/0 JCN 4KV
X0004 TO V7694
EPL (TENSION) OK BOTH DIRECTIONS

EX: 1-3" (102')
V7694 TO P0876
EX: 3-1/0 16KV

EX: 6-3 1/2" (168')
V4226 TO M7585

EX: 2-5" (173')
X0004 TO M8015
IN: 192' 3-1/0 1/0 JCN 4KV
EPL (TENSION) OK BOTH DIRECTIONS


ABANDON 1-4"
INT. PT. TO V5074

INTERCEPT PT.

EX: 1-4" (195')
V7694 TO V5074
RM: 3-#2 16KV

BRIGHTON WAY

UNDERGROUND SERVICE ALERT
Dial 811
Call USA
For Underground Locating
2 Working Days Before You Dig





DATE	REVISION DESCRIPTION	APPROVED	DRAWN	CHECKED
3/6/20	MINOR REVISION	BR	ET	ET

DISTRICT 42-SANTA MONICA	PROJ. MGR. CARMEN HARTE PHONE 805-231-0128	PLANNER BRADLEY RICHMOND PHONE 626-862-0128	SR NO. 2795493
FOREMAN	TRUCK NO. P/E	INVENTORY MAP NO. 6663A7	THOMAS GUIDE GRID NO.
CSD 140 Y N	BY-PASS CODE	EXISTING CHANGE TO	TLM CHECKED
PRODUCT/SAP NO. TD 1633878 - LINE EXTENSION	PRODUCT/SAP NO.	PRODUCT/SAP NO.	PRODUCT/SAP NO.
PROPOSED CONSTRUCTION (LOCATION) SANTA MONICA BLVD RODEO DR TO BEVERLY DR BEVERLY HILLS			ASSOCIATED DESIGN NO. 1220930
B/P	02/20/20	V. TROWBRIDGE	E. TAYLOR
TYPE APPROVED BY	DATE	CHECKED BY	DRAWN BY
Southern California Edison Company			SHEET 3 OF 3
			JOB NO. 1220930

Save Date: Mar 06, 2020 - 5:27 by TAYLOREB

Attachment H: SCG Existing Facility Map



Map Title:
 Printed By: CORP\wperez
 Printed Date: 8/7/2019

LIABILITY STATEMENT The facilities and their depiction on these maps are believed to be reasonably accurate, but the maps are not to be used in lieu of field verification or calling USA at 800-422-4113. NO WARRANTY expressed or implied (including of merchantability or of fitness for a particular purpose) is made as to any matter, including but not limited to, the design, size, type or location of the facilities, their presence or absence, the accuracy of the maps, the means used to transmit the data, absence of viruses (if transmitted electronically, by disk or otherwise), data translation or transmission errors or omissions, compatibility with the user's system or its ability to interpret the data correctly or at all, or any other matter. The Gas Company has no liability for damages (direct, indirect, consequential, incidental or punitive) arising from the transmission, receipt or use by others of the maps or information contained in the maps.



Attachment I: LA County Sewage Generation Table

Estimated Average Daily Sewage Flows for Various Occupancies

Occupancy	Abbreviation	*Average daily flow
Apartment Buildings:		
Bachelor or Single dwelling units	Apt	150 gal/D.U.
1 bedroom dwelling units	Apt	200 gal/D.U.
2 bedroom dwelling units	Apt	250 gal/D.U.
3 bedroom or more dwelling units	Apt	300 gal/D.U.
Auditoriums, churches, etc.	Aud	5 gal/seat
Automobile parking	P	25 gal/1000 sq ft gross floor area
Bars, cocktails lounges, etc.	Bar	20 gal/seat
Commercial Shops & Stores	CS	100 gal/1000 sq ft gross floor area
Hospitals (surgical)	HS	500 gal/bed
Hospitals (convalescent)	HC	85 gal/bed
Hotels	H	150 gal/room
Medical Buildings	MB	300 gal/1000 sq ft gross floor area
Motels	MB	150 gal/unit
Office Buildings	Off	200 gal/1000 sq ft gross floor area
Restaurants, cafeterias, etc.	R	50 gal/seat
Schools:		
Elementary or Jr. High	S	10 gal/student
High Schools	HS	15 gal/student
Universities or Colleges	U	20 gal/student
College Dormitories	CD	85 gal/student

*Multiply the average daily flow by 2.5 to obtain the peak flow

Zoning Coefficients

Zone	Coefficient (cfs/Acre)
Agriculture -----	0.001
Residential*:	
R-1 -----	0.004
R-2 -----	0.008
R-3 -----	0.012
R-4 -----	0.016*
Commercial:	
C-1 through C-4 -----	0.015*
Heavy Industrial:	
M-1 through M-4 -----	0.021*

* Individual building, commercial or industrial plant capacities shall be the determining factor when they exceed the coefficients shown

* Use 0.001 (cfs/unit) for condominiums only

**AN ORDINANCE PRESCRIBING THE CONNECTION FEE RATE
AND MEAN LOADINGS PER UNIT OF USAGE FOR
COUNTY SANITATION DISTRICT NO. 8 OF LOS ANGELES COUNTY**

THE BOARD OF DIRECTORS OF COUNTY SANITATION DISTRICT NO. 8 OF LOS ANGELES COUNTY ORDAINS AS FOLLOWS:

SECTION 1.0 - USER CATEGORIES AND MEAN LOADINGS

Pursuant to Section 3.04(2) of the Master Connection Fee Ordinance of County Sanitation District No. 8 of Los Angeles County, the following shall constitute the user categories and mean loadings per unit of usage for flow, chemical oxygen demand (COD), and suspended solids:

<u>DESCRIPTION</u>	<u>UNIT OF MEASURE</u>	<u>FLOW (Gallons per Day)</u>	<u>COD (Pounds per Day)</u>	<u>SUSPENDED SOLIDS (Pounds per Day)</u>
RESIDENTIAL				
Single Family Home	Dwelling Unit	260	1.22	0.59
Condominiums	Dwelling Unit	195	0.92	0.44
Multi-Unit Residential	Dwelling Unit	156	0.73	0.35
Mobile Home Parks	No. of Spaces	156	0.73	0.35
COMMERCIAL				
Hotel/Motel/Rooming House	Room	125	0.54	0.28
Store	1000 ft ²	100	0.43	0.23
Supermarket	1000 ft ²	150	2.00	1.00
Shopping Center	1000 ft ²	325	3.00	1.17
Regional Mall	1000 ft ²	150	2.10	0.77
Office Building	1000 ft ²	200	0.86	0.45
Medical, Dental, Veterinary Clinic or Building	1000 ft ²	300	1.29	0.68
Restaurant	1000 ft ²	1,000	16.68	5.00
Indoor Theatre	1000 ft ²	125	0.54	0.28
Car Wash				
Tunnel - No Recycling	1000 ft ²	3,700	15.86	8.33
Tunnel - Recycling	1000 ft ²	2,700	11.74	6.16
Wand	1000 ft ²	700	3.00	1.58
Bank, Credit Union	1000 ft ²	100	0.43	0.23
Service Shop, Vehicle Maintenance & Repair Shop	1000 ft ²	100	0.43	0.23
Animal Kennels	1000 ft ²	100	0.43	0.23
Gas Station	1000 ft ²	100	0.43	0.23
Auto Sales	1000 ft ²	100	0.43	0.23
Wholesale Outlet	1000 ft ²	100	0.43	0.23
Nursery/Greenhouse	1000 ft ²	25	0.11	0.06
Light Manufacturing	1000 ft ²	25	0.23	0.09
Lumber Yard	1000 ft ²	25	0.23	0.09
Warehousing	1000 ft ²	25	0.23	0.09
Open Storage	1000 ft ²	25	0.23	0.09
Drive-in Theatre	1000 ft ²	20	0.09	0.05

<u>DESCRIPTION</u>	<u>UNIT OF MEASURE</u>	<u>FLOW (Gallons per Day)</u>	<u>COD (Pounds per Day)</u>	<u>SUSPENDED SOLIDS (Pounds per Day)</u>
COMMERCIAL				
Night Club	1000 ft ²	350	1.50	0.79
Bowling/Skating	1000 ft ²	150	1.76	0.55
Club & Lodge Halls	1000 ft ²	125	0.54	0.27
Auditorium, Amusement	1000 ft ²	350	1.50	0.79
Golf Course and Park (Structures and Improvements)	1000 ft ²	100	0.43	0.23
Campground, Marina, and Recreational Vehicle Park	Sites, Slips, or Spaces	55	0.34	0.14
Convalescent Home	Bed	125	0.54	0.28
Laundromat	1000 ft ²	3,825	16.40	8.61
Mortuary, Funeral Home	1000 ft ²	100	1.33	0.67
Health Spa, Gymnasium With Showers	1000 ft ²	600	2.58	1.35
Without Showers	1000 ft ²	300	1.29	0.68
Convention Center, Fairground, Racetrack, Sports Stadium/Arena	Average Daily Attendance	10	0.04	0.02

INSTITUTIONAL

College/University	Student	20	0.09	0.05
Private School	1000 ft ²	200	0.86	0.45
Library, Museum	1000 ft ²	100	0.43	0.23
Post Office (Local)	1000 ft ²	100	0.43	0.23
Post Office (Regional)	1000 ft ²	25	0.23	0.09
Church	1000 ft ²	50	0.21	0.11

SECTION 2.0 - CONNECTION FEE RATE

Pursuant to Section 3.03 of the Master Connection Fee Ordinance of County Sanitation District No. 8 of Los Angeles County, the following, to be effective on the dates given, shall constitute the Connection Fee Rate per capacity unit:

<u>July 1, 2008</u>	<u>July 1, 2009</u>	<u>July 1, 2010</u>
\$2,530	\$3,290	\$4,150

SECTION 3.0 - COST ALLOCATION FACTORS

Pursuant to Section 3.04(1) of the Master Connection Fee Ordinance of County Sanitation District No. 8 of Los Angeles County, the proportions of the total capital costs required to construct an incremental expansion of the sewerage system of the next anticipated configuration for conveyance, treatment, and disposal of wastewater which are attributable to flow, COD, and suspended solids, designated as X, Y, and Z, respectively, to be effective on the dates given, shall be:

$$X = 0.6696 \qquad Y = 0.1256 \qquad Z = 0.2048$$