



**WAEITY**  
QUALITY WATER SERVICES

**WELL TEST REPORT SEPTEMBER 2, 2019**

PERFORMED FOR: WILLIAM C. BUCKINGHAM

10150 BAR BB LANE

ARROYO GRANDE, CA 93420

WELL IS ON SITE.

BY: WAEITY QUALITY WATER

TODD@WAEITYWATERSERVICE.COM

CLASS A CONTRACTOR LI# 1056567

<u>TIME:</u>	<u>PUMPING LEVEL</u>	<u>GPM</u>
8:00 AM	19 FT	32
8:15	34 FT	32
8:30	34 FT	32
8:45	34 FT	32
9:00	34 FT	32
9:15	34 FT	32
9:30	34 FT	32
9:45	34 FT	32
10:00	34 FT	32
10:15	34 FT	32
10:30	35 FT	32
10:45	35 FT	32
11:00	35 FT	32
11:15	35 FT	32
11:30	36 FT	32
11:45	36 FT	32
12:00	36 FT	32

**WELL INFO.**

WELL DIAMETER: 8 INCH

WELL PUMP: 5 HP

STATIC WATER LEVEL: 19 FT

TEST STARTED: 8:00 AM. FINISHED @ 12:00 PM

WELL DEPTH: 57 FT. PUMP DEPTH: 48 FT

RECOVERY: 10 FT IN 115 SECONDS.

INSPECTED BY: TODD WAEITY/OWNER