



# TWINING

Engineering a Better Tomorrow

## **Geotechnical Investigation Report**

**Proposed Hospital Expansion**

**Kaiser Riverside Medical Center, OSHPD ID: 106334025**

**10800 Magnolia Avenue**

**Riverside, California**

Prepared for:

Kaiser Foundation Hospitals

182 Granite Street

Corona, California 92879

March 31, 2021 (Revised July 26, 2021)

Project No.: 190919.3



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

March 31, 2021 (Revised July 26, 2021)  
Project No.: 190919.3

Mr. Edward Bacic  
Regional Program Manager  
Kaiser Foundation Hospitals  
Southern California Delivery Team  
182 Granite Street  
Corona, California 92879

**Subject:** Geotechnical Investigation Report  
Proposed Hospital Expansion  
Kaiser Riverside Medical Center, OSHPD ID: 106334025  
10800 Magnolia Avenue  
Riverside, California

Dear Mr. Bacic,

In accordance with your request and authorization, we are presenting the results of our geotechnical investigation for the Proposed Hospital Expansion project located at 10800 Magnolia Avenue in Riverside, California. The purpose of our investigation has been to evaluate the subsurface conditions at the site, to identify seismic and geologic hazards present on the site, and to provide geotechnical engineering recommendations for the proposed improvements. This report was prepared in accordance with the requirements of the 2019 California Building Code (2019 CBC), California Geological Survey (CGS) Note 48 (CGS, 2019), ASCE 7-16 (ASCE 2017), and the Standard Geotechnical Report Review Comments prepared and used by Facilities Development Division (FDD) of Office of Statewide Health Planning and Development (OSHPD) for OSHPD 1 Projects.

Based on our findings, the proposed project is geotechnically feasible, provided that the recommendations in this report are incorporated into the design and are implemented during construction of the project.

We appreciate the opportunity to be of service on this project. Should you have any questions regarding this report or if we can be of further service, please do not hesitate to contact the undersigned.


Respectfully submitted,  
**TWINING, INC.**



  
Liangcai He, PhD, RCE 73280, GE 3033  
Chief Geotechnical Engineer



  
Paul Soltis, RCE 56140, GE 2606  
Vice President, Geotechnical Engineering



  
Jonathan Browning, CEG 2615  
Certified Engineering Geologist

**TABLE OF CONTENTS**

	<u>Page</u>
<b>1. INTRODUCTION.....</b>	<b>1</b>
<b>2. SITE DESCRIPTION AND PROPOSED DEVELOPMENT .....</b>	<b>1</b>
<b>3. SCOPE OF WORK .....</b>	<b>2</b>
<b>3.1. LITERATURE REVIEW.....</b>	<b>2</b>
<b>3.2. AERIAL PHOTOGRAPH AND TOPOGRAPHIC MAP REVIEW.....</b>	<b>2</b>
<b>3.3. PRE-FIELD ACTIVITIES AND FIELD EXPLORATION .....</b>	<b>2</b>
<b>3.4. GEOTECHNICAL LABORATORY TESTING.....</b>	<b>3</b>
<b>3.5. GEOPHYSICAL EVALUATION .....</b>	<b>3</b>
<b>3.6. ENGINEERING ANALYSES AND REPORT PREPARATION .....</b>	<b>4</b>
<b>4. GEOLOGY AND SUBSURFACE CONDITIONS.....</b>	<b>4</b>
<b>4.1. GEOLOGIC SETTING.....</b>	<b>5</b>
<b>4.2. SITE GEOLOGY, SUBSURFACE CONDITIONS AND GEOLOGIC CROSS SECTIONS .....</b>	<b>5</b>
4.2.1. Pavement Section.....	5
4.2.2. Artificial Fill .....	5
4.2.3. Old Alluvial Fan Deposits.....	6
4.2.4. Bedrock .....	6
<b>4.3. GROUNDWATER CONDITIONS.....</b>	<b>6</b>
<b>5. GEOLOGIC HAZARDS AND SEISMIC DESIGN CONSIDERATIONS .....</b>	<b>8</b>
<b>5.1. HISTORICAL SEISMICITY .....</b>	<b>8</b>
<b>5.2. ACTIVE FAULTING AND SURFACE FAULT RUPTURE.....</b>	<b>8</b>
<b>5.3. LIQUEFACTION POTENTIAL AND SEISMIC SETTLEMENT .....</b>	<b>9</b>
<b>5.4. LATERAL SPREAD .....</b>	<b>11</b>
<b>5.5. LANDSLIDES .....</b>	<b>11</b>
<b>5.6. FLOODING AND DAM INUNDATION .....</b>	<b>11</b>
<b>5.7. TSUNAMIS AND SEICHES.....</b>	<b>11</b>
<b>5.8. DEAGGREGATED SEISMIC SOURCE PARAMETERS.....</b>	<b>12</b>
<b>5.9. SITE CLASS FOR SEISMIC DESIGN .....</b>	<b>12</b>
<b>5.10. MAPPED CBC SEISMIC DESIGN PARAMETERS .....</b>	<b>12</b>
<b>5.11. SITE-SPECIFIC GROUND MOTION HAZARD ANALYSIS AND SEISMIC DESIGN</b>	
<b>PARAMETERS .....</b>	<b>14</b>
5.11.1. Probabilistic Seismic Hazard Analysis.....	14
5.11.2. Deterministic Seismic Hazard Analysis .....	14
5.11.3. Site-Specific Design Response Spectrum.....	16
5.11.4. Site-Specific Seismic Design Parameters .....	17
<b>6. GEOTECHNICAL ENGINEERING RECOMMENDATIONS .....</b>	<b>17</b>
<b>6.1. GENERAL CONSIDERATIONS.....</b>	<b>17</b>
<b>6.2. SOIL EXPANSION AND COLLAPSE POTENTIAL.....</b>	<b>17</b>
<b>6.3. CORROSIVE SOIL EVALUATION .....</b>	<b>18</b>
6.3.1. Reinforced Concrete .....	18
6.3.2. Buried Metal.....	18
<b>6.4. SITE PREPARATION AND EARTH WORK.....</b>	<b>19</b>

6.4.1.	Site Preparation .....	19
6.4.2.	Temporary Excavations.....	19
6.4.3.	Over-Excavation and Subgrade Preparation.....	19
6.4.4.	Materials for Fill.....	20
6.4.5.	Compacted Fill .....	21
6.4.6.	Excavation Bottom Stability.....	21
6.4.7.	Backfill for Utility Trench.....	21
6.4.8.	Rippability .....	22
6.4.9.	Construction Dewatering.....	22
<b>6.5.</b>	<b>FOUNDATION RECOMMENDATIONS .....</b>	<b>22</b>
6.5.1.	Footing Foundation.....	22
6.5.2.	Mat Foundation.....	24
<b>6.6.</b>	<b>SURCHARGE FROM ADJACENT FOOTINGS .....</b>	<b>24</b>
<b>6.7.</b>	<b>MODULUS OF SUBGRADE REACTION.....</b>	<b>24</b>
<b>6.8.</b>	<b>CONCRETE SLABS .....</b>	<b>24</b>
<b>6.9.</b>	<b>POLE FOUNDATIONS.....</b>	<b>27</b>
6.9.1.	Non-Constrained Ground .....	27
6.9.2.	Constrained Ground .....	27
<b>6.10.</b>	<b>BELOW-GRADE WALL AND LATERAL EARTH PRESSURE RECOMMENDATIONS .....</b>	<b>28</b>
6.10.1.	Backfill and Drainage of Walls .....	28
6.10.2.	Lateral Earth Pressure.....	28
6.10.3.	Seismic Lateral Earth Pressure .....	29
<b>6.11.</b>	<b>TEMPORARY SHORING .....</b>	<b>29</b>
6.11.1.	Lateral Earth Pressures.....	30
6.11.2.	Soldier Pile Design.....	30
6.11.3.	Tieback Design .....	31
6.11.4.	Anchor Installation.....	31
6.11.5.	Lagging and Sheeting.....	32
6.11.6.	Lateral Deflection and Settlement.....	32
6.11.7.	Monitoring .....	32
<b>6.12.</b>	<b>PAVEMENT RECOMMENDATIONS .....</b>	<b>32</b>
6.12.1.	Flexible Pavement Design.....	33
6.12.2.	Rigid Pavement Design.....	33
<b>6.13.</b>	<b>STORMWATER INFILTRATION FACILITY.....</b>	<b>33</b>
<b>6.14.</b>	<b>DRAINAGE CONTROL.....</b>	<b>34</b>
<b>7.</b>	<b>DESIGN REVIEW AND CONSTRUCTION MONITORING .....</b>	<b>36</b>
7.1.	PLANS AND SPECIFICATIONS.....	36
7.2.	PRECONSTRUCTION SURVEYS .....	36
7.3.	CONSTRUCTION MONITORING .....	36
<b>8.</b>	<b>LIMITATIONS .....</b>	<b>37</b>
<b>9.</b>	<b>SELECTED REFERENCES .....</b>	<b>38</b>



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

## **Figures**

Figure 1 – Site Location Map  
Figure 2 – Site Plan and Boring Location Map  
Figure 3 – Regional Geologic Map  
Figures 4A through 4D – Geologic Cross Sections A-A', B-B', C-C', and D-D'  
Figure 5 – Water Levels in Wells Adjacent to the Site  
Figure 6 – Historical Earthquake Epicenter Map  
Figure 7 – Seismic Hazard Zones Map  
Figure 8 – Regional Fault Map  
Figure 9 – Liquefaction Zones Map  
Figure 10 – Dam Inundation Areas Map  
Figure 11 – FEMA Flood Map  
Figure 12 – Shear-Wave Velocity Profile  
Figure 13 – Site-Specific Design Response Spectrum

## **Appendices**

Appendix A – Field Exploration  
Appendix B – Laboratory Testing  
Appendix C – Geophysical Study  
Appendix D – Liquefaction Analysis  
Appendix E – Select Project Plans



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

## 1. INTRODUCTION

This report presents the results of the geotechnical investigation performed by Twining, Inc. (Twining) for the Proposed Hospital Expansion project at Kaiser Permanente Riverside Medical Center (Kaiser RMC) located at 10800 Magnolia Avenue in Riverside, California. A description of the site and the proposed improvements is provided in the following section. The objectives of this investigation have been to evaluate subsurface conditions at the site, to identify seismic and geologic hazards present on the site, and to provide geotechnical recommendations for design and construction of the proposed development, including recommendations for foundations and earthwork.

This report was prepared in accordance with the requirements of the 2019 California Building Code (2019 CBC), California Geological Survey (CGS) Note 48 (CGS, 2019), ASCE 7-16 (ASCE 2017), and the Standard Geotechnical Report Review Comments prepared and used by Facilities Development Division (FDD) of Office of Statewide Health Planning and Development (OSHPD) for OSHPD 1 Projects.

## 2. SITE DESCRIPTION AND PROPOSED DEVELOPMENT

Based on our communications with Kaiser and the project architect, CO Architects, proposed improvements on the Kaiser RMC campus will be developed in seven phases. Details of each phase are provided on Sheets A1.20 through A1.24 included in Plans Appendix E – Select Project Plans. This report is primarily focused on the hospital new tower in Phase 6 located at the northwest corner of the hospital campus adjacent to the existing diagnostic and treatment center. This report also covers the installation of a new generator pad and a 20,000-gallon underground propane tank at the northeast corner of the hospital campus.

Based on information from Kaiser, CO Architects and the project structural engineer, John A. Martin & Associates, Inc., the tower will be an acute care facility (OSHPD-1) with a Risk Category of IV and will be connected to the existing hospital building on the east side of the existing hospital. The total square footage of the new hospital tower will be 291,494. The tower will have a gross building footprint of 61,373 square feet and will consist of five stories above grade and a single-level basement. The proposed building height is 74.5 feet to the roof and 89.5 feet to the top of roof screen. The superstructure will be steel framed utilizing special steel moment frame as the primary seismic force resisting system. The basement will utilize perimeter basement concrete walls acting as special concrete shear walls for lateral force resistance. The foundations will consist of square spread footings at isolated columns and continuous footings at basement walls. Grade beams will tie frame bays together at grade. It is anticipated the maximum dead and live load on a single column will be approximately 750 kips.

Other appurtenant improvements for the new tower are anticipated including parking spaces, hardscape, light poles, utility pipelines, a stormwater infiltration system, and a new driveway approach off Magnolia Avenue for emergency vehicles. The size and depth of the infiltration basin are to be determined, and details of the system are not yet available for our review. Details of the new emergency driveway approach is provided on Sheet C2.01 included in Appendix E.

Anticipated earthwork for the new tower will include 25,000 cubic yards (CY) of cut, 14,500 CY of fill, and 10,500 CY of export.

The project site is located at 10800 Magnolia Avenue in Riverside, California, as shown on Figure 1 – Site Location Map. The overall site plan showing the final finished entire Kaiser RMC site is depicted on Figure 2, along with the field investigation locations performed for this report. The sites are currently



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

occupied by paved surface parking, landscaping, and associated miscellaneous equipment. The site for the new tower is bounded by surface parking and existing hospital structures on the north, existing hospital buildings on the east, surface parking on the south, and the west. The site for the generator pad and the propane tank is approximately 700 feet to the east of the proposed tower at the southeast corner of the campus surrounded by surface parking and roadways on the campus.

The approximate coordinates are latitude 33.905595°N and longitude 117.470066°W for the tower site and latitude 33.904393°N and longitude 117.467919°W for the generator pad and propane tank site. The sites are located on the Riverside West, California 7½-Minute Quadrangle, based on the United States Geological Survey (USGS) topographic map (USGS 2018). The tower site is relatively level with a surface elevation of approximately 723 feet above mean sea level (msl). The site for the generator pad and the propane tank has a surface elevation of approximately 724 to 730 feet above msl.

### **3. SCOPE OF WORK**

Our scope of work included review of background information, pre-field activities and field exploration, geophysical evaluation, laboratory testing, engineering analyses and report preparation. These tasks are described in the following subsections.

#### **3.1. Literature Review**

We reviewed readily available background data including proposed site improvement plans, published geologic maps, topographic maps, aerial photographs, seismic hazard maps and literature, and flood hazard maps relevant to the subject site. Relevant information has been incorporated into this report.

#### **3.2. Aerial Photograph and Topographic Map Review**

Vintage stereoscopic aerial photographs of the site and vicinity from the years between 1931 and 1980, and USGS topographic maps from the years between 1901 and 2018 as well as three-dimensional computer-aided photography flown between the years of 1994 and 2018 and presented by Google Earth (Google, 2019) were reviewed for this report. The earliest images of the vicinity indicate agricultural use up to 1980. The current structure and surrounding hardscape and landscape improvements were built sometime between 1980 and 1994 and have generally stayed in the same configuration. We observed no lineaments indicative of faulting within or adjacent to the site during our aerial photograph and topographic map review.

#### **3.3. Pre-Field Activities and Field Exploration**

Before starting our exploration program, we had several site meetings and performed a geotechnical site reconnaissance to observe the general surficial conditions at the site, to select field exploration locations, and to plan field logistics including traffic control, health and safety, and badging. After exploration locations were delineated, Underground Service Alert was notified of the planned locations a minimum of 72 hours prior to excavation. We also retained GEOVision Inc. of Corona, California, a private utility locating service provider, to clear proposed boring locations of underground utility lines.

The field exploration was conducted between November 2, 2019 and March 13, 2021 and consisted of drilling, testing, sampling, and logging of 13 exploratory hollow-stem-auger (HSA) borings (B-1 through B-13) for the tower, 2 HSA borings for the generator pad (GP-1 and GP-2), and 2 HSA borings for the propane tank (PT-1 and PT-2). The field exploration also included percolation testing

in 3 hand-auger borings (P-3 through P-5) for the tower site. The HSA borings were advanced to approximate depths of 31.5 to 91.5 feet below ground surface (bgs) for the tower, approximately 51.5 feet bgs for the generator pad, and approximately 21.5 feet bgs for the propane tank. The borings were drilled using a RAM 5500 and a CME-75 truck-mounted drill rigs equipped with 8-inch-diameter HSAs. The hand-auger borings (P-3 through P-5) were each drilled to approximately 6 feet bgs for percolation testing. The approximate locations of the borings are shown on Figure 2.

Drive samples of the soils were obtained from the HSA borings using a Standard Penetration Test (SPT) sampler without liners and a modified California split spoon sampler. The samplers were driven using a 140-pound automatic hammer falling approximately 30 inches. The blow-counts to drive the samplers were recorded, and subsurface conditions encountered in the borings were logged by a Twining field engineer. Soil samples obtained from the borings were transported to Twining's geotechnical engineering laboratory for examination and testing.

Percolation tests were performed in the hand-auger borings (P-3 through P-5) according to the boring percolation test guidance provided in the Riverside County Design Handbook for Low Impact Development Best Management Practices. Testing was performed to provide estimates of infiltration rate of the site soils for use in preliminary design of the stormwater infiltration system.

Upon completion of drilling or percolation testing, the borings were backfilled by the drilling subcontractor using drilled soil cuttings, and the surface was repaired to match existing conditions.

Detailed descriptions of the borings, soils encountered during drilling, and the percolation tests are presented in Appendix A – Field Exploration.

### **3.4. Geotechnical Laboratory Testing**

Laboratory tests were performed on selected samples obtained from the borings to aid in the soil classification and to evaluate the engineering properties of site soils. The following tests were performed in general accordance with ASTM standards:

- In-situ moisture and density;
- #200 Wash;
- Grain size analysis;
- Atterberg Limits;
- Expansion Index;
- Consolidation;
- Direct shear;
- Unconfined compression;
- R-Value; and
- Corrosivity.

Detailed laboratory test procedures and results are presented in Appendix B – Laboratory Testing.

### **3.5. Geophysical Evaluation**

As part of the field exploration program, we retained the services of Southwest Geophysics, LLC of San Diego, California (SGL) to perform a geophysical study to measure the shear-wave velocity ( $V_s$ )

profile and the average shear-wave velocity ( $V_{s,30}$ ) in the top 30 meters (or approximately 100 feet) of the soil profile. The study was performed employing the refraction microtremor (ReMi) method, which uses recorded surface waves (specifically Rayleigh waves) that are contained in background noise to develop a  $V_s$  profile of the study area (Louie, 2001). The ReMi method does not require an increase of material velocity with depth; therefore, low velocity zones (velocity inversions) are detectable with ReMi. The results of the ReMi method are a one-dimensional  $V_s$  model, which represents the average condition across the length of the measurement line placed at the ground surface. Results of the study are presented in Appendix C, which indicate that  $V_{s,30}$  of the site is approximately 1,143 feet per second (ft/s) or 348 meters per second (m/s).

### **3.6. Engineering Analyses and Report Preparation**

We compiled and analyzed the data collected from our field exploration and laboratory testing. We performed engineering analyses based on our literature review and data from field exploration and laboratory testing programs. Our analyses included the following:

- Site geology and subsurface conditions;
- Groundwater conditions;
- Geologic hazards and seismic design parameters;
- Liquefaction potential and seismic settlement;
- Soil corrosion potential;
- Soil collapse and expansion potential;
- Site preparation and earthwork;
- Temporary excavations;
- Project feasibility and suitability of on-site soils for foundation support;
- Foundation design parameters including bearing capacity, settlement, and lateral resistance;
- Modulus of subgrade reaction for mat foundation and concrete slab-on-grade design;
- Lateral earth pressures for retaining wall and shoring design;
- Concrete slab-on-grade support; and
- Pavement section recommendations.

We prepared this report to present our conclusions and recommendations from this investigation.

## **4. GEOLOGY AND SUBSURFACE CONDITIONS**

According to the geologic mapping compiled by the California Geological Survey (CGS, 2012), the project site is underlain by Late to Middle Pleistocene Old Alluvium Fan deposits (Geologic Symbol Qof) consisting of slightly to moderately consolidated, moderately dissected boulder, cobble, gravel, sand, and silt deposits issued from a confined valley or canyon. A portion of the geologic map is reproduced as Figure 3 – Regional Geologic Map.

#### **4.1. Geologic Setting**

The site is located in the northern portion of the Peninsular Ranges Geomorphic province, within the Perris structural block. The Peninsular Ranges province extends southeastward from the foot of the Santa Monica and San Gabriel Mountains to beyond the Mexican border and is subdivided into several structural units, such as the Los Angeles Basin, the Palos Verdes Hills, the Santa Ana Mountains, the San Gabriel Valley, the Perris and San Jacinto Mountain blocks, and the California Continental Borderland. The Peninsular Ranges province is generally characterized by northwest oriented valleys and mountain ranges bounded by major right lateral strike-slip fault zones. The San Andreas Fault zone constitutes the eastern provincial boundary; the Patton Escarpment constitutes the western provincial boundary, while the San Jacinto, Elsinore and Newport-Inglewood Fault zones are located within the center of the province. Rocks of the Peninsular Ranges are typically Cretaceous igneous and marine sedimentary and Paleozoic to Mesozoic metasedimentary rocks. Tertiary marine and non-marine sedimentary and volcanic rock along with Quaternary sediment lies unconformably on either the Cretaceous sedimentary or the older basement rock. Perris Block consists of an uplifted Cretaceous and older crystalline bedrock structural unit bounded by the Elsinore fault on the west, the San Jacinto fault on the east, and the Santa Ana basin to the north. The southern boundary is vague and consists of a complex network of east-west trending faults in the Temecula-Murrieta area. The Perris block has multiple erosion surfaces consisting of both crystalline bedrock and very old Mid-Miocene (approximately 12 MYA) alluvium mantling portions of the bedrock. Pleistocene-aged old alluvial fan deposit underlies the subject site and nearby-surrounding area (Morton & Cox, 2001). The earth materials encountered on the subject site are discussed in the following section.

#### **4.2. Site Geology, Subsurface Conditions and Geologic Cross Sections**

According to the geologic mapping compiled by the California Geological Survey (Morton & Cox, 2001) and our investigation, the project site is underlain by Pleistocene-aged old alluvial fan deposit consisting of sand, silt and clay. A generalized description of the subsurface conditions encountered is provided below. Detailed descriptions of the earth materials encountered in the exploratory borings are presented in Appendix A – Field Exploration. Cross sections illustrating the geologic conditions at the site are presented on Figures 4A through 4D – Geologic Cross Sections A-A', B-B', C-C', and D-D'.

##### **4.2.1. Pavement Section**

All borings except for B-8, B-9, B-10, and PT-2 encountered a pavement section. The pavement section encountered in borings B-1, B-2, B-11 through B-13 consisted of approximately 6 to 7 inches of reinforced concrete over 6 to 7 inches of aggregate base, and in borings B-3 through B-7, GP-1, GP-2, and PT-1 consisted of 4 to 8 inches of asphalt over up to 12 inches of aggregate base.

##### **4.2.2. Artificial Fill**

No artificial fill was identified in our borings drilled for the tower. The surficial material consisted of reddish brown sandy lean clay. No evidence of previous agricultural activity was identified in the surficial material. Therefore, it is probable that surficial improvement of existing soil was performed prior to placement of Portland cement concrete, asphalt concrete and base.

Approximately 2 to 4 feet of artificial fill was encountered in borings drilled for the generator pad and the propane tank. The artificial fill consisted of reddish-brown clayey sand and sandy lean clay.

No documentation for the placement and compaction of artificial fill was found during our reference review.

#### **4.2.3. Old Alluvial Fan Deposits**

Pleistocene-aged old alluvial fan deposit underlies the site to the maximum depth of the exploratory borings (approximately 91.5 feet bgs).

In the tower area, the upper 20 feet of the old alluvium consisted primarily of reddish brown to light brown lean clay with varying amounts of sand and occasionally of grayish brown to light brown silt with sand and sandy silt. From 20 to 50 feet bgs, the old alluvium consisted of lean clay and silt with varying amounts of sand interbedded with well-graded sand, poorly graded sand, silty sand with varying amounts of gravel. Below 50 feet bgs to the maximum depth of the exploratory borings, the old alluvium consisted of light brown poorly graded sand to silty sand with varying amounts gravel. The clay and silt layers have a stiff to hard consistency, and the sand layers are mostly dense to very dense and occasionally medium dense.

In the proposed generate pad area, the upper 30 feet of the old alluvium consisted primarily of reddish brown to light brown sandy lean clay with a silty sand between the depths of 15 and 20 feet and a sandy silt or silt with sand layer between the depths of 20 and 25 feet. Below the depth of 30 feet, the old alluvium consisted primarily of light brown poorly graded sand with silt and silty sand. The clay and silt layers have a stiff to hard consistency, and the sand layers are mostly dense to very dense and occasionally medium dense.

In the proposed propane tank area, the old alluvium encountered in boring PT-1 consisted primarily of medium dense to dense silty sand. The old alluvium encountered in boring PT-2 consisted of medium dense silty sand in the upper 6 feet underlain by hard sandy lean clay or sandy silt to the exploration bottom at 21.5 feet bgs.

The old alluvium is estimated to extend to a depth of approximately 300 feet bgs and is underlain by bedrock.

#### **4.2.4. Bedrock**

Our geotechnical borings excavated at the site did not encounter bedrock. Based on the California Geological Survey (Morton & Cox, 2001), Cretaceous Gabbro (crystalline bedrock) is anticipated to be at a depth of approximately 300 feet in the vicinity of the site.

### **4.3. Groundwater Conditions**

During our field investigation, groundwater was encountered at 57.5 feet bgs in boring B-5. Groundwater was not encountered in other borings that were terminated at 51.5 feet bgs or a smaller depth.

Historically high groundwater level in the vicinity of the project site is not available from CGS. We reviewed groundwater level data from Metropolitan Water District of Southern California (MWDSC), Western Municipal Water District (WMWD) and California Department of Water Resources (CDWR).

According to MWDSC (2007) and WMWD (2012) maps, the project site is within the southern portion of the Arlington Basin, which is the portion of the Riverside-Arlington Groundwater Subbasin (Subbasin Number 8.2-03), as defined by the CDWR Bulletin 118-03 (CDWR, 2003). Groundwater occurrence in the Arlington Basin is generally unconfined. Groundwater flow is generally toward the southwest in the southern portion, which agrees well with groundwater levels measured in the three wells adjacent to the project site. The well locations with respect to the project site are shown in Figure 3. Historical water levels in the wells from 1960 to 2019 from WMWD (2012) and CDWR (2019) are shown in Figure 5 and summarized in Table 1. Historic high groundwater data described in WMWD (2012) indicate pre-development groundwater elevation of approximately 705 feet msl in the vicinity of the site.

As shown on Figure 5, the highest water levels in wells Buchanan 1 and Hole 1, located northeast and southwest of the site, respectively, occurred between 1984 and 1996. Figure 5 further indicates that the groundwater level in the area dropped continuously in the past 25 to 35 years since the highest water level year. The drops in wells Buchanan 1 and Hole 1 are approximately 50 and 40 feet, respectively. Well Daly 2 is the closest known well to the site, but no data was available before November 2011. However, it may be estimated that the highest water level in Daly 2 is between 701.5 and 711.5 feet msl assuming a similar water level drop of 40 to 50 feet. Considering water was encountered at 57.5 feet bgs in boring B-5 during our field investigation and assuming the same water level drop, we can estimate that the highest water level at the project site is likely between 7.5 and 17.5 feet bgs (or elevation 715.5 and 705.5 feet msl considering the ground surface elevation is approximately 723 feet msl), and the average is 12.5 feet bgs or 710.5 feet msl.

**Table 1 – Water Levels in Wells Adjacent to the Site**

Local Well ID	Buchanan 1	Daly 2	Hole 1
California State Well Number	03S06W22K004S	03S06W13N002S	03S06W13B001S
Latitude (degrees)	33.893033	33.902396	33.91527
Longitude (degrees)	-117.495077	-117.469653	-117.457580
Approximate Location relative to Project Site	8,860 ft southwest of site	1,150 ft south of site	4,830 ft northeast of site
Approximate Highest Water Level Since 1960 (feet, msl)	678 in 1996	Estimated between 701.5 and 711.5	736.5 in 1984
Approximate Water Level at end of 2019 (feet, msl)	628	661.5	696.5
Water Level Drop from the Highest to the end of 2019 (feet)	50	Estimated between 40 and 50	40

Additionally, GEOBASE, Inc., (2012) reported the highest groundwater elevation since 1978 is 712.2 feet msl in a well approximately 400 to 500 feet upstream of the current project site. It occurred in May 1979, but there is no data in other years available for our review.

It should be noted that groundwater conditions may vary across the site due to stratigraphic and hydrologic conditions and may change over time as a consequence of seasonal and meteorological fluctuations, or of activities by humans at this and nearby sites. For the purpose of this investigation, the historically highest groundwater for this project site can be assumed at approximately 710.5 feet msl or 12.5 feet bgs.

## **5. GEOLOGIC HAZARDS AND SEISMIC DESIGN CONSIDERATIONS**

The site is located in a seismically active area, as is the majority of southern California, and the potential for strong ground motion in the project area is considered high during the design life of the proposed development. The hazards associated with seismic activity in the vicinity of the site area discussed in the following sections.

### **5.1. Historical Seismicity**

The recorded history of earthquakes prior to the seismograph is sparse and inconsistent. The oldest seismographs (or recordable earthquake devices) originated in Italy in the mid 1800s. The modern seismograph was developed in Japan in 1880. Electromagnetic seismometers (calibrated seismographs) were developed between 1928 and 1930. Townley and Allen (1939) documented earthquakes along the Pacific Coast of the U.S. between 1769 and 1928. The systematic recording of large earthquakes in California began in 1932-1933 by the U.S. Coast and Geodetic Survey (Richter, 1958). As part of our investigation, we reviewed earthquake data recorded between A.D. 1700 and 2019 by searching historical accounts and publications cataloging North American earthquake activity, and the current USGS database (USGS, 2019). The nearest significant earthquake epicenter to the site was the 1923 moment magnitude ( $M_w$ ) 6.3 North San Jacinto Fault earthquake, which occurred approximately 14.1 miles or 22.8 kilometers (km) northeast of the site. The epicentral locations of the most significant earthquakes are shown on Figure 6 – Historical Earthquake Epicenter Map.

### **5.2. Active Faulting and Surface Fault Rupture**

The site is not located within or adjacent to an Alquist-Priolo Earthquake Fault Zone (EFZ) (CGS 2016). The boundary of the closest Alquist-Priolo EFZ is located approximately 6.9 miles (11.1 kilometers) southwest of the site associated with the Elsinore fault (Figure 7). Figure 8 shows the locations of the recognized nearby faults with respect to the site. The City of Riverside (2018) and the County of Riverside (2019) do not identify any additional hazardous faults in the immediate site vicinity.

A fault table of the active or potentially active faults within 62 miles (100 kilometers) of the site was generated by EQFAULT (Blake, 2000a) and was reviewed for this investigation. However, due to the limitations of the data base utilized by Blake, all of the fault distances were determined by individual measurements from more precise geologic maps, including the State's Alquist-Priolo EFZ maps (Bryant and Hart, 2007), and other CGS and USGS sources. The faults in Table 2 are considered to represent the closest and most significant potential hazard to the site with respect to potential ground surface rupture and/or generate strong ground motion in the event of a moderately sized or larger earthquake. Based on our review of geologic and seismologic literature and our site evaluation, it is our opinion that the likelihood of surface fault rupture and earthquake-induced landslides at the site during the life of the proposed improvements is low.

**Table 2 – Nearest Known Active Faults**

Fault Name	Faulting Mechanism	Distance to Site (miles)
unnamed fault in east Corona	Strike Slip	5.4
Elsinore - Glen Ivy segment	Strike Slip	7.9
Fontana Seismic Trend	Strike Slip	8.8
Chino Central Avenue	Strike Slip	12.8
San Jacinto - San Bernardino Valley segment	Strike Slip	13.8
Red Hill - Etiwanda	Reverse	16.1
Cucamonga Sierra Madre	Reverse	17.8
San Jose	Reverse	19.5
San Andreas - San Bernardino segment	Strike Slip	21.5
Puente Hills Blind Thrust	Reverse	22.7
Lower Elysian Park Thrust	Reverse	27.9

### 5.3. Liquefaction Potential and Seismic Settlement

Liquefaction is the phenomenon in which loosely deposited granular soils with silt and clay contents of less than approximately 35 percent, and non-plastic silts located below the water table undergo rapid loss of shear strength when subjected to strong earthquake-induced ground shaking. Ground shaking of sufficient duration results in the loss of grain-to-grain contact due to a rapid rise in pore water pressure and causes the soil to behave as a fluid for a short period of time.

Seismic settlement can occur when loose to medium dense granular materials densify during seismic shaking and liquefaction. Seismically-induced settlement may occur in dry, unsaturated, as well as saturated soils. Liquefaction is generally known to occur in loose, saturated, relatively clean, fine-grained cohesionless soils at depths shallower than approximately 50 feet. Factors to consider in the evaluation of soil liquefaction potential include groundwater conditions, soil type, grain size distribution, relative density, degree of saturation, and both the intensity and duration of ground motion. Other phenomena associated with soil liquefaction include sand boils, ground oscillation, and loss of foundation bearing capacity.

Seismic settlement can occur when medium dense granular materials densify during seismic shaking and/or liquefaction. Seismically-induced settlement may occur in dry, unsaturated, as well as saturated soils.

The area of the project site has not been evaluated for liquefaction by CGS. According to the liquefaction zones map in the General Plan 2025 of the City of Riverside, the site has moderate to high liquefaction potential (Figure 9).

We performed site-specific liquefaction analysis for low-density, non-plastic and low plasticity alluvium layers that are susceptible to liquefaction at the site. Based on Seed et al. (2003), the silt

and sandy silt layers with water content less than 85% of liquid limit are considered not susceptible to liquefaction in our analysis.

The analysis was performed based on SPT blowcounts from the HSA borings using the computer program LiqSVs version 2.0 (Geologismiki, 2019) and the procedure of Boulanger and Idriss (2014). The analysis considered an Mw 7.7 associated with a full rupture of the Elsinore Fault Zone, a  $PGA_M$  of 0.59 g discussed in Section 5.11.4, and a groundwater level at 12.5 feet bgs during earthquake discussed in Section 4.3. Seismic settlement above the groundwater table was considered negligible as the layers are cohesive soils. Below the water table, seismic settlements were calculated for each layer where the factor of safety against liquefaction is less than 1.3 (i.e.,  $FS < 1.3$ ). Detailed input parameters and results of the liquefaction analyses are presented in Appendix D of this report. The analysis results are summarized in Table 3.

**Table 3 – Summary of Liquefaction Analysis Results**

<b>Boring No</b>	<b>Total depth of boring (feet)</b>	<b>Depths of Liquefiable Layers (feet bgs)</b>	<b>Seismic Settlement (inch)</b>
B-1	51.5	20 - 25; 35 - 40	2.28
B-2	31.5	None	Negligible
B-3	51.5	None	Negligible
B-4	31.5	None	Negligible
B-5	91.5	None	Negligible
B-6	51.5	None	Negligible
B-7	31.5	25-30	1.14
B-8	51.5	None	Negligible
B-9	31.5	None	Negligible
B-10	31.5	None	Negligible
B-11	31.5	None	Negligible
B-12	31.5	None	Negligible
B-13	31.5	20 - 25	0.66
GP-1	51.5	35 - 40	1.14
GP-2	51.5	None	Negligible
PT-1	21.5	None	Negligible

The results indicate that during strong earthquake events if liquefaction were to occur at the site, it would be within localized zones at depths 20 feet or greater. The results indicate that the maximum seismic settlements are approximately 2.28 inches at the proposed tower site and 1.14 inches at the proposed generator site. Based on the calculated total settlements and measured distances between borings, the maximum calculated differential settlements are approximately 2.28 inches over a horizontal distance of 50 feet at the proposed tower site and 1.14 inches over a horizontal distance of 40 feet at the proposed generator site. The settlement would occur within localized zones

at 20 feet below ground surface (bgs) or deeper during strong earthquake events if liquefaction were to occur.

We note that, at the tower site, only one out of the 13 borings has a calculated seismic settlement of 2.28 inches, two borings have 1.14 inches, and most borings have negligible settlements. At the generator site, only one out of the three borings has a calculated seismic settlement of 1.14 inches and the other two borings have negligible settlements. In addition, the calculated settlement is considered conservative as it is based on boring data collected at 5-foot intervals. Considering the lack of horizontally continuous liquefiable layers, the presence of 20 feet or more of overlying cohesive soils and the conservative settlement estimate, it is our opinion that, for design of the new tower, total seismic settlement at the foundation level may be taken as 2.28 inches, and the differential settlement can be taken as 1.14 inches over a horizontal distance of 50 feet. For design of the generator and tank, total seismic settlement at the foundation level may be taken as 1.14 inches, and the differential settlement can be taken as 0.6 inches over a horizontal distance of 40 feet.

#### **5.4. Lateral Spread**

The potential of liquefaction-induced lateral spread at the site is considered remote because the site has low liquefaction potential, does not have a sloping ground, and is not adjacent to a slope.

#### **5.5. Landslides**

The area of the project site is not within an area with the potential for earthquake-induced landslides. Considering the site is relatively flat and not close to significant slopes, the potential for earthquake-induced landslides to occur at the site is considered very low.

#### **5.6. Flooding and Dam Inundation**

According to the Flood Hazard Areas map (Figure 10) in the General Plan 2025 of the City of Riverside, the site is not located within a 100- or 500-year floodplain. However, the site is located within the inundation area associated with incidents and failures of the Harrison dam and the Mockingbird Canyon dam. It is further noted that the site is not located within the inundation area of Lake Mathews (Figure 10).

According to the flood insurance rate maps (FIRMs) of the Federal Emergency Management Agency (FEMA) for use in administering the National Flood Insurance Program, the site is located within Zone X, which is described as "Areas of 0.2% annual chance flood hazard; areas of 1% annual chance flood with average depths of less than 1 foot or drainage areas less than 1 square mile." A portion of the FEMA flood map is reproduced in Figure 11.

#### **5.7. Tsunamis and Seiches**

Tsunamis are waves generated by massive landslides near or under sea water. The potential for the site to be adversely impacted by earthquake-induced tsunamis is considered to be remote because the site is not within the official tsunami inundation area mapped by California and the site is located tens of miles inland from the Pacific Ocean coast and has an approximate ground surface elevation of 723 feet msl that exceeds the maximum height of potential tsunami inundation in California (USGS 2013).

Seiches are standing wave oscillations of an enclosed water body (e.g., a lake, reservoir, or bay) after the original driving force has dissipated. Resulting oscillation could cause waves up to tens of

feet high, which in turn could cause extensive damage along the shoreline. The most serious consequences of a seiche would be the overtopping and failure of a dam. The potential for the site to be adversely impacted by earthquake-induced seiches would be associated with the potential of seiche-induced failure of the Harrison dam or the Mockingbird Canyon dam, because the site is within the inundation area of the two dams.

#### **5.8. Deaggregated Seismic Source Parameters**

We performed a seismic hazard de-aggregation analysis for the peak ground acceleration with a probability of exceedance of 2% in 50 years. The analysis used the USGS Unified Hazard Tool based on the 2014 USGS seismic source model. The results of the analysis indicate the controlling modal moment magnitude  $M_w$  and fault distance  $R$  are 6.47 and 7.53 miles (12.12 km), respectively.

#### **5.9. Site Class for Seismic Design**

The  $V_s$  profile from the geophysical study (Section 3.5 and Appendix C) performed by Southwest Geophysics for the site is shown in Figure 12, which indicates that the site  $V_{s,30}$  is approximately 348 m/s or 1,143 ft/s. We recommend that a  $V_{s,30}$  value of 348 m/s be used for this project.

Based on the site subsurface conditions (Section 4.2 and Appendix A) and the site  $V_{s,30}$  values, we have determined Site Class D for the project seismic design according to Chapter 20 of ASCE 7-16.

#### **5.10. Mapped CBC Seismic Design Parameters**

Our recommendations for seismic design parameters have been developed in accordance with the 2019 CBC and ASCE 7-16 (ASCE 2017) standards. As the site is classified as seismic Site Class D and the mapped spectral acceleration parameter at period 1-second,  $S_1$ , is greater than 0.2 g, a site-specific ground motion hazard analysis is required according to Section 11.4.7 of ASCE 7-16.

As an alternative, Exception 2 in Section 11.4.8 of ASCE 7-16 may be used for the project. For structural design based on this exception, Table 4 presents the seismic design parameters for the project.

The site-specific ground motion hazard analysis and seismic design parameters are presented in Section 5.11.

**Table 4 – 2019 California Building Code Seismic Design Parameters  
for Design Based on Exception 2 in Section 11.4.8 of ASCE 7-16**

Design Parameters	Value
Site Class	D
Mapped Spectral Acceleration Parameter at Period of 0.2-Second, $S_s$ (g)	1.5
Mapped Spectral Acceleration Parameter at Period 1-Second, $S_1$ (g)	0.582
Site Coefficient, $F_a$	1
Site Coefficient, $F_v$	1.718
Adjusted $MCE_R^1$ Spectral Response Acceleration Parameter, $S_{MS}$ (g)	1.5
Adjusted $MCE_R^1$ Spectral Response Acceleration Parameter, $S_{M1}$ (g)	1.0
Design Spectral Response Acceleration Parameter, $S_{DS}$ (g)	1.0
Design Spectral Response Acceleration Parameter, $S_{D1}$ (g)	0.667
Risk Coefficient $C_{RS}$	0.943
Risk Coefficient $C_{R1}$	0.921
Peak Ground Acceleration, $PGA_M^2$ (g)	0.601
Seismic Design Category <sup>3</sup>	D
Long-Period Transition Period, $T_L$ (seconds)	8
$T_s = S_{D1} / S_{DS}$	0.667
<p>When using the above parameters for seismic design, the seismic design coefficient <math>C_s</math> should be calculated as follows:</p> <p>For <math>T \leq 1.5T_s</math>, <math>C_s = \frac{S_{DS}}{\left(\frac{R}{I_e}\right)}</math></p> <p>For <math>T_L \geq T &gt; 1.5T_s</math>, <math>C_s = 1.5 \frac{S_{D1}}{T\left(\frac{R}{I_e}\right)}</math></p> <p>For <math>T &gt; T_L</math>, <math>C_s = 1.5 \frac{S_{D1}T_L}{T^2\left(\frac{R}{I_e}\right)}</math></p> <p>where  <math>T</math> = the fundamental period of the structure(s) determined in Section 12.8.2 of ASCE 7-16;  <math>R</math> = the response modification factor determined in Table 12.2-1 of ASCE 7-16; and  <math>I_e</math> = the importance factor determined in accordance with Section 11.5.1 of ASCE 7-16.</p>	
<p>Notes: <sup>1</sup> Risk-Targeted Maximum Considered Earthquake.  <sup>2</sup> Peak Ground Acceleration adjusted for site effects.  <sup>3</sup> For <math>S_1</math> greater than or equal to 0.75 g, the Seismic Design Category is E for risk category I, II, and III structures and F for risk category IV structures.</p>	

### 5.11. Site-Specific Ground Motion Hazard Analysis and Seismic Design Parameters

The site-specific ground motion hazard analysis was performed in accordance with Section 21.2 of ASCE 7-16 based on a 2% probability of exceedance in 50 years. To develop the site-specific design response spectrum, we performed probabilistic seismic hazard analysis (PSHA) and deterministic seismic hazard analysis (DSHA) to compute the risk-targeted maximum considered earthquake ( $MCE_R$ ) response accelerations. Our PSHA and DSHA used four NGA-West2 ground motion prediction equations (GMPEs) developed by Abrahamson et al. (2014), Boore et al. (2014), Campbell and Bozorgnia (2014), and Chiou and Youngs (2014), respectively. The analyses were based on the Uniform California Earthquake Rupture Forecast Version 3 (UCERF3) developed by the Working Group on California Earthquake Probabilities (WGCEP). UCERF3 is the California portion of the 2014 USGS national seismic source model (Petersen et al. 2014). Our analyses included treatment of maximum direction spectra and adjustment for risk targeting.

The analyses were performed using a  $V_{s,30}$  value of 348 m/sec and site coordinates of latitude 33.905595°N and longitude 117.470066°W. The site-specific design response spectrum is presented in Figure 13 – Site-Specific Design Response Spectrum, along with the  $MCE_R$  ground motions from our PSHA and DSHA. The detailed analysis description and results are presented below.

#### 5.11.1. Probabilistic Seismic Hazard Analysis

A site-specific PSHA was performed to evaluate probabilistic  $MCE_R$  ground motions. The probabilistic spectral response accelerations are taken as the spectral response accelerations in the direction of maximum horizontal response represented by a 5% damped acceleration response spectrum that is expected to achieve a 1% probability of collapse within a 50-year period. In this report, ordinates of the probabilistic ground motion response spectrum were determined by Method 1 of Section 21.2.1.1 of ASCE 7-16.

The PSHA was first performed using the Hazard Spectrum Calculator by OpenSHA.org (<http://www.opensha.org/apps-HazardSpectrumLocal>) to obtain an average spectrum of the geometric-mean acceleration response spectra from the four NGA-West2 GMPEs. The spectra were calculated for 5-percent damped and a 2 percent probability of exceedance within a 50-year period. The average spectrum was converted to the maximum response ground motion using scale factors described in Section 21.2 of ASCE 7-16. The scale factors are 1.1 for spectral response periods less than or equal to 0.2 s, 1.3 for a period of 1.0 s, 1.5 for periods greater than or equal to 5.0 s, and between these periods are obtained by linear interpolation. The maximum response ground motion was then multiplied by a risk coefficient  $C_R$  to obtain the probabilistic  $MCE_R$  ground motion response spectrum. The values of  $C_R$  are  $C_{RS}$  for periods less than or equal to 0.2 s and  $C_{R1}$  for periods greater than or equal to 1.0 s. For periods between periods 0.2 s and 1.0 s,  $C_R$  is based on linear interpolation of  $C_{RS}$  and  $C_{R1}$ . The values of  $C_{RS}$  and  $C_{R1}$  for this project are presented in Table 4.

#### 5.11.2. Deterministic Seismic Hazard Analysis

A site-specific DSHA was performed to evaluate the deterministic  $MCE_R$  ground motions. The deterministic  $MCE_R$  response acceleration at specified periods was calculated as the 84th percentile of the maximum rotated component of ground motion computed at each period for characteristic earthquakes on known active faults within the region.

The active faults and their parameters used in our DSHA are provided in Table 5, obtained from the Caltrans ARS Online Tool version 2.3.09 ([http://dap3.dot.ca.gov/ARS\\_Online/index.php](http://dap3.dot.ca.gov/ARS_Online/index.php)). The DSHA was performed for each fault to obtain the 5-percent-damped deterministic pseudo-absolute acceleration response spectrum using the four NGA-West2 GMPEs implemented in a Microsoft Excel spreadsheet available from the Pacific Earthquake Engineering Research Center (<https://peer.berkeley.edu/research/data-sciences/databases>).

**Table 5 - Seismic Source Parameters**

Fault Name	Elsinore (Glen Ivy rev)	San Jacinto (San Bernardino)	San Jacinto (San Bernardino Valley section)	Elsinore fault zone (Chino section)	Elsinore (Temecula)	San Andreas (San Bernardino S)
Fault ID	365	336	310	355	378	325
Slip Sense	Strike-Slip	Strike-Slip	Strike-Slip	Strike-Slip	Strike-Slip	Strike-Slip
M <sub>w</sub>	7.7	7.7	7.7	6.6	7.7	7.9
Dip, (deg)	90	90	90	50	90	90
Z <sub>TOR</sub> (km)	0	0	0	0	0	0
Z <sub>BOT</sub> , (km)	13	16	15	9.2	14	12.8
W (km)	13	16	15	12	14	12.8
R <sub>RUP</sub> (km)	12.86	22.06	23.83	13.2	27.43	34.69
R <sub>JB</sub> (km)	12.86	22.06	23.83	13.2	27.43	34.69
R <sub>X</sub> (km)	12.86	22.06	23.83	13.2	18.89	34.69
F <sub>NM</sub>	0	0	0	0	0	0
F <sub>RV</sub>	0	0	0	0	0	0

**Notes:**

M<sub>w</sub> = Moment magnitude.

Z<sub>TOR</sub> = The depth to the top of the rupture plane.

Z<sub>BOT</sub> = The depth to the bottom of the rupture plane.

W = Fault rupture width.

R<sub>RUP</sub> = Closest distance to coseismic rupture.

R<sub>JB</sub> = Closest distance to surface projection of coseismic rupture.

R<sub>X</sub> = Horizontal distance from top of rupture measured perpendicular to fault strike.

F<sub>RV</sub> = Reverse-faulting factor: 0 for strike-slip, normal, normal-oblique; 1 for reverse, reverse-oblique and thrust.

F<sub>NM</sub> = Normal-faulting factor: 0 for strike slip, reverse, reverse-oblique, thrust and normal-oblique; 1 for normal.

The resulting 84<sup>th</sup> percentile geometric-mean acceleration response spectra for the earthquakes were used to develop a deterministic response spectrum based on the greatest spectral acceleration at each period, and then converted into maximum rotated components of ground motion using the scale factors described in Section 21.2 of ASCE 7-16 as discussed in Section 5.11.1 of this report. The final deterministic MCE<sub>R</sub> is taken as the maximum rotated deterministic response spectrum scaled by a single factor equal to the greater of  $1.5F_a/S_{a,max,max}$  and 1, where  $S_{a,max,max}$  is the maximum spectral acceleration of the maximum rotated deterministic response spectrum, and  $F_a$  is determined to be 1 using Table 11.4.1 of ASCE 7-16.

### 5.11.3. Site-Specific Design Response Spectrum

The site-specific  $MCE_R$  spectral response acceleration was calculated at each period to be the lesser of the spectral response accelerations from the probabilistic and deterministic  $MCE_R$ , but not less than 1.5 times 80 percent of the spectral acceleration evaluated in accordance with Sections 11.4.6 and 21.3 of ASCE 7-16. In order to calculate the 80 percent of the spectral acceleration, values of  $S_{DS}$ ,  $S_{D1}$  and the design spectrum were calculated using the mapped values presented in Table 4, except that  $S_{M1}$  and  $S_{D1}$  at this step were based on an  $F_v$  value of 2.5, in accordance with Section 21.3 of ASCE 7-16.

Finally, the site-specific design spectral response acceleration at each period was calculated as two-thirds of the site-specific  $MCE_R$  spectral acceleration. The site-specific design response spectrum and relevant response spectral data are presented in Table 6 and Figure 13 – Site-Specific Design Response Spectrum.

**Table 6 - Site-Specific Design Response Spectrum Data**

Period T (sec)	General Procedure Design Response Spectrum for Exception 2 of ASCE 7-16 (g)	Risk Coefficient $C_R$	Site-Specific Ground Motion Analysis Spectral Accelerations (g)						
			Maximum direction 2%- in-50-years Probabilistic Spectrum	Probabilistic $MCE_R$	Maximum direction 84th- percentile Deterministic Spectrum	Deterministic $MCE_R$	80% General Procedure Design Response Spectrum with $F_v=2.5$	Site Specific $MCE_R$	Site- Specific Design Response Spectrum
0.01	0.445	0.943	0.850	0.801	0.647	0.647	0.345	0.647	0.431
0.02	0.490	0.943	0.855	0.807	0.649	0.649	0.369	0.649	0.433
0.03	0.535	0.943	0.903	0.851	0.674	0.674	0.394	0.674	0.449
0.05	0.625	0.943	1.083	1.021	0.770	0.770	0.444	0.770	0.513
0.075	0.738	0.943	1.382	1.303	0.934	0.934	0.506	0.934	0.623
0.1	0.850	0.943	1.630	1.537	1.085	1.085	0.567	1.085	0.723
0.133	1.000	0.943	1.817	1.713	1.238	1.238	0.650	1.238	0.825
0.15	1.000	0.943	1.911	1.802	1.315	1.315	0.691	1.315	0.876
0.194	1.000	0.943	2.020	1.904	1.440	1.440	0.800	1.440	0.960
0.2	1.000	0.943	2.034	1.919	1.457	1.457	0.800	1.457	0.971
0.25	1.000	0.942	2.093	1.971	1.554	1.554	0.800	1.554	1.036
0.3	1.000	0.940	2.112	1.986	1.667	1.667	0.800	1.667	1.111
0.4	1.000	0.938	2.014	1.889	1.747	1.747	0.800	1.747	1.165
0.5	1.000	0.935	1.884	1.761	1.789	1.789	0.800	1.761	1.174
0.667	1.000	0.930	1.639	1.524	1.681	1.681	0.800	1.524	1.016
0.75	0.889	0.928	1.516	1.406	1.628	1.628	0.800	1.406	0.938
0.9	0.741	0.924	1.354	1.250	1.572	1.572	0.800	1.250	0.834
0.97	0.687	0.922	1.268	1.169	1.540	1.540	0.800	1.200	0.800
1	0.667	0.921	1.234	1.137	1.528	1.528	0.776	1.164	0.776
1.5	0.444	0.921	0.821	0.756	1.208	1.208	0.517	0.776	0.517
2	0.333	0.921	0.604	0.556	0.996	0.996	0.388	0.582	0.388
3	0.222	0.921	0.402	0.370	0.766	0.766	0.259	0.388	0.259
4	0.167	0.921	0.300	0.277	0.607	0.607	0.194	0.291	0.194
5	0.133	0.921	0.248	0.229	0.484	0.484	0.155	0.233	0.155

#### 5.11.4. Site-Specific Seismic Design Parameters

The site-specific seismic design parameters are provided in Table 7. These parameters were determined from the site-specific design response spectrum presented in Table 6 following Section 21.4 of ASCE 7-16.

It should be noted that for use with the equivalent lateral force procedure in structural design, the site specific design spectral acceleration,  $S_a$  (the last column in Table 6 of this report), at  $T$  may replace  $S_{D1}/T$  and  $S_{D1}T_L/T^2$  in ASCE 7-16 Eqs. (12.8-3) and (12.8-4), respectively. The site-specific seismic design parameter  $S_{DS}$  shown in Table 7 of this report may be used in ASCE 7-16 Eqs. (12.8-2), (12.8-5), (15.4-1), and (15.4-3). The mapped value of  $S_1$  in Table 4 of this report should be used in ASCE 7-16 Eqs. (12.8-6), (15.4-2), and (15.4-4).

**Table 7 - Site-Specific Seismic Design Parameters**

Site-Specific Seismic Design Parameters	Design Values (g)
Spectral Response Acceleration 0.2-second period, $S_{MS}$	1.585
Spectral Response Acceleration 1-second period, $S_{M1}$	1.164
Design Spectral Response Acceleration for short period, $S_{DS}$	1.056
Design Spectral Response Acceleration for 1-second period, $S_{D1}$	0.776
MCE Geomatic Mean ( $MCE_G$ ) Peak Ground Acceleration, $PGA_M$	0.588

## 6. GEOTECHNICAL ENGINEERING RECOMMENDATIONS

Based on the results of our literature review and the field exploration, laboratory testing, and engineering analyses, it is our opinion that the proposed construction is feasible from a geotechnical standpoint, provided that the recommendations in this report are incorporated into the design plans and are implemented during construction.

### 6.1. General Considerations

Geotechnical engineering recommendations presented in this report for the proposed project are based on our understanding of the proposed development, subsurface conditions encountered during our field exploration, the results of laboratory testing on soil samples taken from the site, and our engineering analyses.

The following sections present our conclusions and recommendations pertaining to the engineering design for this project. If the design substantially changes, then our geotechnical engineering recommendations would be subject to revision based on our evaluation of the changes.

### 6.2. Soil Expansion and Collapse Potential

Based on our field exploration and laboratory test results, the risk of soil expansion and collapse is low at the site and will not adversely affect the design and construction of the project.

### **6.3. Corrosive Soil Evaluation**

The potential for the near-surface on-site materials to corrode buried steel and concrete improvements was evaluated. Laboratory testing was performed on one selected near-surface soil to evaluate pH and electrical resistivity, as well as chloride and sulfate contents. The pH and electrical resistivity tests were performed in accordance with California Test 643, and the sulfate and chloride tests were performed in accordance with California Tests 417 and 422, respectively. These laboratory test results are presented in Appendix B.

Corrosive soil may be defined as the soil has minimum electrical resistivity less than 1,000 ohm-centimeters, or chloride concentration greater than 500 parts per million (ppm), or sulfate concentration in soils greater than 2,000 ppm, or a pH less than 5.5 (e.g., based on the County of Los Angeles criteria or the California Department of Transportation criteria).

Discussions of corrosion protection for reinforced concrete and buried metal is provided below. Further interpretation of the corrosivity test results and associated corrosion design and construction recommendations are within the purview of a corrosion specialist. It is recommended that a qualified corrosion engineer be retained to review the corrosivity test results, to evaluate the general corrosion potential with respect to construction materials at this site, and to review the proposed design.

#### **6.3.1. Reinforced Concrete**

Laboratory tests indicate that the soil has 427 ppm (0.0427%) or less of water soluble sulfate ( $\text{SO}_4$ ) by weight. Based on ACI 318, concrete in contact with the site soils will have a sulfate exposure class S0. As a minimum, we recommend that Type II cement and a water-cement ratio of no greater than 0.50 be used on the project.

Test results indicate that the soil has 165 ppm or less of water soluble chlorides by weight and the potential for chloride attack of reinforcing steel in concrete structures and pipes in contact with soil is negligible. However, if needed, a corrosion specialist may be consulted for protection from chloride attack.

#### **6.3.2. Buried Metal**

A factor for evaluating corrosivity to buried metal is electrical resistivity. The electrical resistivity of a soil is a measure of resistance to electrical current. Corrosion of buried metal is directly proportional to the flow of electrical current from the metal into the soil. As resistivity of the soil decreases, the corrosivity generally increases. Test results indicate the site soils have a minimum electrical resistivity value greater than 1,000 ohm-centimeters, except for the boring PT-2 area where site soils have a minimum electrical resistivity value of 990 ohm-centimeters. Based on the criteria of the County of Los Angeles and the California Department of Transportation, the soils with minimum electrical resistivity less than 1,000 ohm-centimeters are considered corrosive to buried metals.

Correlations between resistivity and corrosion potential published by the National Association of Corrosion Engineers (NACE, 1984) indicate that the soils with minimum electrical resistivity less than 1,000 ohm-centimeters are considered severely corrosive to buried metals. Based on that, corrosion protection for metal in contact with site soils should be considered. Corrosion protection may include the use of epoxy or asphalt coatings. A corrosion specialist should be consulted regarding appropriate protection for buried metals and suitable types of piping.

#### **6.4. Site Preparation and Earth Work**

In general, earthwork should be performed in accordance with the recommendations presented in this report. Twining should be contacted for questions regarding the recommendations or guidelines presented herein.

##### **6.4.1. Site Preparation**

Site preparation should begin with the removal of utility lines, asphalt, concrete, vegetation, topsoil, and other deleterious debris from areas to be graded. Tree stumps and roots should be removed to such a depth that organic material is not present. Clearing and grubbing should extend to the outside edges of the proposed excavation and fill areas. We recommend that unsuitable materials such as organic matter or oversized material be removed and disposed of offsite. The debris and unsuitable material generated during clearing and grubbing should be removed from areas to be graded and disposed of at a legal dump site away from the project area.

##### **6.4.2. Temporary Excavations**

Temporary excavations less than 20 feet deep are expected for the project. We anticipate that unsurcharged excavations with vertical sides less than 4 feet high will generally be stable; however, if excavation extends to the sandy soil layers, some sloughing of cohesionless sandy materials encountered at the site should be expected.

Where space is available, temporary, un-surcharged excavation sides over 4 feet in height should be sloped no steeper than an inclination of 1.5H:1V (horizontal:vertical).

The tops of the excavation sides should be barricaded so that vehicles and storage loads are away from the top edge of the excavated slopes with a distance at least equal to the height of the slopes. A greater setback may be necessary when considering heavy vehicles, such as concrete trucks and cranes. Twining should be advised of such heavy vehicle loadings so that specific setback requirements can be established. If the temporary construction slopes are to be maintained during the rainy season, berms are recommended to be graded along the tops of the slopes in order to prevent runoff water from entering the excavation and eroding the slope faces.

Excavations should not undermine the existing adjacent improvements. Prior to excavation in the proximity of an existing improvement, Twining should be contacted to evaluate that there will be no loss of support for all excavations close to the existing improvement.

Personnel from Twining should observe the excavations so that any necessary modifications based on variations in the encountered soil conditions can be made. All applicable safety requirements and regulations, including CalOSHA requirements, should be met. Stability of temporary excavations is the responsibility of the contractor.

##### **6.4.3. Over-Excavation and Subgrade Preparation**

The proposed structures may be supported by shallow foundations. It is recommended that the footings be founded on undisturbed competent native soils or engineered fill.

Undocumented fill, if encountered during construction within the proposed tower, generator pad and propane tank footprints, should be removed to its full depth. For the tower slab and footings,

no additional overexcavation is required once the fill is removed. Once the fill has been removed and the native material exposed, the upper 6 inches of the exposed native material should be scarified, moisture conditioned, and recompacted to 90%, and observed by a representative of Twining prior to the placement of any fill or reinforcing bar.

If fill is encountered during excavation for minor structures that are structurally separated from the tower, the excavation should extend at least 2 feet below the finished grade or at least 1 foot below the bottom of the footing of the minor structures, whichever is greater. Excavation for pavements and hardscape should be over-excavated at least 1 foot as measured from the bottom of the pavement or hardscape section.

Laterally, foundation excavation should extend beyond the foundation limits a minimum distance equal to two feet or the depth of over-excavation, whichever is greater. Excavation for other improvements (e.g., concrete walkways, flatwork, pavement) should extend laterally at least two feet beyond the limits of the improvements.

The extent and depths of all removal should be evaluated by Twining's representative in the field based on the materials exposed. Should excavations expose soft soils or soils considered as unsuitable for use as fill by a Twining representative, additional removals may be recommended. For example, deeper removal may be required in areas where soft, saturated, or organic materials are encountered.

The exposed bottom of over-excavation should be evaluated and approved by Twining. The excavation bottom to receive fill should be scarified to a minimum depth of 6 inches and moisture conditioned to achieve generally consistent moisture contents approximately 2 percent above the optimum moisture content. The scarified bottom should be compacted to at least 90 percent relative compaction in accordance with the latest version of ASTM Test Method D1557 and then evaluated and approved by Twining.

Prior to placement of reinforcing steel or concrete for foundations, the bottom of footing excavations should be scarified to a minimum depth of 6 inches, moisture conditioned to achieve generally consistent moisture contents approximately 2 percent above the optimum moisture content, and recompacted to at least 90 percent of the maximum dry density as determined from ASTM D 1557.

Fill and backfill materials should be compacted fill in accordance with Sections 6.4.4 and 6.4.5 of this report. Prior to placement of any fill, the geotechnical engineer or their representative should review the bottom of the excavation for conformance with the recommendations of this report.

#### **6.4.4. Materials for Fill**

In general, on-site soils are considered as suitable for use as fill materials. All fill soils should be free of organics, debris, rocks or lumps over three inches in largest dimension, other deleterious material, and not more than 40 percent larger than  $\frac{3}{4}$  inch. Larger chunks, if generated during excavation, may be broken into acceptably sized pieces or may be disposed of offsite.

Any imported fill material should consist of granular soil having a "very low" expansion potential (i.e., expansion index of 20 or less). Import material should also have low corrosion potential (that is, chloride content less than 500 ppm, soluble sulfate content of less than 0.1 percent, and pH of 5.5 or higher).

All fill soils should be evaluated and approved by a Twining representative prior to importing or filling.

#### **6.4.5. Compacted Fill**

Unless otherwise recommended, the exposed excavation bottom to receive fill should be prepared in accordance with Section 6.4.3 of this report. Prior to placement of compacted fill, the contractor should request Twining to evaluate the exposed excavation bottoms.

Compacted fill should be placed in horizontal lifts of approximately 8 to 10 inches in loose thickness, depending on the equipment used. Prior to compaction, each lift should be moisture conditioned, mixed, and then compacted by mechanical methods. The moisture content should be approximately 2 percent above the optimum moisture content. Fill materials should be compacted to a minimum relative compaction of 95 percent within the upper one foot below new vehicle trafficked pavement sections, and 90 percent in all other areas, unless indicated otherwise. The relative compaction should be determined by ASTM D1557. Successive lifts should be treated in the same manner until the desired finished grades are achieved.

#### **6.4.6. Excavation Bottom Stability**

In general, we anticipate that bottoms of the excavations will be stable and should provide suitable support for the proposed improvements. Conditions of the excavation bottom should be evaluated by Twining during the scarification and re-compaction efforts. If unstable bottom conditions are encountered, remedial measures would be required to stabilize the bottom. Soft bottom conditions can be identified by surface yielding under rubber-tired equipment loading and the inability to achieve proper compaction. Recommendations for stabilizing excavation bottoms should be based on evaluation in the field by the geotechnical consultant at the time of construction.

#### **6.4.7. Backfill for Utility Trench**

Utility trench excavations to receive backfill shall be free of trash, debris or other unsatisfactory materials at the time of backfill placement.

At locations where the trench bottom is yielding or otherwise unstable, pipe support may be improved by placing 12 inches of crushed aggregate base (CAB) or crushed miscellaneous base (CMB) as defined in the "Greenbook" Standard Specifications for Public Works Construction (SSPWC).

The trench should be bedded with clean sand extending to at least 6 inches below the bottom of the pipe and one foot over the top of pipe. Pipe bedding as specified in SSPWC can be used. Bedding material should consist of clean sand having a sand equivalent (SE) of 30 or greater. Alternative materials meeting the intent of the bedding specifications are also acceptable. Samples of materials proposed for use as bedding should be provided to the engineer for inspection and testing before the material is imported for use on the project. The onsite materials in the upper 20 feet consist of sandy lean clay and thus do not appear suitable for bedding, unless segregation of sandy materials is performed during excavation. The pipe bedding material should be placed over the full width of the trench. After placement of the pipe, the bedding should be brought up uniformly on both sides of the pipe and mechanically compacted to reduce the potential for unbalanced loads. No void or uncompacted areas should be left beneath the pipe haunches.

Above pipe bedding, trench backfill may be onsite soils and should not contain rocks or lumps over 3 inches in largest dimension. Larger chunks, if generated during excavation, may be broken into acceptably sized pieces or may be disposed of offsite. The moisture content should be approximately 2 percent above the optimum moisture content.

Backfill may be placed and compacted by mechanical means and should be compacted to 90 percent of the laboratory maximum dry density as per ASTM Standard D1557. Where pavement is planned, the top 12 inches of subgrade soils and the overlying aggregate base should be compacted to 95 percent.

Jetting or flooding of pipe bedding and backfill material is not recommended.

#### **6.4.8. Rippability**

The earth materials underlying the site should be generally excavatable with heavy-duty earthwork equipment in good working condition. Some gravels, cobbles and artificial fill (although not identified in our borings) should be anticipated.

#### **6.4.9. Construction Dewatering**

As discussed earlier, groundwater was encountered at approximately 57.5 feet bgs during our field exploration. Construction of the project is anticipated to occur above the groundwater. The possibility to encounter groundwater is low during earthwork and foundation preparation for the proposed structures, and the need for dewatering is not anticipated for construction of foundations and utility trenches.

### **6.5. Foundation Recommendations**

Based upon the excavation/over-excavation and backfill recommendations, the proposed project may be supported on shallow foundations designed in accordance with the geotechnical recommendations presented below. Structural design of foundations should be performed by the structural engineer and should conform to the 2019 California Building Code.

#### **6.5.1. Footing Foundation**

Continuous strip footings or isolated footings for the proposed tower should be placed on the subgrade prepared in accordance the requirements described in Section 6.4. Geotechnical design parameters for these footings presented in Table 8 may be used. Twining should be contacted for footing dimensions, allowable bearing pressures, and settlements that are outside the indicated applicable ranges.

Footings beneath the design groundwater level should be designed for hydrostatic uplift. For this project site, the design groundwater level can be assumed to be approximately 710.5 feet above msl or 12.5 feet bgs as discussed in Section 4.3 – Groundwater Conditions.

Lateral loads may be resisted by footing base friction and by the passive resistance of the soils based on recommendations provided in Table 8.

The total lateral resistance can be taken as the sum of the friction at the base of the footing and passive resistance. The upper one foot of soil should be neglected when calculating the passive resistance. The passive resistance value may be increased by one-third for transient loads from wind or earthquake.

**Table 8 - Geotechnical Design Parameters for Footing Foundations**

<b>Minimum Footing Dimensions</b>	<ul style="list-style-type: none"> <li>• <u>Continuous footings</u>: 18 inches in width.</li> <li>• <u>Square footings</u>: 24 inches in width.</li> <li>• <u>Minimum embedment</u>: 24 inches measured from the lowest adjacent grade to the bottom of the footing.</li> <li>• <u>Minimum thickness</u>: 6 inches</li> </ul>
<b>Allowable Bearing Pressure</b>	<ul style="list-style-type: none"> <li>• For footings installed 10 feet or less below existing ground surface: allowable bearing pressures of 1,500 and 1,800 pounds per square foot (psf) may be used for continuous and square footings, respectively.</li> <li>• For footings installed more than 10 feet below existing ground surface: allowable bearing pressures of 4,500 and 5,500 psf may be used for continuous and square footings, respectively.</li> <li>• The allowable bearing values correspond to a factor of safety of 3.</li> <li>• The allowable bearing values may be increased by one-third for transient loads from wind or earthquake.</li> </ul>
<b>Estimated Static Settlement</b>	<ul style="list-style-type: none"> <li>• Approximately one inch of total settlement with differential settlement estimated to be on the order of ½ inches over 30 feet.</li> <li>• The static settlement of the foundation system is expected to complete on initial application of loading.</li> </ul>
<b>Allowable Friction at the Bottom of Footing</b>	<ul style="list-style-type: none"> <li>• 0.3.</li> <li>• No increase is allowed for transient loading conditions.</li> <li>• The allowable bottom friction values correspond to a factor of safety of 1.5.</li> </ul>
<b>Allowable Lateral Passive Resistance</b>	<ul style="list-style-type: none"> <li>• 250 psf per foot of depth (i.e., 250 pcf equivalent fluid pressure).</li> <li>• The allowable passive resistance corresponds to a factor of safety of 2.</li> </ul>

### 6.5.2. Mat Foundation

Mat foundations for the proposed generator pad and propane tank or other structures should be placed on the subgrade prepared in accordance the requirements described in Section 6.4. The depths, plan dimensions, and vertical load of the mat are not available for our review at the time of this report. For design of mat foundations with plan dimension of 20 feet by 70 feet or smaller, an allowable bearing pressure of 2,000 psf may be used. A factor of safety of 3 is incorporated into the allowable bearing capacity. Estimated total settlement at the center of the mat is about 1.5 inches, and along the edges of the mat varies from 0.6 to 0.9 inches. Settlement of the mat is expected to complete on initial application of loading. For structural design of the mat according to the 2019 CBC, a subgrade modulus k calculated from Section 6.7 may be used.

Lateral loads may be resisted by footing base friction and by the passive resistance of the soils based on recommendations provided in Table 8.

The total lateral resistance can be taken as the sum of the friction at the base of the footing and passive resistance. The upper one foot of soil should be neglected when calculating the passive resistance. The passive resistance value may be increased by one-third for transient loads from wind or earthquake.

### 6.6. Surcharge from Adjacent Footings

Design of new footings or evaluation of existing footings should consider vertical surcharge from adjacent footings that are located above the 1:1 plane drawn up from the closest bottom edge of the footing being designed or evaluated. Surcharge located below the 1:1 plane may be ignored.

### 6.7. Modulus of Subgrade Reaction

The modulus of subgrade reaction k for design of mat foundations, combined footing, and slabs-on-grade may be obtained from the following equation.

$$k = \frac{k_1}{B} \left( \frac{2L + B}{3L} \right)$$

where:  $k_1$  = modulus for a 1-foot by 1-foot plate = 100 pounds per cubic inch (pci);  
B = width of combined footing or slab in feet;  
L = length of combined footing or slab in feet, and  $L \geq B$ .

### 6.8. Concrete Slabs

Slabs should be supported on non-expansive engineered fill in accordance with Section 6.4 of this report. For design of concrete slabs, the subgrade modulus k calculated from Section 6.7 may be used.

The design of slabs beneath the design groundwater level should consider hydrostatic uplift. For this project site, the design groundwater level can be assumed to be approximately 710.5 feet above msl or 12.5 feet bgs as discussed in Section 4.3 – Groundwater Conditions. Additionally, the slabs should be waterproofed and have proper under drainage. The under drainage for slabs beneath the



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

design water level should consist of at least 6 inches of free draining materials that consist of clean sand, gravel, or crushed rock with less than 5% fines.

Floor slabs should be designed and reinforced in accordance with the structural engineer's recommendations. For slabs not supporting heavy loads, we recommend that the concrete should have a thickness of at least 4 inches, a 28-day compressive strength of at least 3,000 pounds per square inch (psi), a water-cement ratio of 0.50 or less, and a slump of 4 inches or less. Slabs should be reinforced with at least No. 3 reinforcing bars placed longitudinally at 18 inches on center. The reinforcement should extend through the control joints to reduce the potential for differential movement. Control joints should be constructed in accordance with recommendations from the structural engineer or architect. For slabs supporting equipment, a minimum thickness of 5 inches is recommended. Additional thickness and reinforcement recommendations may be provided by the structural engineer.

The topmost 8 inches below the slab subgrade should be maintained in a moisture condition of approximately 0 to 2 percent above optimum moisture content. The slab subgrade should be tested for moisture and compaction immediately prior to placement of the gravel or sand base, if any. All underslab materials should be adequately compacted prior to the placement of concrete. Care should be taken during placement of the concrete to prevent displacement of the underslab materials. The underslab material should be dry or damp and should not be saturated prior to the placement of concrete. The concrete slab should be allowed to cure properly and should be tested for moisture transmission prior to placing vinyl or other moisture-sensitive floor covering. In moisture sensitive areas, the floor slabs should be dampproofed in accordance with Section 1805A.2 of 2019 CBC. Specific recommendations can be provided by a waterproofing consultant.

Table 9 provides general recommendations for various levels of protection against vapor transmission through concrete floor slabs placed over a properly prepared subgrade. Care should be taken not to puncture the plastic membrane during placement of the membrane itself and the overlying silty sand.

**Table 9 - Options for Subgrade Preparation below Concrete Floor Slabs**

Primary Objective	Recommendation
<b>Enhanced protection against vapor transmission</b>	<ul style="list-style-type: none"> <li>• Concrete floor slab-on-grade placed directly on a 15-mil-thick moisture vapor retarder that meets the requirements of ASTM E1745 Class C (Stego Wrap or similar)</li> <li>• The moisture vapor retarder membrane should be placed directly on the subgrade (ACI302.1R-67); if required for either leveling of the subgrade or for protection of the membrane from protruding gravel, then place about 2 inches of silty sand<sup>1</sup> under the membrane</li> </ul>
<b>Above-standard protection against vapor transmission</b>	<p>This option is available if the slab perimeter is bordered by continuous footings at least 24 inches deep, OR if the area adjacent and extending at least 10 feet from the slab is covered by hardscape without planters:</p> <ul style="list-style-type: none"> <li>• 2 inches of dry silty sand<sup>1</sup>; over</li> <li>• Waterproofing plastic membrane 10 mils in thickness; over</li> <li>• At least 4 inches of ¾-inch crushed rock<sup>2</sup> or clean gravel<sup>3</sup> to act as a capillary break</li> </ul>
<b>Standard protection against vapor transmission</b>	<ul style="list-style-type: none"> <li>• 2 inches of dry silty sand<sup>1</sup>; over</li> <li>• Waterproofing plastic membrane 10 mils in thickness</li> <li>• If required for either leveling of the subgrade or for protection of the membrane from protruding gravel, place at least 2 inches of silty sand<sup>1</sup> under the membrane.</li> </ul>
<p>Notes:</p> <p><sup>1</sup> The silty sand should have a gradation between approximately 15 and 40 percent passing the No. 200 sieve and a plasticity index of less than 4.</p> <p><sup>2</sup> The ¾-inch crushed rock should conform to Section 200-1.2 of the latest edition of the "Greenbook" Standard Specifications for Public Works Construction (Public Works Standards, Inc., 2012).</p> <p><sup>3</sup> The gravel should contain less than 10 percent of material passing the No. 4 sieve and less than 3 percent passing the No. 200 sieve.</p>	

The above recommendations are intended to reduce the potential for cracking of slabs; however, even with the incorporation of the recommendations presented herein, slabs may still exhibit some cracking. The occurrence of concrete shrinkage cracks is independent of the supporting soil characteristics.

## 6.9. Pole Foundations

Pole foundations for flagpoles, fences, and signposts may be designed using an allowable unit skin friction of 375 psf and an allowable end bearing resistance of 2,000 psf. A factor of safety of 2 is incorporated into the allowable skin friction, and a factor of 3 is incorporated into the allowable end bearing.

Lateral resistance for conditions with and without lateral constraint provided at the ground surface conditions are provided below based on 2019 CBC.

### 6.9.1. Non-Constrained Ground

The embedment of pole foundations where no lateral constraint is provided at or above the ground surface should be calculated using Equation 18A-1 of 2019 CBC (shown below) or a minimum 3 feet below the ground surface, whichever is deeper.

$$d = \frac{A}{2} \left( 1 + \sqrt{1 + \frac{4.36h}{A}} \right) \quad \text{(Equation 18A-1 of 2019 CBC)}$$

where:

A =  $2.34P/(S_1 \cdot b)$

b = Diameter of round post or footing or diagonal dimension of square post or footing, feet.

d = Depth of embedment in earth in feet but not over 12 feet for purpose of computing lateral pressure.

h = Distance in feet from ground surface to point of application of "P".

P = Applied lateral force in pounds.

S<sub>1</sub> = Allowable lateral soil-bearing pressure based on a depth of one-third the depth of embedment in pounds per square foot.

An allowable passive earth pressure of 250 pcf up to a maximum of 3,750 psf may be used for design provided the upper one foot of passive resistance is neglected in the structural design. Isolated pole foundations spaced at least 3 diameters of the maximum pole foundation may be designed using an allowable lateral resistance equal to 2 times of the allowable passive pressure.

### 6.9.2. Constrained Ground

The embedment of pole foundations where lateral constraint is provided at the ground surface, such as by a rigid floor or pavement, should be calculated using Equation 18A-2 of 2019 CBC (shown below) or a minimum 3 feet below the ground surface, whichever is deeper.

$$d = \sqrt{\frac{4.25Ph}{S_3 b}} \quad \text{(Equation 18A-2 of 2019 CBC)}$$

where:

b = Diameter of round post or footing or diagonal dimension of square post or footing, feet.

d = Depth of embedment in earth in feet but not over 12 feet for purpose of computing lateral pressure.

h = Distance in feet from ground surface to point of application of "P".

P = Applied lateral force in pounds.

$S_3$  = Allowable lateral soil-bearing pressure based on a depth of one-third the depth of embedment in pounds per square foot.

An allowable passive earth pressure of 250 pcf up to a maximum of 3,750 psf may be used for design provided the upper one foot of passive resistance is neglected in the structural design. Isolated pole foundations spaced at least 3 diameters of the maximum pole foundation may be designed using an allowable lateral resistance equal to 2 times of the allowable passive pressure.

## **6.10. Below-Grade Wall and Lateral Earth Pressure Recommendations**

For walls below grade, recommendations for wall lateral loads, backfill, and drainage are provided below. Lateral resistance may be based on Section 6.5.1 of this report. Retaining walls should be designed to have a factor of safety of 1.5 for static stability and 1.1 for stability due to transient loads from wind or seismic.

### **6.10.1. Backfill and Drainage of Walls**

The backfill material behind walls should consist of granular non-expansive material and be approved by the project geotechnical engineer. Based on the soil materials encountered during our exploration, most on-site soils will meet this requirement, provided that wall backfill is adequately drained.

Wall backfill should be adequately drained. Adequate backfill drainage is essential to provide a free-drained backfill condition and to limit hydrostatic buildup behind walls. Drainage behind walls may be provided by a geosynthetic drainage composite such as TerraDrain, MiraDrain, or equivalent, attached to the outside perimeter of the wall and installed in accordance with the manufacturer's recommendations. The drainage system should meet the minimum requirements of Sections 1805A.4.2 and 1805A.4.3 of 2019 CBC.

Walls beneath the design groundwater level should be waterproofed. For this project site, the design groundwater level can be assumed to be approximately 710.5 feet above msl or 12.5 feet bgs as discussed in Section 4.3 – Groundwater Conditions. Walls above this level should be damp-proofed.

### **6.10.2. Lateral Earth Pressure**

The values presented below assume that the supported grade is level and that surcharge loads are not applied. The recommended design lateral earth pressure is calculated assuming that a drainage system will be installed behind retaining walls in accordance with Sections 1805A.4.2 and 1805A.4.3 of 2019 CBC and that external hydrostatic pressure will not develop behind the walls.

Walls that are free to move and rotate at the top (such as cantilevered walls) and have adequate drainage may be designed for the active earth pressure equivalent to a fluid weighting 51 pcf.

Walls that are restricted to move horizontally at the top (such as by a floor deck) and have adequate drainage may be designed for the "at-rest" earth pressure equivalent to a fluid weighing 72 pcf.


Where wall backfill does not have adequate drainage or is beneath the design groundwater level, walls under active conditions should be designed for 88.1 pcf equivalent fluid pressure (including 25.7 pcf effective earth pressure and 62.4 pcf hydrostatic pressure), and walls under

at-rest conditions should be designed for 98.7 pcf equivalent fluid pressure (including 36.3 pcf effective earth pressure and 62.4 pcf hydrostatic pressure). For this project site, the design groundwater level can be assumed to be approximately 710.5 feet above msl or 12.5 feet bgs as discussed in Section 4.3 – Groundwater Conditions.

Vertical surcharge loads within a 1:1 plane projected from the bottom of the wall distributed over retained soils should be considered as additional uniform horizontal pressures acting on the wall. These additional pressures can be estimated as approximately 41% and 58% of the magnitude of the vertical surcharge pressures for the “active” and “at-rest” conditions, respectively.

### 6.10.3. Seismic Lateral Earth Pressure

Walls retaining more than 6 feet high earth should be designed for seismic lateral earth pressure. The seismic pressure distribution may be considered a triangle with the maximum pressure at the bottom. The combination of static and incremental seismic pressures shown in the following diagram may be used for seismic design for both cantilever and restrained walls.



where  $H$  is in feet

### Seismic Earth Pressure Distribution on Walls

### 6.11. Temporary Shoring

If the project involves excavations that lack sufficient space for sloped excavations, cantilevered shoring or braced- or tieback shoring should be considered and designed.

For vertical excavations less than approximately 15 feet in height, cantilevered shoring may be used. Where cantilevered shoring is used for deeper excavations, the total deflection at the top of the wall tends to exceed acceptable magnitudes. Shoring of excavations deeper than approximately 15 feet should be accomplished with the aid of internal bracing or tieback earth anchors.

The shoring design should be provided by a California Registered Civil Engineer experienced in the design and construction of shoring under similar conditions. Once the final excavation and shoring plans are complete, the plans and the design should be reviewed by the geotechnical engineer for conformance with the design intent and recommendations. Further, the shoring system should satisfy applicable requirements of CalOSHA.

#### 6.11.1. Lateral Earth Pressures

For design of cantilevered shoring for excavations less than 15 feet in height, a triangular distribution of lateral earth pressure may be used. It may be assumed that the drained soils, with a level surface behind the cantilevered shoring, will exert an equivalent fluid pressure of 51 pcf.

For the design of braced- or tieback-shoring, a rectangular pressure distribution where the pressure may be used. The design pressure should be  $36H$  psf, where  $H$  is the retained soil height in feet.

Any surcharge (live, including traffic, or dead load) located within a 1:1 plane projected upward from the base of the shored excavation, including adjacent structures, should be added to the lateral earth pressures. The lateral contribution of a uniform surcharge load located immediately behind the temporary shoring may be calculated by multiplying the vertical surcharge pressure by 41% for cantilevered shoring and 58% for braced- or tieback-shoring, corresponding to the “active” and “at-rest” conditions, respectively. Lateral load contributions of surcharges located at a distance behind the shored wall may be provided once the load configurations and layouts are known. As a minimum, a 250 psf vertical uniform surcharge is recommended to account for nominal construction and/or traffic loads. More detailed lateral pressure and loading information can be provided, if needed, for specific loading scenarios as recognized through the design process.

#### 6.11.2. Soldier Pile Design

The soldier piles for support of shoring should be designed in accordance with the geotechnical parameters presented in Table 10. Soldier piles should be spaced no closer than  $3D$  on center, where  $D$  is the diameter of the drilled shaft for the soldier piles. Soldier piles may consist of either cast-in-place concrete caissons or pre-drilled steel beams encased in concrete (below the bottom of the excavation) and slurry (above the bottom of the excavation).

**Table 10 - Geotechnical Design Parameters for Soldier Piles**

The allowable lateral resistance of an isolated soldier pile drilled into the on-site soils can be calculated using equivalent fluid pressure (EFP)	250 pcf
Increase (multiplier) of the ultimate lateral passive resistance due to arching (this value is applicable for soldier piles that are spaced no closer than 3 diameters)	2

Continuous timber lagging should be used between the soldier piles. If treated timber is used, the lagging may remain in place. To develop the full lateral resistance, provisions should be taken to assure firm contact between the soldier piles and the soils; for this, we recommend that 1-½-sack sand-cement slurry infill behind the lagging be used. For drilled piles, we recommend that piles adjacent to one another be drilled alternately on different days to minimize disturbance to the open excavations.

Drilling of the soldier pile shafts can be accomplished using conventional drilling equipment. Caving should be anticipated where layers of clean sand or silty sand occurs. In the event of soil caving, it may be necessary to use casing and/or drilling mud to permit the installation of the soldier piles. Drilled holes for soldier piles should not be left open overnight. Concrete for piles should be placed immediately after the drilling of the hole and placement of the steel pile (or rebar cage) is complete. The concrete should be pumped to the bottom of the drilled shaft using a tremie. Once concrete pumping is initiated, the bottom of the tremie should remain below the surface of the concrete to prevent contamination of the concrete by soil inclusions. If steel casing is used, the casing should be removed as the concrete is placed. The concrete placed in the soldier pile excavations may be a lean mix concrete above the elevation of the bottom of the excavation. However, the concrete that is placed in the portion of the soldier pile that is below the deepest planned excavated level should have a minimum 28-day compressive strength of at least 2,500 pounds per square inch (psi). The contractor may also consider the use of driven piles or piles that are vibrated into place in lieu of drilled piles to address potential issues related to caving of drilled shafts.

### **6.11.3. Tieback Design**

Excavations deeper than 15 feet may require tieback anchors to be used to resist lateral loads. For design purposes, it may be assumed that the failure wedge adjacent to the shoring is defined by a plane up at approximately 30 degrees from the vertical from the toe of the wall. The anchors should extend at least 15 feet beyond the potential failure wedge; however, the shoring engineer should evaluate the bonded length required beyond the failure wedge based on the loading on the shoring and the allowable skin friction provided. The bonded length should commence no less than 3 feet beyond the failure wedge.

We recommend using an allowable soil/anchor bond friction of 500 psf along the anchors in the bonded zone with a factor of safety of 1.5. Only friction developed beyond the active wedge should be considered when determining the tieback resistance. If the anchors are spaced at least 6 feet on center, no reduction in the capacity of the anchors need be considered due to group action.

As the tieback shoring system is intended for temporary use, provisions should be made in the design to de-tension and abandon the tiebacks when the subgrade walls are able to support the lateral loads.

### **6.11.4. Anchor Installation**

The anchors may be installed at angles of 15 to 30 degrees below the horizontal. Caving may occur during the drilling of tiebacks if loose cohesionless materials are encountered. The contractor should implement appropriate measures to stabilize the drilled hole such as the installation of steel casing for loose cohesionless materials or the use of drilling mud. The anchors should be filled with concrete placed by pumping from the tip out. The portion of the anchor tendons within the failure wedge should be sleeved in plastic. If the anchor tendons are sleeved, it is acceptable to grout the entire length of the anchor.

#### **6.11.5. Lagging and Sheeting**

Continuous lagging will be required between the soldier piles. The soldier piles and anchors should be designed for the full anticipated lateral pressure. However, where lagging is relatively flexible to wales or soldier beams, the pressure on the lagging will be less due to arching in the soils. We recommend that the lagging be designed for a semi-circular distribution of earth pressure where the maximum pressure is 500 pounds per square foot at the mid-line between soldier piles, and 0 pounds per square foot at the soldier piles.

#### **6.11.6. Lateral Deflection and Settlement**

Excessive deflection could result in settlement or undermining of surrounding structures. Shoring should be adequately designed, installed, and monitored to limit the amount of lateral deflection of the shoring system and settlement behind the shoring to the allowable values of adjacent structures and improvements. The amount of deflection of the shoring system and the allowable deflections and settlements should be determined by the shoring designer. The allowable deflections and settlements should be based on the proximity of adjacent structures and improvements and the potential negative effects on those structures. If it is desired to reduce the deflection, a greater lateral pressure could be used in shoring design. If greater than anticipated deflection occurs during construction, additional bracing or tiebacks may be necessary to minimize deflection of existing adjacent improvements.

Settlement of structures or facilities founded adjacent to the shoring will occur in proportion to both the distance between the shoring and the facilities, and the amount of horizontal deflection of the shoring system. The vertical settlement will be a maximum at the shoring face and decrease as the horizontal distance from the shoring increases. Beyond a distance from the shoring equal to the height of the shoring, the settlement is expected to be negligible. The maximum vertical settlement is expected to be about 75 percent of the maximum horizontal deflection on top of the shoring system. The geotechnical engineer should review the shoring design to ensure that the recommendations provided herein are properly incorporated into the design.

#### **6.11.7. Monitoring**

For excavations in close proximity to existing improvements, some means of monitoring the performance of the shoring system is recommended. Monitoring should consist of periodic surveying of lateral and vertical locations at the tops of all soldier piles. The geotechnical engineer should review the results of the monitoring during construction.

### **6.12. Pavement Recommendations**

Pavement section should be constructed on top of properly prepared subgrade in accordance with Section 6.4 of this report and aggregate base (AB) section compacted to 95 percent of the maximum dry density in accordance with ASTM D1557.

We performed laboratory R-value testing for preliminary pavement section design. The test indicates an R value of 9, and it was used in our pavement structural calculations. Sections 6.12.1 and 6.12.2 present our recommendations for preliminary design of flexible and rigid pavement sections, respectively. Final pavement design should be based on field observations, additional R-value tests during construction should the materials exposed differ than what is expected based on our field exploration, and the anticipated traffic index as determined by the project civil engineer.

### 6.12.1. Flexible Pavement Design

Our flexible pavement structural design is in accordance with Chapter 630 of the Caltrans Highway Design Manual, which is based on a relationship between the gravel equivalent (GE) of the pavement structural materials, the traffic index (TI), and the R-value of the underlying subgrade soil. For preliminary design of flexible pavement section, Table 11 provides recommended minimum thicknesses for hot mix asphalt (HMA) and aggregate base sections for different traffic indices.

**Table 11 – Recommended Minimum HMA and Base Section Thicknesses**

Traffic Index	5.0	6.0	7.0
HMA Thickness (in)	4	5	6
Aggregate Base Thickness (in)	7	9	12

### 6.12.2. Rigid Pavement Design

For preliminary design of rigid pavement section, Table 12 provides recommended minimum thicknesses for Portland cement concrete (PCC) pavement section and Class 2 Aggregate Base (AB) section for different traffic indices. The recommended values are based on a minimum 28-day concrete compressive strength of 3,500 psi. Positive drainage should be provided away from all pavement areas to prevent seepage of surface and/or subsurface water into the pavement base and/or subgrade.

**Table 12 – Recommended Minimum Rigid Pavement Thicknesses**

Traffic Index	5.0	6.0	7.0
PCC Thickness (in)	6	6.5	7.0
Aggregate Base Thickness (in)	6	6	6

### 6.13. Stormwater Infiltration Facility

Percolation testing will be required based on the actual location and depth of the planned system. The design of stormwater infiltration facility should be based on percolation test results with an appropriate factor of safety.

Our percolation test results may be used in preliminary design. Details of the percolation tests are presented in Appendix A. Infiltration rates with a factor of safety of 3 from our percolation tests are summarized in Table 13.

Any proposed infiltration facility should have a minimum setback from property lines and foundations recommended in Table 14. In addition, the bottom of the infiltration facility should be at least 10 feet above the seasonal high groundwater. We recommend that we review the proposed groundwater infiltration system prior to implementation or finalizing design.

**Table 13 – Infiltration Rate with a Factor of Safety of 3**

Test Location	Depth of Test Borehole (feet)	Infiltration Rate (inch/hour)
P-3	6	0.7
P-4	6	0.8
P-5	6	0.5

**Table 14 – Recommended Minimum Infiltration Facility Setback**

Setback from	Distance
Property lines & public right of way	5 feet
Foundations	the greater of 15 feet or a 1:1 plane drawn up from the bottom of foundation
Seasonal high groundwater	10 feet minimum depth from invert of infiltration device
Face of slope	the greater of 5 feet or one half of the slope height
Water wells	100 feet

#### 6.14. Drainage Control

The control of surface water is essential to the satisfactory performance of proposed structures and site improvements. Surface water should be controlled so that conditions of uniform moisture are maintained beneath the improvements, even during periods of heavy rainfall. The following recommendations are considered minimal:

- Ponding and areas of low flow gradients should be avoided.
- If bare soil within 5 feet of the structure is not avoidable, then a gradient of 5 percent or more should be provided sloping away from the improvement. Corresponding paved surfaces should be provided with a gradient of at least 1 percent.
- The remainder of the unpaved areas should be provided with a drainage gradient of at least 2 percent.
- Positive drainage devices, such as graded swales, paved ditches, and/or catch basins should be employed to accumulate and to convey water to appropriate discharge points.
- Concrete walks and flatwork should not obstruct the free flow of surface water.
- Brick flatwork should be sealed by mortar or be placed over an impermeable membrane.
- Area drains should be recessed below grade to allow free flow of water into the basin.

- Enclosed raised planters should be sealed at the bottom and provided with an ample flow gradient to a drainage device. Recessed planters and landscaped areas should be provided with area inlet and subsurface drain pipes.
- Planters should not be located adjacent to the structures wherever possible. If planters are to be located adjacent to the structures, the planters should be positively sealed, should incorporate a subdrain, and should be provided with free discharge capacity to a drainage device.
- Planting areas at grade should be provided with positive drainage. Wherever possible, the grade of exposed soil areas should be established above adjacent paved grades. Drainage devices and curbing should be provided to prevent runoff from adjacent pavement or walks into planted areas.
- Gutter and downspout systems should be provided to capture discharge from roof areas. The accumulated roof water should be conveyed to off-site disposal areas by a pipe or concrete swale system.

Landscape watering should be performed judiciously to preclude either soaking or desiccation of soils. The watering should be such that it just sustains plant growth without excessive watering. Sprinkler systems should be checked periodically to detect leakage and they should be turned off during the rainy season.



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

## **7. DESIGN REVIEW AND CONSTRUCTION MONITORING**

Geotechnical review of plans and specifications is of paramount importance in engineering practice. The poor performance of many structures has been attributed to inadequate geotechnical review of construction documents. Additionally, observation and testing of the subgrade will be important to the performance of the proposed development. The following sections present our recommendations relative to the review of construction documents and the monitoring of construction activities.

### **7.1. Plans and Specifications**

The design plans and specifications should be reviewed by Twining, Inc. prior to bidding and construction, as the geotechnical recommendations may need to be reevaluated in the light of the actual design configuration and loads. This review is necessary to evaluate whether the recommendations contained in this report and future reports have been properly incorporated into the project plans and specifications. Based on the work already performed, this office is best qualified to provide such review.

### **7.2. Preconstruction Surveys**

We recommend that preconstruction surveys be performed on the adjacent improvements prior to commencement of excavation activities for the subject project. The surveys should include written and photographic (or videographic) documentation of the existing conditions, as well as performance of floor level surveys or establishment of elevation monuments. Documentation of other structures and sensitive instruments within approximately 50 feet of the excavation(s) should also be performed.

### **7.3. Construction Monitoring**

Site preparation, removal of unsuitable soils, assessment of imported fill materials, fill placement, foundation installation, and other site grading operations should be observed and tested, as appropriate. The substrata exposed during the construction may differ from that encountered in the test excavations. Continuous observation by a representative of Twining, Inc. during construction allows for evaluation of the soil conditions as they are encountered and allows the opportunity to recommend appropriate revisions where necessary.



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

## 8. LIMITATIONS

The recommendations and opinions expressed in this report are based on Twining, Inc.'s review of available background documents, on information obtained from field explorations, and on laboratory testing. It should be noted that this study did not evaluate the possible presence of hazardous materials on any portion of the site. In the event that any of our recommendations conflict with recommendations provided by other design professionals, we should be contacted to aid in resolving the discrepancy.

Due to the limited nature of our field explorations, conditions not observed and described in this report may be present on the site. Uncertainties relative to subsurface conditions can be reduced through additional subsurface exploration. Additional subsurface evaluation and laboratory testing can be performed upon request. It should be understood that conditions different from those anticipated in this report may be encountered during grading operations, for example, the extent of removal of unsuitable soil, and that additional effort may be required to mitigate them.

Site conditions, including groundwater elevation, can change with time as a result of natural processes or the activities of man at the subject site or at nearby sites. Changes to the applicable laws, regulations, codes, and standards of practice may occur as a result of government action or the broadening of knowledge. The findings of this report may, therefore, be invalidated over time, in part or in whole, by changes over which Twining, Inc. has no control.

Twining's recommendations for this site are, to a high degree, dependent upon appropriate quality control of subgrade preparation, fill placement, and foundation construction. Accordingly, the recommendations are made contingent upon the opportunity for Twining to observe grading operations and foundation excavations for the proposed construction. If parties other than Twining are engaged to provide such services, such parties must be notified that they will be required to assume complete responsibility as the geotechnical engineer of record for the geotechnical phase of the project by concurring with the recommendations in this report and/or by providing alternative recommendations.

This document is intended to be used only in its entirety. No portion of the document, by itself, is designed to completely represent any aspect of the project described herein. Twining should be contacted if the reader requires additional information or has questions regarding the content, interpretations presented, or completeness of this document.

This report has been prepared for the exclusive use by the client and its agents for specific application to the proposed project. Land use, site conditions, or other factors may change over time, and additional work may be required with the passage of time. Based on the intended use of this report and the nature of the new project, Twining may require that additional work be performed and that an updated report be issued. Non-compliance with any of these requirements by the Client or anyone else will release Twining from any liability resulting from the use of this report by any unauthorized party.

Twining performed its evaluation using the degree of care and skill ordinarily exercised under similar circumstances by reputable geotechnical professionals with experience in this area in similar soil conditions. No other warranty, either express or implied, is made as to the conclusions and recommendations contained in this report.

## 9. SELECTED REFERENCES

- Abrahamson, N.A., Silva, W.J., and Kamai, R., 2014, Summary of the ASK14 Ground Motion Relation for Active Crustal Regions. *Earthquake Spectra*: August 2014, Vol. 30, No. 3, pp. 1025-1055.
- American Society of Civil Engineers, 2016, Minimum Design Loads and Associated Criteria for Buildings and Other Structures: ASCE Standard ASCE/SEI 7-16, 800 pp, ISBN 9780784414248.
- ASTM, current latest version, "Soil and Rock: American Society for Testing and Materials," vol. 4.08 for ASTM test methods D-420 to D-4914; and vol. 4.09 for ASTM test methods D-4943 to highest number.
- Boore, D.M., Stewart, J.P., Seyhan, Emel, and Atkinson, G.A., 2014, NGA-West2 equations for predicting response spectral accelerations for shallow crustal earthquakes. *Earthquake Spectra*: August 2014, Vol. 30, No. 3, pp. 1057-1085.
- Boulanger, R.W. and Idriss, I. M., 2014. CPT and SPT Based Liquefaction Triggering Procedures. Department of Civil & Environmental Engineering, College of Engineering, University of California at Davis.
- California Buildings Standards Commission, 2019, California Building Code, California Code of Regulations, Title 24, Volume 2 of Part 2, Effective January 1, 2020, ISBN 978-1-60983-891-1.
- California Geological Survey (CGS), 2012, Geologic Compilation of Quaternary Surficial Deposits in Southern California, Santa Ana 30x60 Quadrangle (REVISED), CGS Special Report 217, Plate 16 1:100,000 Scale.
- California Geological Survey (CGS), 2019, Note 48, Checklist for the Review of Engineering Geology and Seismology Reports for California Public Schools, Hospitals, and Essential Services Buildings, October.
- California Geological Survey (CGS), 2016, Earthquake Zones of Required Investigation, Corona South Quadrangle, Seismic Hazards Zones Official Map, scale 1:24,000, released May 1, 2003.
- Campbell, K.W., and Bozorgnia, Yousef, 2014, Campbell-Bozorgnia NGA-West2 ground motion model for the average horizontal components of PGA, PGV, and 5%-damped linear response spectra. *Earthquake Spectra*: August 2014, Vol. 30, No. 3, pp. 1087-1115.
- Chiou, B.S.-J., and Youngs, R.R., 2014, Update of the Chiou and Youngs NGA ground motion model for average horizontal component of peak ground motion and response spectra. *Earthquake Spectra*: August 2014, Vol. 30, No. 3, pp. 1117-1153.
- GEOBASE, Inc., 2012, Geotechnical Report, Kaiser Foundation Hospitals, Kaiser Permanente – RMC Generator Upgrade, 10800 Magnolia Avenue, Riverside, California, January 2012, GeoBase Project Number: C.314.49.00.
- Geologismiki, 2019, LiqSVs 2.0 – SPT & Vs Liquefaction Analysis Software, First Release May 16, 2016, Updated May 25, 2019.
- Ishihara, K. and Yoshimine, M., 1992. Evaluation of Settlements in Sand Deposits Following Liquefaction During Earthquakes, *Soils and Foundations*, Japanese Society of Soil Mechanics and Foundation Engineering, Vol. 32, No. 1, March 1992.



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424


- Jennings, C. W. and Bryant, W. A., 2010, Fault Activity Map of California: California Geological Survey, Geologic Data Map Series, Map No. 6, Scale 1 : 750,000.
- Kayen, R. E. S. Moss, E. M. Thompson, R. B. Seed, K. O. Cetin, A. Der Kiureghian, Y. Tanaka, K. Tokimatsu, 2013. Shear-Wave Velocity–Based Probabilistic and Deterministic Assessment of Seismic Soil Liquefaction Potential, *Journal of Geotechnical and Geoenvironmental Engineering*, Vol. 139, No. 3, March 1.
- Metropolitan Water District of Southern California (MWDSC), 2007, Final Groundwater Assessment Study, A Status Report on the Use of Groundwater in the Service Area of the Metropolitan Water District of Southern California, Report Number 1308, September 2007.
- Miller, R. V., Tan, S. S., 1976, *Geology and Engineering Aspects of the South Half Riverside West Quadrangle*, Orange County, California, CDMG Special Report 126.
- Morton, D.M., and Cox, B. F., 2001, *Geologic map of the Riverside West 7.5' quadrangle*, Riverside County, California. U.S. Geological Survey, Open-File Report OF-01-451, scale 1:24,000.
- National Association of Corrosion Engineers (NACE), 1984, *Corrosion Basics, an Introduction*.
- Petersen, M.D., Moschetti, M.P., Powers, P.M., Mueller, C.S., Haller, K.M., Frankel, A.D., Zeng, Yuehua, Rezaeian, Sanaz, Harmsen, S.C., Boyd, O.S., Field, Ned, Chen, Rui, Rukstales, K.S., Luco, Nico, Wheeler, R.L., Williams, R.A., and Olsen, A.H., 2014, Documentation for the 2014 update of the United States national seismic hazard maps: U.S. Geological Survey Open-File Report 2014–1091, 243 p., <https://dx.doi.org/10.3133/ofr20141091>. <https://pubs.usgs.gov/of/2014/1091/pdf/ofr2014-1091.pdf>
- Pradel, D., 1998, Procedure to Evaluate Earthquake-Induced Settlements in Dry Sandy Soils, *ASCE, Journal of Geotechnical & Geoenvironmental Engineering*, Vol. 124, No. 4, 364-368
- Romanoff, Melvin, 1989, *Underground Corrosion*, NBS Circular 579. Reprinted by NACE. Houston, TX, pp. 166–167.
- Seed, R. B., Cetin, K. O., Moss, R. E. S., Kammerer, A. M., Wu, J., Pestana, J. M., Riemer, M. F., Sancio, R. B., Bray, J. D., Kayen, R. E., and Faris, A. (2003). "Recent Advances in Soil Liquefaction Engineering: A Unified and Consistent Framework." EERC Report No. 2003-06.
- U.S. Geological Survey (USGS), 2013, *Modeling for the SAFRR Tsunami Scenario—Generation, Propagation, Inundation, and Currents in Ports and Harbors by the SAFRR Tsunami Modeling Working Group*. USGS Open-File Report 2013–1170–D, California Geological Survey Special Report 229
- U.S. Geological Survey, 2018, *USGS 1:24000-scale Riverside West Quadrangle, California – Orange County 7.5-Minute Series*.
- Western Municipal Water District (WMWD), 2012, *Arlington Basin Groundwater Management Plan*, September 2012.



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

## FIGURES



SCALE IN FEET



REFERENCE: USGS (2018)



**TWINING**


**SITE LOCATION MAP**

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE 1



284 STD

MAGNOLIA AVENUE

183 STD

EXISTING PS  
662 STD

178 STD  
15 ADA  
2 VAN

92 STD  
6 ADA  
2 VAN

1,106 STD  
45 ADA

PARK SIERRA DRIVE

251 STD  
42 ADA  
13 VAN

134 STD  
39 ADA  
11 VAN

**LEGEND**

**B-1**  
TD=51.5'  
◆ APPROXIMATE LOCATION OF BORING BY TWINING  
TOTAL DEPTH IN FEET

**P-1**  
TD=6'  
▲ APPROXIMATE LOCATION OF PERCOLATION TEST BY TWINING  
TOTAL DEPTH IN FEET

A A'  
— GEOLOGIC CROSS SECTION

Qof GEOLOGIC UNIT

— APPROXIMATE LOCATION OF PROPERTY LINE

REFERENCE: CO ARCHITECTS (2021)

0 150' 300'

NOTE: ALL DIMENSIONS AND LOCATIONS ARE APPROXIMATE



**TWINING**



**SITE PLAN AND BORING LOCATION MAP**

PROPOSED HOSPITAL TOWER  
KAISER RIVERSIDE MEDICAL CENTER  
10800 MAGNOLIA AVENUE  
RIVERSIDE, CALIFORNIA

PROJECT No.  
190919.3

REPORT DATE  
July 2021

FIGURE 2



**LEGEND**

- Qof Old Alluvial Fan Deposits
- Qyf Young Alluvial Fan Deposits
- gr Granitic and other intrusive rocks of all ages
- Qss Coarse-grained formations - sandstone and conglomerate
- Kv Cretaceous age formations of volcanic origin
- Groundwater monitoring wells

REFERENCE: BEDROSSIAN AND ROFFERS (2012)

**REGIONAL GEOLOGIC MAP**

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
KAISER RIVERSIDE MEDICAL CENTER  
10800 MAGNOLIA AVENUE  
RIVERSIDE, CALIFORNIA


PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE 3




SE ↘



**LEGEND**



NOTE: All dimensions, locations, and directions are approximate.



EXISTING GRADE

APPROXIMATE LOCATION OF EXPLORATORY BORING OR CPT  
TD = TERMINATION DEPTH IN FEET

GEOLOGIC CONTACT  
(DASHED WHERE APPROXIMATELY LOCATED)


APPROXIMATE GROUNDWATER TABLE

Qof OLD ALLUVIAL FAN DEPOSITS



<b>GEOLOGIC CROSS SECTION A-A'</b>		
PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025 KAISER RIVERSIDE MEDICAL CENTER 10800 MAGNOLIA AVENUE RIVERSIDE, CALIFORNIA		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE 4A


NE ↘



**LEGEND**



NOTE: All dimensions, locations, and directions are approximate.




EXISTING GRADE  
 APPROXIMATE LOCATION OF EXPLORATORY BORING OR CPT  
 TD = TERMINATION DEPTH IN FEET  
 GEOLOGIC CONTACT (DASHED WHERE APPROXIMATELY LOCATED)  
 APPROXIMATE GROUNDWATER TABLE

Qof OLD ALLUVIAL FAN DEPOSITS



<b>GEOLOGIC CROSS SECTION B-B'</b>		
PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025 KAISER RIVERSIDE MEDICAL CENTER 10800 MAGNOLIA AVENUE RIVERSIDE, CALIFORNIA		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE 4B


SE ↘



**LEGEND**



NOTE: All dimensions, locations, and directions are approximate.




EXISTING GRADE  
 APPROXIMATE LOCATION OF EXPLORATORY BORING OR CPT  
 TD = TERMINATION DEPTH IN FEET  
 GEOLOGIC CONTACT (DASHED WHERE APPROXIMATELY LOCATED)  
 APPROXIMATE GROUNDWATER TABLE

Af ARTIFICIAL FILL  
 Qof OLD ALLUVIAL FAN DEPOSITS



<b>GEOLOGIC CROSS SECTION C-C'</b>		
PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025 KAISER RIVERSIDE MEDICAL CENTER 10800 MAGNOLIA AVENUE RIVERSIDE, CALIFORNIA		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE 4C


NE ↘





**LEGEND**




NOTE: All dimensions, locations, and directions are approximate.

-  EXISTING GRADE
-  APPROXIMATE LOCATION OF EXPLORATORY BORING OR CPT  
TD = TERMINATION DEPTH IN FEET
-  GEOLOGIC CONTACT (DASHED WHERE APPROXIMATELY LOCATED)
-  APPROXIMATE GROUNDWATER TABLE

-  ARTIFICIAL FILL
-  OLD ALLUVIAL FAN DEPOSITS




<b>GEOLOGIC CROSS SECTION D-D'</b>		
PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025 KAISER RIVERSIDE MEDICAL CENTER 10800 MAGNOLIA AVENUE RIVERSIDE, CALIFORNIA		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE 4D



**WATER LEVELS IN WELLS ADJACENT TO THE SITE**  
 PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA

PROJECT NO. 190191.3	DATE March 2021	FIGURE 5
-------------------------	--------------------	----------



CGS Map Sheet 48: Historic Earthquakes, 1769 to 2015 - California (Magnitude 5.0-plus)

Historic Earthquakes, 1769-2015 - California (Magnitude 5.0 Plus)

- 7+
- 6-7
- 5-6




### HISTORICAL EARTHQUAKE EPICENTER MAP

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA

PROJECT NO.  
190919.3

REPORT DATE  
March 2021


FIGURE 6




**MAP EXPLANATION**

**EARTHQUAKE FAULT ZONES**

**Earthquake Fault Zones**  
 Zone boundaries are delineated by straight-line segments; the boundaries define the zone encompassing active faults that constitute a potential hazard to structures from surface faulting or fault creep such that avoidance as described in Public Resources Code Section 2621.5(a) would be required.



**Active Fault Traces**  
 Faults considered to have been active during Holocene time and to have potential for surface rupture: Solid Line in Black or Red where Accurately Located; Long Dash in Black or Solid Line in Purple where Approximately Located; Short Dash in Black or Solid Line in Orange where Inferred; Dotted Line in Black or Solid Line in Rose where Concealed; Query (?) indicates additional uncertainty. Evidence of historic offset indicated by year of earthquake-associated event or C for displacement caused by fault creep.




**SEISMIC HAZARD ZONES**

**Liquefaction Zones**  
 Areas where historical occurrence of liquefaction, or local geological, geotechnical and ground water conditions indicate a potential for permanent ground displacements such that mitigation as defined in Public Resources Code Section 2693(c) would be required.



**Earthquake-Induced Landslide Zones**  
 Areas where previous occurrence of landslide movement, or local topographic, geological, geotechnical and subsurface water conditions indicate a potential for permanent ground displacements such that mitigation as defined in Public Resources Code Section 2693(c) would be required.





**SEISMIC HAZARD ZONES MAP**

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE 7



- - - - - FAULT ALONG WHICH HISTORIC DISPLACEMENT HAS OCCURRED
- HOLOCENE FAULT DISPLACEMENT
- - - - - LATE QUATERNARY FAULT DISPLACEMENT
- - - - - QUATERNARY FAULT DISPLACEMENT
- - - - - PRE-QUATERNARY FAULT DISPLACEMENT




REFERENCE: JENNINGS AND BRYANT (2010)

**REGIONAL FAULT MAP**

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE 8
-------------------------	---------------------------	----------





- LEGEND**
- VERY LOW
  - LOW
  - MODERATE
  - HIGH
  - VERY HIGH
  - RIVERSIDE CITY BOUNDARY
  - RIVERSIDE PROPOSED SPHERE OF INFLUENCE



APPROXIMATE SCALE IN MILES



**TWINING**


**LIQUEFACTION ZONES MAP**

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE 9



**LEGEND**

**FLOOD HAZARD AREAS**

-  1% ANNUAL CHANCE OF FLOOD
-  0.2% ANNUAL CHANCE OF FLOOD
-  DEPARTMENT OF WATER RESOURCES AWARENESS FLOODPLAIN

**DAM INUNDATION AREAS**

-  SYCAMORE CANYON DAM
-  BOX SPRINGS DAM
-  PRENDA DAM
-  WOODCREST DAM
-  MARY ST DAM
-  ALESSANDRO DAM

-  LAKE MATHEWS DAM (FORMERLY CAJALCO DAM)
-  HARRISON DAM
-  MOCKINGBIRD CANYON DAM
-  FAIRMOUNT DAM

-  RIVERSIDE CITY LIMITS
-  RIVERSIDE SPHERE OF INFLUENCE



APPROXIMATE SCALE IN MILES



**TWINING**



**DAM INUNDATION AREAS MAP**

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA

PROJECT NO.  
190919.3


REPORT DATE  
March 2021

FIGURE 10



<b>FEMA FLOOD MAP</b>		
PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025 KAISER RIVERSIDE MEDICAL CENTER 10800 MAGNOLIA AVENUE RIVERSIDE, CALIFORNIA		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE 11

DEPTH BELOW EXISTING GROUND SURFACE (feet)	SHEAR-WAVE VELOCITY, $V_s$	
	(feet/second)	(meters/second)
0	652.4	198.9
10.23	652.4	198.9
10.23	1000.9	305.1
16.6	1000.9	305.1
16.6	953.8	290.7
24.08	953.8	290.7
24.08	939.9	286.5
33.86	939.9	286.5
33.86	1067.6	325.4
45.56	1067.6	325.4
45.56	1386.4	422.6
60.88	1386.4	422.6
60.88	1372.1	418.2
77.62	1372.1	418.2
77.62	1720.6	524.4
100	1720.6	524.4



**MEASURED SHEAR-WAVE VELOCITY PROFILE**

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA


PROJECT NO.  
190191.3

DATE  
March 2021

FIGURE 12

PERIOD (seconds)	SITE-SPECIFIC DESIGN SPECTRAL ACCELERATION Sa, (g)
0.01	0.431
0.02	0.433
0.03	0.449
0.05	0.513
0.075	0.623
0.1	0.723
0.133	0.825
0.15	0.876
0.194	0.960
0.2	0.971
0.25	1.036
0.3	1.111

PERIOD (seconds)	SITE-SPECIFIC DESIGN SPECTRAL ACCELERATION Sa, (g)
0.4	1.165
0.5	1.174
0.667	1.016
0.75	0.938
0.9	0.834
0.97	0.800
1	0.776
1.5	0.517
2	0.388
3	0.259
4	0.194
5	0.155



Note: See Table 6 of the report for ordinates of the various curves.



**SITE-SPECIFIC DESIGN RESPONSE SPECTRUM**

PROPOSED HOSPITAL EXPANSION, OSHPD: 106334025  
 KAISER RIVERSIDE MEDICAL CENTER  
 10800 MAGNOLIA AVENUE  
 RIVERSIDE, CALIFORNIA

PROJECT NO.  
190191.3

DATE  
March 2021

FIGURE 13



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

# **APPENDIX A FIELD EXPLORATION**



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

## **Appendix A Field Exploration**

### **General**

The field exploration was conducted between November 2, 2019 and March 13, 2021 and consisted of drilling, testing, sampling, and logging 13 exploratory hollow-stem-auger (HSA) borings (B-1 through B-13) for the tower, 2 HSA borings for the generator pad (GP-1 and GP-2), and 2 HSA borings for the propane tank (PT-1 and PT-2). The field exploration also included 3 hand-auger borings (P-3 through P-5) for percolation testing for the tower site.

The HSA borings were advanced to approximate depths of 31.5 to 91.5 feet below ground surface (bgs) for the tower, approximately 51.5 feet bgs for the generator pad, and approximately 21.5 feet bgs for the propane tank. Drilling operation for the HSA borings was performed by 2R drilling of Chino, California using a RAM 5500 and a CME-75 truck-mounted drill rigs equipped with 8-inch diameter hollow-stem-augers. Borings P-3 through P-5 were advanced to a depth of approximately 6 feet bgs using a 5-inch diameter hand auger.

The approximate locations of the borings are shown on Figure 2.

### **Drilling and Sampling**

An explanation of the boring logs is presented as Figure A-1. The boring logs are presented as Figures A-2 through A-21. The boring logs describe the earth materials encountered, samples obtained, and show the field and laboratory tests performed. The logs also show the boring number, drilling date, and the name of the logger and drilling subcontractor. The borings were logged by an engineer using the Unified Soil Classification System under the supervision of a registered California Geotechnical Engineer. The boundaries between soil types shown on the logs are approximate because the transition between different soil layers may be gradual. Drive and bulk samples of representative earth materials were obtained from the borings.

Disturbed samples were obtained from select depths using a Standard Penetration Test (SPT) sampler. This sampler consists of a 2-inch O.D., 1.4-inch I.D. split barrel shaft with room for liner but liner was not used. Soil samples obtained by the SPT sampler were retained in plastic bags. A California modified sampler was also used to obtain drive samples of the soils from select depths. This sampler consists of a 3-inch outside diameter (O.D.), 2.4-inch inside diameter (I.D.) split barrel shaft. The samples were retained in brass rings for laboratory testing.

When the boring was drilled to a select depth, the sampler was lowered to the bottom of the boring and then driven a total of 18-inches into the soil using an automatic hammer weighing 140 pounds dropped from a height of 30 inches. The number of blows required to drive the samplers the final 12 inches is presented on the boring logs.

Groundwater was encountered at approximately 57.5 feet bgs in boring B-5. Upon completion of the borings or percolation testing, the boreholes were backfilled with drilled soil cuttings, and the surface was repaired to match existing conditions.

### **Percolation Testing**

Percolation testing was performed on February 12 and 13, 2020 in the hand auger borings (P-3 through P-5) in accordance with the procedures of the Riverside County Design Handbook for Low Impact Development Best Management Practices. After installing pipe and filter rock, the



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

boreholes were filled with water to approximately one foot bgs and presoaked for two consecutive 25-minute sessions prior to testing. At the end of each presoak session, more than 6 inches of water level drop was observed in the borings.

After presoaking, the boreholes were filled with water again, and measurements were recorded. The last reading was used to determine the percolation rate at each test location.

Our calculated infiltration rates with a factor safety of 3 are presented in Table A-1 below. Detailed test data is attached at the end of this appendix.

**Table A-1 – Infiltration Rate with a Factor of Safety of 3**

Test Location	Depth of Test Borehole (feet)	Infiltration Rate (inch/hour)
P-3	6	0.7
P-4	6	0.8
P-5	6	0.5

## UNIFIED SOIL CLASSIFICATION CHART

MAJOR DIVISIONS			SYMBOLS		TYPICAL DESCRIPTIONS
			GRAPH	LETTER	
<b>COARSE GRAINED SOILS</b>  <small>MORE THAN 50% OF MATERIAL IS LARGER THAN NO. 200 SIEVE SIZE</small>	<b>GRAVEL AND GRAVELLY SOILS</b>  <small>MORE THAN 50% OF COARSE FRACTION RETAINED ON NO. 4 SIEVE</small>	<b>CLEAN GRAVELS</b>  <small>(LITTLE OR NO FINES)</small>		<b>GW</b>	WELL-GRADED GRAVELS, GRAVEL - SAND MIXTURES, LITTLE OR NO FINES
		<b>GRAVELS WITH FINES</b>  <small>(APPRECIABLE AMOUNT OF FINES)</small>		<b>GP</b>	POORLY-GRADED GRAVELS, GRAVEL - SAND MIXTURES, LITTLE OR NO FINES
		<b>GRAVELS WITH FINES</b>  <small>(APPRECIABLE AMOUNT OF FINES)</small>		<b>GM</b>	SILTY GRAVELS, GRAVEL - SAND - SILT MIXTURES
		<b>GRAVELS WITH FINES</b>  <small>(APPRECIABLE AMOUNT OF FINES)</small>		<b>GC</b>	CLAYEY GRAVELS, GRAVEL - SAND - CLAY MIXTURES
	<b>SAND AND SANDY SOILS</b>  <small>MORE THAN 50% OF COARSE FRACTION PASSING ON NO. 4 SIEVE</small>	<b>CLEAN SANDS</b>  <small>(LITTLE OR NO FINES)</small>		<b>SW</b>	WELL-GRADED SANDS, GRAVELLY SANDS, LITTLE OR NO FINES
		<b>CLEAN SANDS</b>  <small>(LITTLE OR NO FINES)</small>		<b>SP</b>	POORLY-GRADED SANDS, GRAVELLY SAND, LITTLE OR NO FINES
		<b>SANDS WITH FINES</b>  <small>(APPRECIABLE AMOUNT OF FINES)</small>		<b>SM</b>	SILTY SANDS, SAND - SILT MIXTURES
		<b>SANDS WITH FINES</b>  <small>(APPRECIABLE AMOUNT OF FINES)</small>		<b>SC</b>	CLAYEY SANDS, SAND - CLAY MIXTURES
<b>FINE GRAINED SOILS</b>  <small>MORE THAN 50% OF MATERIAL IS SMALLER THAN NO. 200 SIEVE SIZE</small>	<b>SILTS AND CLAYS</b>  LIQUID LIMIT LESS THAN 50		<b>ML</b>	INORGANIC SILTS AND VERY FINE SANDS, ROCK FLOUR, SILTY OR CLAYEY FINE SANDS OR CLAYEY SILTS WITH SLIGHT PLASTICITY	
			<b>CL</b>	INORGANIC CLAYS OF LOW TO MEDIUM PLASTICITY, GRAVELLY CLAYS, SANDY CLAYS, SILTY CLAYS, LEAN CLAYS	
			<b>OL</b>	ORGANIC SILTS AND ORGANIC SILTY CLAYS OF LOW PLASTICITY	
	<b>SILTS AND CLAYS</b>  LIQUID LIMIT GREATER THAN 50		<b>MH</b>	INORGANIC SILTS, MICACEOUS OR DIATOMACEOUS FINE SAND OR SILTY SOILS	
			<b>CH</b>	INORGANIC CLAYS OF HIGH PLASTICITY	
			<b>OH</b>	ORGANIC CLAYS OF MEDIUM TO HIGH PLASTICITY, ORGANIC SILTS	
<b>HIGHLY ORGANIC SOILS</b>				<b>PT</b>	PEAT, HUMUS, SWAMP SOILS WITH HIGH ORGANIC CONTENTS

NOTE: DUAL SYMBOLS ARE USED TO INDICATE BORDERLINE SOIL CLASSIFICATIONS

### COARSE-GRAINED SOILS

### FINE-GRAINED SOILS

Relative Density	SPT (blows/ft)	Relative Density (%)	Consistency	SPT (blows/ft)
Very Loose	<4	0 - 15	Very Soft	<2
Loose	4 - 10	15 - 35	Soft	2 - 4
Medium Dense	10 - 30	35 - 65	Medium Stiff	4 - 8
Dense	30 - 50	65 - 85	Stiff	8 - 15
Very Dense	>50	85 - 100	Very Stiff	15 - 30
			Hard	>30

NOTE: SPT blow counts based on 140 lb. hammer falling 30 inches

### LABORATORY TESTING ABBREVIATIONS

ATT	Atterberg Limits
C	Consolidation
CORR	Corrosivity Series
DS	Direct Shear
EI	Expansion Index
GS	Grain Size Distribution
K	Permeability
MAX	Moisture/Density (Modified Proctor)
O	Organic Content
RV	Resistance Value
SE	Sand Equivalent
SG	Specific Gravity
TX	Triaxial Compression
UC	Unconfined Compression

Sample Symbol	Sample Type	Description
	SPT	1.4 in. I.D., 2.0 in. O.D. driven sampler
	California Modified	2.4 in. I.D., 3.0 in. O.D. driven sampler
	Bulk	Retrieved from soil cuttings
	Thin-Walled Tube	Pitcher or Shelby Tube



# TWINING

### EXPLANATION FOR LOG OF BORINGS

Proposed Hospital Expansion, OSHPD: 106334025  
Kaiser Permanente Riverside Medical Center  
Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A-1

DATE DRILLED 11/9/19 LOGGED BY DHC **BORING NO.** B-1  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										6 inches of Portland cement concrete over 5 inches of base
									CL	Sandy lean CLAY; reddish brown; slightly moist
718	5			23	11.9	121.8			CL	-- same; stiff
713	10			16					CL	-- same; stiff
708	15			50	11.7	124.6			CL	-- same; hard
703	20			13			#200, ATT		ML	Sandy SILT; stiff; grey; slightly moist
698	25			31	17.3	114.0			ML	-- same; very stiff
693	30			9					CL	Sandy lean CLAY; stiff; brown; slightly moist
688	35									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 2
-------------------------	---------------------------	--------------

DATE DRILLED 11/9/19 LOGGED BY DHC **BORING NO.** B-1  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
				25	22.5	98.2			CL CL	Sandy lean CLAY; stiff, brown; slightly moist <i>(continued)</i> -- same; very stiff
683	40			13					CL	-- same; stiff; light brown with orange oxidation staining
678	45			70	2.8	107.1			SM	Silty SAND; dense; light brown with some orange grains; slightly moist
673	50			25					SM	-- same; medium dense
668	55	Total Depth = 51.5 feet Backfilled on 11/9/2019 Groundwater not encountered. Borehole filled with cuttings at completion. Surface patched with PCC.								
663	60									
658	65									
653	70									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 2

DATE DRILLED 11/9/19 LOGGED BY DHC **BORING NO.** B-2  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										5 inches of Portland cement concrete over 6 inches of base
									CL	Sandy lean CLAY; reddish brown; slightly moist
718	5			5			#200		CL	-- same; medium stiff
713	10			81	9.7	126.8			CL	-- same; hard; brown
708	15			34					ML	Sandy SILT; hard; greyish brown; slightly moist
703	20			54	20.2	100.4	DS		ML	-- same; hard
698	25			32					SM	Silty SAND; dense; light brown; slightly moist
693	30			28	23.1	103.1			CL	Sandy lean CLAY; very stiff; brown; slightly moist
688	35									Total Depth = 31.5 feet Backfilled on 11/9/2019 Groundwater not encountered. Borehole filled with cuttings at completion.

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 3

DATE DRILLED 11/2/19 LOGGED BY DHC **BORING NO.** B-3  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										8 inches of asphalt concrete over 6 inches of base
718	5			16	9.7	100.3			CL	Sandy lean CLAY; reddish brown; slightly moist; mostly fine sand
									CL	-- same; stiff
713	10			26			#200, ATT		CL	Lean CLAY with sand; very stiff; light brown
708	15			48	3.1	117.9	C, DS		CL	-- same; hard
703	20			40			GS		SW-SM	Well graded SAND with silt; dense; light brown; slightly moist
698	25			48	2.5	104.3			CL	Sandy lean CLAY; hard; light brown; slightly moist
693	30			26			#200, ATT		CL	-- same; very stiff
688	35									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 4
-------------------------	---------------------------	--------------

DATE DRILLED 11/2/19 LOGGED BY DHC **BORING NO.** B-3  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
				32/50 for 6"	15.5	104.8			SM	Silty SAND; very dense; light brown; slightly moist
683	40			38					SM	-- same; dense; light brown with some red; fine sand
678	45			65	9.1	104.0			SM	-- same; dense; with some oxidation staining
673	50			21			#200, ATT		ML	SILT with sand; stiff; greyish brown; slightly moist
668	55	Total Depth = 51.5 feet Backfilled on 11/2/2019 Groundwater not encountered. Borehole filled with cuttings at completion. Surface patched with cold-patch asphalt.								
663	60									
658	65									
653	70									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 4

DATE DRILLED 11/3/19 LOGGED BY DHC **BORING NO.** B-4  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										4 inches of asphalt concrete over 12 inches of base
718	5			9					CL	Sandy lean CLAY; reddish brown; slightly moist to dry
									CL	-- same; stiff
713	10			50 for 6"	6.6	121.8	#200		CL	Lean CLAY with sand; hard; reddish brown; slightly moist to dry
708	15			24			#200, ATT		CL	Sandy lean CLAY; very stiff; light brown; dry to slightly moist
703	20			52	1.2	101.3	DS		SW	Well graded SAND; very dense; light brown; dry to slightly moist
698	25			25					CL	Sandy lean CLAY; very stiff; brown; slightly moist
693	30			41	13.8	108.6	C		ML	SILT with sand; very stiff; brown; slightly moist
688	35									Total Depth = 31.5 feet Backfilled on 11/3/2019 Groundwater not encountered. Borehole filled with cuttings at completion. Surface patched with cold-patch asphalt.

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 5

DATE DRILLED 12/8/19 LOGGED BY DHC **BORING NO.** B-5  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) 57.5  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										4.5 inches of asphalt concrete over 2 inches of base Sandy lean CLAY; reddish brown; slightly moist
718	5			6					CL	-- same; medium stiff
713	10			20/50 for 6"	14.9	118.5	UC		CL	-- same; hard; brown; with tan mottling; dry to slightly moist
708	15			17					CL	--same; very stiff; light brown with khakhi mottling; slightly moist; some caliche nodules
703	20			51	1.2	113.4	DS		SP-SM	Poorly graded SAND with silt; dense; light brown; dry to slightly moist; with some fine gravel
698	25			14					CL	Lean CLAY with sand; stiff; brown; slightly moist
693	30			55	4.2	122.7			SM	Silty SAND; dense; light brown; slightly moist
688	35									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 6
-------------------------	---------------------------	--------------

DATE DRILLED 12/8/19 LOGGED BY DHC **BORING NO.** B-5  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) 57.5  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
				33					SM SM	Silty SAND; dense; light brown; slightly moist ( <i>continued</i> ) -- same; dense
683	40			24	23.7	97.1			CL	Lean CLAY with sand; very stiff; tan with orange oxidation staining; slightly moist
678	45			38			#200		SP-SM	Poorly graded SAND with silt; dense; light brown; some fine gravel
673	50			50 for 2"	4.4	101.8			SM	Silty SAND; dense; tan with orange oxidation staining; slightly moist
668	55			22					SP-SM	Poorly graded SAND with silt; light brown; some fine gravel; wet
663	60			28/50 for 6"	9.4	128.2			SP	Poorly graded SAND; dense; light brown with brown, black, and red; wet
658	65									
653	70									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 6
-------------------------	---------------------------	--------------

DATE DRILLED 12/8/19 LOGGED BY DHC **BORING NO.** B-5  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) 57.5  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
				15					SM	Silty SAND; medium dense; light brown; wet
648	75									
643	80			50 for 4"						No recovery; dense
638	85									
633	90			43					SM	-- same; dense
628	95									Total Depth = 91.5 feet Backfilled on 12/8/2019 Groundwater encountered at approximately 57.5 feet bgs. Borehole filled with cuttings at completion.
623	100									
618	105									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 6
-------------------------	---------------------------	--------------

DATE DRILLED 11/2/19 LOGGED BY DHC **BORING NO.** B-6  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										5 inches of asphalt concrete over 7 inches of base
									CL	Sandy lean CLAY; reddish brown; slightly moist; fine sand
718	5			11			#200		CL	-- same; stiff
713	10			50	7.9	117.2			CL	-- same; hard
708	15			30			#200		CL	-- same; very stiff; greyish brown; slightly moist; fine sand
703	20			47	7.0	118.9			CL	-- same; hard
698	25			19			#200, ATT		CL	Lean CLAY with sand; very stiff; brown; slightly moist
693	30			69	2.8	102.9			SM	Silty SAND; dense; light brown; slightly moist
688	35									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 7
-------------------------	---------------------------	--------------

DATE DRILLED 11/2/19 LOGGED BY DHC **BORING NO.** B-6  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
				41					SW-SM	Well graded SAND with silt; light brown to red to black; slightly moist
683	40			25	18.0	100.2	#200, ATT, C		CL	Lean CLAY with sand; very stiff; brown; slightly moist
678	45			50					CL	-- same; hard
673	50			50 for 6"					CL	No recovery
668	55	Total Depth = 51.5 feet Backfilled on 11/2/2019 Groundwater not encountered. Borehole filled with cuttings at completion. Surface patched with cold-patch asphalt.								
663	60									
658	65									
653	70									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 7

DATE DRILLED 11/3/19 LOGGED BY DHC **BORING NO.** B-7  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
									CL	7 inches of asphalt concrete with no base Sandy lean CLAY; reddish brown; slightly moist
718	5			27	9.7	119.8			CL	-- same; very stiff
713	10			39			#200, ATT		CL	Lean CLAY with sand; hard; light brown with white streaks; dry to slightly moist
708	15			48	9.9	113.5			CL	-- same; hard
703	20			19					SM	Silty SAND; medium dense; light brown; dry to slightly moist
698	25			26	9.7	118.1			SW-SM	Well graded SAND with silt; medium dense; brown; slightly moist
693	30			11					CL	Sandy lean CLAY; stiff; brown; slightly moist
688	35	Total Depth = 31.5 feet Backfilled on 11/3/2019 Groundwater not encountered. Borehole filled with cuttings at completion. Surface patched with cold-patch asphalt.								

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 8

DATE DRILLED 11/3/19 LOGGED BY DHC **BORING NO.** B-8  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
									CL	Sandy lean CLAY; brown; wet
718	5			5					CL	-- same; medium stiff
713	10			37	14.8	117.9			CL	Lean CLAY with sand; very stiff; reddish brown; moist
708	15			21					CL	Sandy lean CLAY; very stiff; light brown; slightly moist
703	20			26	26.3	94.9	#200, ATT, C		ML	Sandy SILT; very stiff; greyish brown; slightly moist
698	25			15					CL	Sandy lean CLAY; stiff; brown; slightly moist
693	30			32	21.5	103.1	C		CL	-- same; very stiff
688	35									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 9
-------------------------	---------------------------	--------------

DATE DRILLED 11/3/19 LOGGED BY DHC **BORING NO.** B-8  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
				42			#200		SW	Well graded SAND; dense; light brown; slightly moist
683	40			53	13.6	108.1			SW-SM	Well graded SAND with silt; dense; light brown; dry to slightly moist
678	45			41			#200		SW-SM	-- same; dense
673	50			50 for 6"	3.2	102.1			SW-SM	-- same; very dense
668	55	Total Depth = 51.5 feet Backfilled on 11/3/2019 Groundwater not encountered. Borehole filled with cuttings at completion.								
663	60									
658	65									
653	70									

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 9
-------------------------	---------------------------	--------------

DATE DRILLED 11/3/19 LOGGED BY DHC **BORING NO.** B-9  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven						
								CL	Sandy lean CLAY; reddish brown; moist
718	5			13	12.5	116.7		CL	--same; loose
713	10			10				CL	--same; stiff
708	15			14	14.5	108.0		CL	-- same; stiff; with approximately 10% gravel
703	20			20				ML	SILT with sand; very stiff; light brown; slightly moist
698	25			34	20.6	108.1		SM	Silty SAND; medium dense; light brown; slightly moist
693	30			18				CL	Sandy lean CLAY; very stiff; brown; slightly moist
688	35	Total Depth = 31.5 feet Backfilled on 11/3/2019 Groundwater not encountered. Borehole filled with cuttings at completion.							

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 10

DATE DRILLED 11/2/19 LOGGED BY DHC **BORING NO.** B-10  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
									CL	Sandy lean CLAY; reddish brown; slightly moist
718	5			10			#200, ATT		CL	-- same; stiff
713	10			10	14.6	114.9			CL	-- same; medium stiff; brown
708	15			18			#200, ATT		CL	-- same; very stiff
703	20			25	13.8	110.1			ML	Sandy SILT; very stiff; brown; slightly moist
698	25			16			#200, ATT		CL	Sandy lean CLAY; very stiff; brown; slightly moist
693	30			29	19.3	106.1			CL	-- same; very stiff
688	35	Total Depth = 31.5 feet Backfilled on 11/2/2019 Groundwater not encountered. Borehole filled with cuttings at completion.								

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 11

DATE DRILLED 12/7/19 LOGGED BY DHC **BORING NO.** B-11  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										6.5 inches of Portland cement concrete over 6 inches of base
									CL	Sandy lean CLAY; reddish brown; moist
718	5			3					CL	-- same; soft
713	10			35	12.8	119.1	C		CL	-- same; very stiff
708	15			26					ML	SILT; very stiff; light brown; slightly moist
703	20			38	25.0	100.1			ML	-- same; very stiff; caliche nodules
698	25			19					CL	Sandy lean CLAY; very stiff; brown; slightly moist  -- thin layer of reddish brown silty sand
693	30			37	18.3	110.8			ML	Sandy SILT; very stiff; brown; slightly moist
688	35									Total Depth = 31.5 feet Backfilled on 12/7/2019 Groundwater not encountered. Borehole filled with cuttings at completion.

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 12
-------------------------	---------------------------	---------------

DATE DRILLED 11/9/19 LOGGED BY DHC **BORING NO.** B-12  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										6 inches of Portland cement concrete over 6 inches of base
									CL	Sandy lean CLAY; reddish brown; slightly moist
718	5			10					CL	-- same; stiff
713	10			48	11.3	121.8			CL	-- same; hard
708	15			49					SM	Silty SAND; dense; light grey; dry to slightly moist
703	20			49	5.9	117.4	C		SM	-- same; dense
698	25			36			#200, ATT		SM	--same; dense; light brown; slightly moist
693	30			29	10.8	114.8			SM	-- same; medium dense
688	35									Total Depth = 31.5 feet Backfilled on 11/9/2019 Groundwater not encountered. Borehole filled with cuttings at completion. Surface patched with PCC.

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 13
-------------------------	---------------------------	---------------

DATE DRILLED 12/7/19 LOGGED BY DHC **BORING NO.** B-13  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										6.5 inches of Portland cement concrete over 6 inches of base
									CL	Lean CLAY with sand; reddish brown; moist
718	5			13	16.4	113.9	UC		CL	-- same; stiff
713	10			10					CL	-- same; stiff
708	15			56	10.5	122.5	C		ML	Sandy SILT; hard; reddish brown with light brown mottling; slightly moist; some caliche nodules
703	20			15			#200, ATT		ML	-- same; stiff; light brown with tan mottling; some caliche nodules
698	25			35	4.6	115.8	DS		SP	Poorly graded SAND; medium dense; reddish brown; slightly moist
693	30			16					CL	Sandy lean CLAY; stiff; reddish brown; slightly moist
688	35									Total Depth = 31.5 feet Backfilled on 12/7/2019 Groundwater not encountered. Borehole filled with cuttings at completion.

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 14

DATE DRILLED 3/13/2021 LOGGED BY CDD **BORING NO.** GP-1  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 724 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										7 inches of asphalt over 6 inches of base
									SC	<b>FILL</b> Clayey SAND; reddish brown; slightly moist; with approximately 10% gravel
719	5			22					ML	<b>ALLUVIUM</b> Sandy SILT; reddish brown; slightly moist
									CL	Sandy Lean CLAY; medium brown; very stiff; slightly moist
714	10			63	8.6	129.3	C		CL	-- same; reddish to medium brown; hard
709	15			16					SM	Silty SAND; light brown; medium dense; slightly moist
704	20			33	16.5	106.7	#200		ML	SILT with sand; light brown; very stiff; slightly moist
699	25			10					CL	Lean CLAY with sand; medium to dark brown; stiff; slightly moist
694	30			56	12.6	106.1	C		ML	Sandy SILT; medium brown; hard; slightly moist; with approximately 2% fine gravel
689	35									

BORING LOG 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/30/21



<b>LOG OF BORING</b>		
Proposed Hospital Expansion, OSHPD: 106334025 Kaiser Permanente Riverside Medical Center Riverside, California		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 15

DATE DRILLED 3/13/2021 LOGGED BY CDD **BORING NO.** GP-1  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 724 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
				18			#200, ATT		SP-SM	Poorly Graded SAND with silt; light brown; medium dense; slightly moist; with approximately 2% fine gravel
684	40			55	5.5	111.4			SM	Silty SAND; light brown to gray; dense; slightly moist
679	45			41			#200		SP-SM	Poorly Graded SAND with silt; light brown; dense; slightly moist
674	50			71	13.6	112.8			SP-SM	-- same; dense
669	55	Total Depth = 51.5 feet Backfilled on 3/13/2021 Groundwater not encountered. Backfilled with neat cement grout at completion. Surface patched with PCC.								
664	60									
659	65									
654	70									

BORING LOG 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/30/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 15

DATE DRILLED 3/13/2021 LOGGED BY CDD **BORING NO.** GP-2  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 724 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
					11.4					4 inches of asphalt over 7 inches of base
							#200, ATT, EI, MAX, DS		CL	<b>FILL</b> Sandy lean CLAY; reddish brown; slightly moist; with approximately 10% fine gravel
719	5			36	7.1	124.1			CL	<b>ALLUVIUM</b> Sandy Lean CLAY; reddish brown; slightly moist
									CL	-- same; very stiff
714	10			27			#200, ATT		CL	-- same; light to medium brown; very stiff
709	15			41	3.8	115.5	DS		SM	Silty SAND; light brown; medium dense; slightly moist
704	20			23					ML	Sandy SILT; light brown to gray; very stiff; slightly moist
699	25			26	16.4	113.4	C		CL	Sandy Lean CLAY; medium to light brown; very stiff; slightly moist
694	30			18			#200, ATT		SM	Silty SAND; light brown; medium dense; slightly moist
689	35									

BORING LOG 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/30/21



<b>LOG OF BORING</b>		
Proposed Hospital Expansion, OSHPD: 106334025 Kaiser Permanente Riverside Medical Center Riverside, California		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 16

DATE DRILLED 3/13/2021 LOGGED BY CDD **BORING NO.** GP-2  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 724 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
				74	1.6	109.7			SP-SM	Poorly Graded SAND with silt; light brown; very dense; slightly moist
684	40			40			#200		SP-SM	-- same; dense
679	45			34/50 for 5.5"	2.1	112.3			SP-SM	-- same; very dense
674	50			42					SP-SM	-- same; dense; moist; with approximately 5% fine gravel
669	55	Total Depth = 51.5 feet Backfilled on 3/13/2021 Groundwater not encountered. Backfilled with neat cement grout at completion. Surface patched with PCC.								
664	60									
659	65									
654	70									

BORING LOG 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/30/21



<b>LOG OF BORING</b>		
Proposed Hospital Expansion, OSHPD: 106334025 Kaiser Permanente Riverside Medical Center Riverside, California		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 16

DATE DRILLED 3/13/2021 LOGGED BY CDD **BORING NO.** PT-1  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 724 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
										6 inches of asphalt over 6 inches of base
									SC	<b>FILL</b> Clayey SAND; reddish brown; slightly moist
							#200		SM	<b>ALLUVIUM</b> Silty SAND; reddish brown; slightly moist
719	5			39	8.4	125.9	DS		SM	-- same; medium brown; medium dense
714	10			19			#200, ATT		SM	-- same; medium dense
709	15			47	5.6	110.2			SM	-- same; dense
704	20			19			#200, ATT		ML	Sandy SILT; medium brown; very stiff; slightly moist
699	25									Total Depth = 21.5 feet Backfilled on 3/13/2021 Groundwater not encountered. Backfilled with neat cement grout at completion. Surface patched with PCC.
694	30									
689	35									

BORING LOG 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/30/21



<b>LOG OF BORING</b>		
Proposed Hospital Expansion, OSHPD: 106334025 Kaiser Permanente Riverside Medical Center Riverside, California		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 17

DATE DRILLED 3/13/2021 LOGGED BY CDD **BORING NO.** PT-2  
 DRIVE WEIGHT 140 lbs. DROP 30 inches DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 8" HSA DRILLER 2R Drilling SURFACE ELEVATION (ft.) 730 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	ADDITIONAL TESTS	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven							
									CL	<b>FILL</b> Sandy Lean CLAY; reddish brown; slightly moist
							#200, ATT, EI		SM	<b>ALLUVIUM</b> Silty SAND; medium brown; slightly moist
725	5								CL	Sandy Lean CLAY, reddish brown, slightly moist
720	10			44					CL	-- same; hard
715	15			50 for 5"	2.6	121.7			ML	Sandy SILT; medium brown to gray; hard; slightly moist
710	20			37			#200, ATT		CL	Sandy Lean CLAY; medium brown; hard; dry
705	25									Total Depth = 21.5 feet Backfilled on 3/13/2021 Groundwater not encountered. Backfilled with cuttings.
700	30									
695	35									

BORING LOG 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/30/21



<b>LOG OF BORING</b>		
Proposed Hospital Expansion, OSHPD: 106334025 Kaiser Permanente Riverside Medical Center Riverside, California		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 18

DATE DRILLED 2/12/2020 LOGGED BY DHC **BORING NO.** P-3  
 DRIVE WEIGHT \_\_\_\_\_ DROP \_\_\_\_\_ DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 5" Hand Auger DRILLER Twining, Inc. SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven						
718	5						[Hatched Pattern]	CL	Sandy lean CLAY; yellowish brown; slightly moist  -- turns reddish brown
713	10								Total Depth = 6.0 feet Backfilled on 2/12/2020 Groundwater not encountered. Hole backfilled with cuttings.
708	15								
703	20								
698	25								
693	30								
688	35								

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 19
-------------------------	---------------------------	---------------

DATE DRILLED 2/12/2020 LOGGED BY DHC **BORING NO.** P-4  
 DRIVE WEIGHT \_\_\_\_\_ DROP \_\_\_\_\_ DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 5" Hand Auger DRILLER Twining, Inc. SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven						
718	5						[Hatched Pattern]	CL	Sandy lean CLAY; reddish brown; slightly moist
713	10								Total Depth = 6.0 feet Backfilled on 2/12/2020 Groundwater not encountered. Hole backfilled with cuttings.
708	15								
703	20								
698	25								
693	30								
688	35								

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE A - 20
-------------------------	---------------------------	---------------

DATE DRILLED 2/12/2020 LOGGED BY DHC **BORING NO.** P-5  
 DRIVE WEIGHT \_\_\_\_\_ DROP \_\_\_\_\_ DEPTH TO GROUNDWATER (ft.) N/E  
 DRILLING METHOD 5" Hand Auger DRILLER Twining, Inc. SURFACE ELEVATION (ft.) 723 ±(MSL)

ELEVATION (feet)	DEPTH (feet)	SAMPLES		BLOWS / FOOT	MOISTURE (%)	DRY DENSITY (pcf)	GRAPHIC LOG	U.S.C.S. CLASSIFICATION	DESCRIPTION
		Bulk	Driven						
718	5						[Hatched Pattern]	CL	Sandy lean CLAY; reddish brown; slightly moist
713	10								Total Depth = 6.0 feet Backfilled on 2/12/2020 Groundwater not encountered. Hole backfilled with cuttings.
708	15								
703	20								
698	25								
693	30								
688	35								

BORING LOG 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 3/24/21



## LOG OF BORING

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE A - 21

## Infiltration Rate Calculation Sheet

Project :	Kaiser Riverside Medical Cntr	Project No. :	190919.3	Date :	3/31/2021
Test Hole No.:	P-3	Tested by :	DHC		
Depth of Test Hole, $D_T$ (in):	72	USCS Soil Classification :	CL		
Test Hole Dimension (inches)			Length	Width	
Diameter (if round) (inches) =	6.5	Sides (if rectangular) =			

### Sandy Soil Criteria Test\*

Trial No.	Start Time	Stop Time	Time Interval (min.)	Initial Depth to Water (in.)	Final Depth to Water (in.)	Change in Water Level (in.)	Greater than or Equal to 6" ? (Y/N)
1	7:00 AM	7:25 AM	25	15.6	50.4	34.8	Y
2	7:25 AM	7:50 AM	25	14.4	48.0	33.6	Y

\*If two consecutive measurements show that six inches of water seeps away in less than 25 minutes, the test shall be run for an additional hour with measurements taken every 10 minutes. Otherwise, pre-soak overnight. Obtain at least twelve measurements per hole over at least six hours (approximately 30 minute intervals) with a precision of at least 0.25".

			$\Delta t$	$H_o$	$H_f$	$\Delta H$	
Trial No.	Start Time	Stop Time	Time Interval (min.)	Initial Water Height (inches)	Final Water Height (inches)	Change in Water Level (inches)	Tested Infiltration Rate
1	7:52 AM	8:02 AM	10	63.00	34.80	28.20	5.44
2	8:02 AM	8:12 AM	10	63.60	44.40	19.20	3.37
3	8:12 AM	8:22 AM	10	64.80	45.60	19.20	3.29
4	8:22 AM	8:32 AM	10	62.40	46.80	15.60	2.71
5	8:32 AM	8:42 AM	10	63.60	50.40	13.20	2.20
6	8:42 AM	8:52 AM	10	63.60	51.00	12.60	2.08
7							
8							
9							
10							
11							
12							
13							
14							
15							

Infiltration Rate with a factor of safety of 3 = 0.7 inch /hr

## Infiltration Rate Calculation Sheet

Project :	Kaiser Riverside Medical Cntr	Project No. :	190919.3	Date :	3/31/2021
Test Hole No.:	P-4	Tested by :	DHC		
Depth of Test Hole, $D_T$ (in):	72	USCS Soil Classification :	CL		
Test Hole Dimension (inches)			Length	Width	
Diameter (if round) (inches) =	6.5	Sides (if rectangular) =			

### Sandy Soil Criteria Test\*

Trial No.	Start Time	Stop Time	Time Interval (min.)	Initial Depth to Water (in.)	Final Depth to Water (in.)	Change in Water Level (in.)	Greater than or Equal to 6" ? (Y/N)
1	8:50 AM	9:15 AM	25	12.0	33.6	21.6	Y
2	9:15 AM	9:40 AM	25	13.2	35.4	22.2	Y

\*If two consecutive measurements show that six inches of water seeps away in less than 25 minutes, the test shall be run for an additional hour with measurements taken every 10 minutes. Otherwise, pre-soak overnight. Obtain at least twelve measurements per hole over at least six hours (approximately 30 minute intervals) with a precision of at least 0.25".

Trial No.	Start Time	Stop Time	$\Delta t$	$H_o$	$H_f$	$\Delta H$	Tested Infiltration Rate
1	9:41 AM	9:51 AM	10	68.40	50.40	18.00	2.88
2	9:51 AM	10:01 AM	10	67.20	50.40	16.80	2.71
3	10:01 AM	10:11 AM	10	64.80	49.20	15.60	2.59
4	10:11 AM	10:21 AM	10	63.60	50.40	13.20	2.20
5	10:21 AM	10:31 AM	10	66.00	52.20	13.80	2.22
6	10:31 AM	10:41 AM	10	64.80	51.00	13.80	2.26
7							
8							
9							
10							
11							
12							
13							
14							
15							

Infiltration Rate with a factor of safety of 3 = 0.8 inch /hr

## Infiltration Rate Calculation Sheet

Project :	Kaiser Riverside Medical Cntr	Project No. :	190919.3	Date :	3/31/2021
Test Hole No.:	P-5	Tested by :	DHC		
Depth of Test Hole, $D_T$ (in):	72	USCS Soil Classification :	CL		
Test Hole Dimension (inches)			Length	Width	
Diameter (if round) (inches) =	6.5	Sides (if rectangular) =			

### Sandy Soil Criteria Test\*

Trial No.	Start Time	Stop Time	Time Interval (min.)	Initial Depth to Water (in.)	Final Depth to Water (in.)	Change in Water Level (in.)	Greater than or Equal to 6" ? (Y/N)
1	11:38 AM	12:03 PM	25	14.4	45.0	30.6	Y
2	12:03 PM	12:28 PM	25	10.8	38.4	27.6	Y

\*If two consecutive measurements show that six inches of water seeps away in less than 25 minutes, the test shall be run for an additional hour with measurements taken every 10 minutes. Otherwise, pre-soak overnight. Obtain at least twelve measurements per hole over at least six hours (approximately 30 minute intervals) with a precision of at least 0.25".

			$\Delta t$	$H_o$	$H_f$	$\Delta H$	
Trial No.	Start Time	Stop Time	Time Interval (min.)	Initial Water Height (inches)	Final Water Height (inches)	Change in Water Level (inches)	Tested Infiltration Rate
1	12:29 PM	12:39 PM	10	64.80	38.40	26.40	4.84
2	12:39 PM	12:49 PM	10	64.20	41.40	22.80	4.08
3	12:49 PM	12:59 PM	10	63.00	36.60	26.40	5.01
4	12:59 PM	1:09 PM	10	66.00	54.00	12.00	1.90
5	1:09 PM	1:19 PM	10	65.40	53.40	12.00	1.92
6	1:19 PM	1:29 PM	10	63.00	53.40	9.60	1.56
7							
8							
9							
10							
11							
12							
13							
14							
15							

Infiltration Rate with a factor of safety of 3 = 0.5 inch /hr



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

# APPENDIX B LABORATORY TESTING



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

## **Appendix B Laboratory Testing**

### **Laboratory Moisture Content and Density Tests**

The moisture content and dry densities of selected driven samples obtained from the exploratory borings were evaluated in general accordance with the latest version of ASTM D 2937. The results are shown on the boring logs in Appendix A, and also summarized in Table B-1.

### **No. 200 Wash Sieve**

The amount of fines passing the No. 200 sieve was evaluated in accordance with ASTM D 1140. The results are presented in Table B-2.

### **Grain Size Analysis**

The grain size analysis was evaluated in accordance with ASTM D 422. The results are presented in Figure B-1.

### **Atterberg Limits**

Tests were performed on selected representative fine-grained soil samples to evaluate the liquid limit, plastic limit, and plasticity index in general accordance with ASTM D 4318. These test results were utilized to evaluate the soil classification in accordance with the Unified Soil Classification System. The test results are summarized in on Figures B-2 and B-3 and Table B-3.

### **Resistance Value (R-value)**

R-value testing was performed on a select bulk sample of the near-surface soils encountered at the site. The test was performed in general accordance with ASTM D 2844. The result is summarized in Table B-4.

### **Expansion Index**

The expansion index of a select soil sample was evaluated in general accordance with ASTM D 4829. The specimen was molded under a specified compactive energy at approximately 50 percent saturation. The prepared 1-inch thick by 4-inch diameter specimen was loaded with a surcharge of 144 pounds per square foot and was inundated with tap water. Readings of volumetric swell were made for a period of 24 hours. The result of expansion index test is presented in Table B-5.

### **Maximum Density and Optimum Moisture**

Modified Proctor testing was performed on near-surface soils to determine the maximum dry density and optimum water content for compaction. The test was performed in accordance with ASTM D 1557 Method A. Test results are attached to this appendix as Figure B-4.

### **Direct Shear**

Direct shear tests were performed on representative soil samples in general accordance with the latest version of ASTM D 3080 to evaluate the shear strength characteristics of the selected



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

materials. The samples were inundated during shearing to represent adverse field conditions. Test results are presented on Figures B-5 through B-13.

### **Consolidation**

Consolidation tests were performed on select modified-California soil samples in general accordance with the latest version of ASTM D2435. The samples were inundated during testing to represent adverse field conditions. The percent consolidation for each load cycle was recorded as a ratio of the amount of vertical compression to the original height of the sample. The testing was performed by the geotechnical laboratory of Twining and the laboratory of Hushmand Associates, Inc. (HAI) of Irvine, California. The results of the tests by Twining are presented in Figures B-14 through B-22 and those by HAI in HAI's laboratory test sheets and graphs included in this appendix.

### **Unconfined Compression**

Unconfined compression (UC) testing was conducted to assess unconfined compression strength of site soils. The testing was performed using strain-controlled application of the axial load on representative relatively undisturbed samples. The testing was performed by the laboratory of Hushmand Associates, Inc. (HAI) of Irvine, California in general accordance with ASTM D2166. At the time of testing, the moisture content and dry density of each sample were measured. Stress-strain measurements were also plotted for the UC tests. Test results are presented in HAI's laboratory test sheets and graphs included in this appendix. The UC strengths of the samples are summarized on Table B-6.

### **Corrosivity**

Soil pH and resistivity tests were performed by Anaheim Test Lab, Inc. (ATLI) of Anaheim, California on a representative soil sample. The resistivity of the soil assumes saturated soil conditions. The chloride and sulfate contents of the selected samples were evaluated in general accordance with the latest versions of Caltrans test methods CT417, CT422, and CT 643. The test results are presented on Table B-7 and the ATLI reports included in this appendix.



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

**Table B-1**  
**Moisture Content and Dry Density**

<b>Boring No.</b>	<b>Depth (feet)</b>	<b>Moisture Content (%)</b>	<b>Dry Density (pcf)</b>
B-1	5	11.9	121.8
B-1	15	11.7	124.6
B-1	25	17.3	114.0
B-1	35	22.5	98.2
B-1	45	2.8	107.1
B-2	10	9.7	126.8
B-2	20	20.2	100.4
B-2	30	23.1	103.1
B-3	5	9.7	100.3
B-3	15	3.1	117.9
B-3	25	2.5	104.3
B-3	35	15.5	104.8
B-3	45	9.1	104.0
B-4	10	6.6	121.8
B-4	20	1.2	101.3
B-4	30	13.8	108.6
B-5	10	14.9	118.5
B-5	20	1.2	113.4
B-5	30	4.2	122.7
B-5	40	23.7	97.1
B-5	50	4.4	101.8
B-5	60	9.4	128.2
B-6	10	7.9	117.2
B-6	20	7.0	118.9
B-6	30	2.8	102.9
B-6	40	18.0	100.2
B-7	5	9.7	119.8
B-7	15	9.9	113.5
B-7	25	9.7	118.1
B-8	10	14.8	117.9
B-8	20	26.3	94.9
B-8	30	21.5	103.1
B-8	40	13.6	108.1
B-8	50	3.2	102.1
B-9	5	12.5	116.7
B-9	15	14.5	108.0
B-9	25	20.6	108.1



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

B-10	10	14.6	114.9
B-10	20	13.8	110.1
B-10	30	19.3	106.1
B-11	10	12.8	119.1
B-11	20	25.0	100.1
B-11	30	18.3	110.8
B-12	10	11.3	121.8
B-12	20	5.9	117.4
B-12	30	10.8	114.8
B-13	5	16.4	113.9
B-13	15	10.5	122.5
B-13	25	4.6	115.8
GP-1	10	8.6	129.3
GP-1	20	16.5	106.7
GP-1	30	12.6	106.1
GP-1	40	5.5	111.4
GP-1	50	13.6	112.8
GP-2	5	7.1	124.1
GP-2	15	3.8	115.5
GP-2	25	16.4	113.4
GP-2	35	1.6	109.7
GP-2	45	2.1	112.3
PT-1	5	8.4	125.9
PT-1	15	5.6	110.2
PT-2	15	2.6	121.7



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

**Table B-2  
Number 200 Wash Results**

Boring No.	Depth (feet)	Percent Passing #200
B-1	20	68.5
B-2	5	53.4
B-3	10	75.9
B-3	20	5.1
B-3	30	63.6
B-3	50	81.7
B-4	10	83.8
B-4	15	65.1
B-5	45	7.5
B-6	5	64.8
B-6	15	70.0
B-6	25	82.2
B-6	40	71.7
B-7	10	78.1
B-8	20	68.3
B-8	35	4.8
B-8	45	6.5
B-10	5	58.9
B-10	15	68.9
B-10	25	55.1
B-12	25	19.4
B-13	20	67.4
GP-1	20	77.7
GP-1	35	9
GP-1	45	6.4
GP-2	Bulk	54.7
GP-2	10	58.7
GP-2	30	48.7
GP-2	40	11.0
PT-1	10	48.9
PT-1	20	62.1
PT-2	Bulk	49.5
PT-2	20	55.3



2883 East Spring Street  
 Suite 300  
 Long Beach CA 90806

Tel 562.426.3355  
 Fax 562.426.6424

**Table B-3  
 Atterberg Limits Results**

Boring No.	Depth (feet)	Liquid Limit	Plastic Limit	Plasticity Index	U.S.C.S. Classification
B-1	20	NP	NP	NP	Sandy Silt (ML)
B-3	10	30	17	13	Lean Clay with Sand (CL)
B-3	30	30	21	9	Sandy Lean Clay (CL)
B-3	50	NP	NP	NP	Silt with Sand (ML)
B-4	15	29	21	8	Sandy Lean Clay (CL)
B-6	25	30	16	14	Lean Clay with Sand (CL)
B-6	40	41	26	15	Lean Clay with Sand (CL)
B-7	10	28	17	11	Lean Clay with Sand (CL)
B-8	20	42	27	15	Sandy Silt (ML)
B-10	5	26	18	8	Sandy Lean Clay (CL)
B-10	15	28	18	10	Sandy Lean Clay (CL)
B-10	25	28	20	8	Sandy Lean Clay (CL)
B-12	25	NP	NP	NP	Silty Sand (SM)
B-13	20	NP	NP	NP	Sandy Silt (ML)
GP-1	35	NP	NP	NP	Poorly Grade Sand (SP)
GP-2	0 - 5	28	19	9	Sandy Lean Clay (CL)
GP-2	10	28	20	8	Sandy Lean Clay (CL)
GP-2	30	NP	NP	NP	Silty Sand (SM)
PT-1	10	NP	NP	NP	Silty Sand (SM)
PT-1	20	NP	NP	NP	Sandy Silt (ML)
PT-2	0 - 5	NP	NP	NP	Silty Sand (SM)
PT-2	20	26	21	5	Sandy Lean Clay (CL)

**Table B-4  
 Resistance Value (R-value)**

Boring No.	Depth (feet)	R Value
B-3	0 - 5	9

**Table B-5  
 Expansion Index**

Boring No.	Depth (feet)	Expansion Index	Expansion Potential
B-3	0 - 5	31	low
GP-2	0 - 5	19	very low
PT-2	0 - 5	19	very low



2883 East Spring Street  
Suite 300  
Long Beach CA 90806


Tel 562.426.3355  
Fax 562.426.6424

**Table B-6**  
**Unconfined Compression Test Results**

Boring No.	Depth (feet)	Soil Classification	Unconfined Compression Strength, $q_u$ , (psf)
B-3	25	Poorly Graded Sand with Silt (SP-SM)	540
B-5	10	Sandy Lean Clay (CL)	10,307
B-6	10	Sandy Lean Clay (CL)	11,909
B-6	20	Sandy Lean Clay (CL)	5,171
B-7	15	Sandy Lean Clay (CL)	10,161
B-13	5	Sandy Lean Clay (CL)	1,524

**Table B-7**  
**Corrosivity Test Results**

Boring No.	Depth (feet)	pH	Water Soluble Sulfate (ppm)	Water Soluble Chloride (ppm)	Minimum Resistivity (ohm-cm)
B-1	0-5	7.1	313	104	1,400
GP-2	0-5	6.8	374	131	1,600
PT-2	0-5	6.9	427	165	990




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Sample Location	U.S.C.S. Classification						Cc	Cu
● B-3 at 20 ft	Well graded SAND with silt						1.09	6.28
D <sub>100</sub>	D <sub>60</sub>	D <sub>50</sub>	D <sub>30</sub>	D <sub>10</sub>	%Gravel	%Sand	%Silt	%Clay
12.5	1.003	0.765	0.417	0.16	4.0	90.9	5.1	

GRAIN SIZE 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 11/19/19



<b>GRAIN SIZE DISTRIBUTION</b>		
Proposed Hospital Expansion, OSHPD: 106334025 Kaiser Permanente Riverside Medical Center Riverside, California		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE B- 1



Sample Location	LL	PL	PI	U.S.C.S. Classification
● B-1 at 20 ft	NP	NP	NP	Sandy SILT
⊠ B-10 at 5 ft	26	18	8	Sandy lean CLAY
▲ B-10 at 15 ft	28	18	10	Sandy lean CLAY
★ B-10 at 25 ft	28	20	8	Sandy lean CLAY
⊙ B-12 at 25 ft	NP	NP	NP	Silty SAND
⊕ B-13 at 20 ft	NP	NP	NP	Sandy SILT
○ B-3 at 10 ft	30	17	13	Lean CLAY with sand
△ B-3 at 30 ft	30	21	9	Sandy lean CLAY
⊗ B-3 at 50 ft	NP	NP	NP	SILT
⊕ B-4 at 15 ft	29	21	8	Sandy lean CLAY
□ B-6 at 25 ft	30	16	14	Lean CLAY with sand
⊕ B-6 at 40 ft	41	26	15	Lean CLAY with sand
⊕ B-7 at 10 ft	28	17	11	Lean CLAY with sand
★ B-8 at 20 ft	42	27	15	Sandy SILT
⊗ GP-1 at 35 ft	NP	NP	NP	Poorly graded SAND with silt
■ GP-2 at 1-5 ft	28	19	9	Sandy lean CLAY
◆ GP-2 at 10 ft	28	20	8	Sandy lean CLAY
◇ GP-2 at 30 ft	NP	NP	NP	Silty SAND
× PS-1 at 10 ft	33	17	16	Sandy lean CLAY
⊕ PS-2 at 10 ft	33	22	11	Sandy lean CLAY

ATTERBERG LIMITS - 190919.3 - KAISER RIVERSIDE TOWER.GPJ - TWINING LABS.GDT - 3/29/21



### ATTERBERG LIMITS

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California


PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-2



COMPACTION (MODIFIED BY PAUL) 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/24/21



Boring No.: GP-2  
 Sample Depth: BULK 0-5'  
 Sample Description: Sandy Lean CLAY

Test Method: ASTM D1557 Method A  
 Sampled By: CDD  
 Sample Date: 3/13/21  
 Test Date: 3/18/21

**TEST RESULTS**  
 Maximum Dry Density: 132.5 pcf  
 Optimum Water Content: 8.0 %

Curves of 100% Saturation  
 for Specific Gravity Equal to:

- 2.80
- 2.70
- 2.60
- 2.50




**MOISTURE-DENSITY RELATIONSHIP**

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE B-4
-------------------------	---------------------------	------------

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 2/20/20



**Boring No.:** B-13  
**Sample Depth (ft):** 25  
**Sample Description:** Poorly graded SAND  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 115.8

**Shear Strength Parameters**

**Peak** ● **Ultimate** ✕

**Cohesion, C (psf):** 120      204  
**Friction Angle,  $\phi$  (deg):** 34      29

**Initial Moisture (%):** 4.6  
**Final Moisture (%):** 13.8



### DIRECT SHEAR TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-5

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 2/20/20



**Boring No.:** B-2  
**Sample Depth (ft):** 20  
**Sample Description:** Sandy SILT  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 100.4

**Shear Strength Parameters**

**Peak** ● **Ultimate** ✕

**Cohesion, C (psf):** 702      198  
**Friction Angle, Ø (deg):** 26      28

**Initial Moisture (%):** 20.2  
**Final Moisture (%):** 17.8



### DIRECT SHEAR TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-6

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 2/20/20



**Boring No.:** B-3  
**Sample Depth (ft):** 15  
**Sample Description:** Lean CLAY with sand  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 117.9

**Shear Strength Parameters**

**Peak** —●—      **Ultimate** —✕—

**Cohesion, C (psf):** 132      0  
**Friction Angle,  $\phi$  (deg):** 33      33

**Initial Moisture (%):** 3.1  
**Final Moisture (%):** 11.3



### DIRECT SHEAR TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-7

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 2/20/20



**Boring No.:** B-4  
**Sample Depth (ft):** 20  
**Sample Description:** Well graded SAND  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 101.3

**Shear Strength Parameters**

**Peak** ● **Ultimate** ✕

**Cohesion, C (psf):** 444      50  
**Friction Angle,  $\phi$  (deg):** 32      31

**Initial Moisture (%):** 1.2  
**Final Moisture (%):** 16.6



### DIRECT SHEAR TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-8

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 2/20/20



**Boring No.:** B-5  
**Sample Depth (ft):** 20  
**Sample Description:** Poorly graded SAND with silt  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 113.4

**Shear Strength Parameters**  
**Peak** ● **Ultimate** ✕  
**Cohesion, C (psf):** 324      0  
**Friction Angle,  $\phi$  (deg):** 36      34  
**Initial Moisture (%):** 1.2  
**Final Moisture (%):** 13.3



### DIRECT SHEAR TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-9

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 2/20/20



**Boring No.:** B-8  
**Sample Depth (ft):** 10  
**Sample Description:** Lean CLAY with sand  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 117.9

**Shear Strength Parameters**

**Peak** ● **Ultimate** ✕

**Cohesion, C (psf):** 504      312  
**Friction Angle,  $\phi$  (deg):** 25      25

**Initial Moisture (%):** 14.8  
**Final Moisture (%):** 13.4



### DIRECT SHEAR TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-10

SHEAR STRENGTH, psf



**Boring No.:** GP-2  
**Sample Depth (ft):** 0-5'  
**Sample Description:** Sandy Lean CLAY  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 132.7

**Shear Strength Parameters**

	<b>Peak</b> ●	<b>Ultimate</b> ⊠
<b>Cohesion, C (psf):</b>	624	408
<b>Friction Angle, Ø (deg):</b>	21	23
<b>Initial Moisture (%):</b>	7.7	
<b>Final Moisture (%):</b>	11.4	

**Sample Remolded to 90% Relative Compaction**



**DIRECT SHEAR TEST**

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California


PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-11

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/24/21

SHEAR STRENGTH, psf



**Boring No.:** GP-2  
**Sample Depth (ft):** 15  
**Sample Description:** Silty SAND  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 115.5

**Shear Strength Parameters**

	<b>Peak</b> ●	<b>Ultimate</b> ⊠
<b>Cohesion, C (psf):</b>	36	120
<b>Friction Angle, <math>\phi</math> (deg):</b>	34	28
<b>Initial Moisture (%):</b>	3.8	
<b>Final Moisture (%):</b>	14.7	

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/24/21



### DIRECT SHEAR TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-12

SHEAR STRENGTH, psf



**Boring No.:** PT-1  
**Sample Depth (ft):** 5  
**Sample Description:** Sandy SILT  
**Strain Rate (in./min):** 0.005  
**Dry Density (pcf):** 125.9

**Shear Strength Parameters**

	<b>Peak</b> ●	<b>Ultimate</b> ✕
<b>Cohesion, C (psf):</b>	318	288
<b>Friction Angle, Ø (deg):</b>	32	26
<b>Initial Moisture (%):</b>	8.4	
<b>Final Moisture (%):</b>	13.1	

DIRECT SHEAR 190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/24/21



### DIRECT SHEAR TEST

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California


PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-13

CONSOL STRAIN\_190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 1/15/20

STRAIN, %



Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● B-1 at 5 ft	Sandy lean CLAY	121.8	11.9




### CONSOLIDATION TEST

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE B-14
-------------------------	---------------------------	-------------

CONSOL STRAIN\_190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 1/15/20

STRAIN, %



Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● B-11 at 10 ft	Sandy Lean CLAY	119.1	12.8




### CONSOLIDATION TEST

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE B-15
-------------------------	---------------------------	-------------

CONSOL STRAIN\_190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 1/15/20

STRAIN, %



Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● B-12 at 20 ft	SILT with sand	117.4	5.9




### CONSOLIDATION TEST

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE B-16
-------------------------	---------------------------	-------------

CONSOL STRAIN\_190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 1/15/20

STRAIN, %



Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● B-3 at 15 ft	Lean CLAY with sand	117.9	3.1




### CONSOLIDATION TEST

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE B-17
-------------------------	---------------------------	-------------

CONSOL STRAIN\_190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 1/15/20




Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● B-6 at 40 ft	Lean CLAY with sand	100.2	18.0



CONSOLIDATION TEST		
Proposed Hospital Expansion, OSHPD: 106334025 Kaiser Permanente Riverside Medical Center Riverside, California		
PROJECT NO. 190919.3	REPORT DATE March 2021	FIGURE B-18

CONSOL STRAIN\_190919.3 - KAISER RIVERSIDE TOWER.GPJ TWINING LABS.GDT 1/15/20



Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● B-8 at 20 ft	Sandy SILT	94.9	26.3



### CONSOLIDATION TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-19

STRAIN, %



Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● GP-1 at 10 ft	Sandy Lean CLAY	129.3	8.6

CONSOL STRAIN\_190919.3 - KAISER RIVERSIDE.GPJ TWINING LABS.GDT 3/29/21



### CONSOLIDATION TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-20

STRAIN, %



Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● GP-1 at 30 ft	Sandy SILT	106.1	12.6



### CONSOLIDATION TEST


Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-21

STRAIN, %



Sample Location	Soil Description	Dry Density (pcf)	Moisture Content (%)
● GP-2 at 25 ft	Sandy Lean CLAY	113.4	16.4



### CONSOLIDATION TEST

Proposed Hospital Expansion, OSHPD: 106334025  
 Kaiser Permanente Riverside Medical Center  
 Riverside, California

PROJECT NO.  
190919.3

REPORT DATE  
March 2021

FIGURE B-22



Hushmand Associates, Inc.  
250 Goddard, Irvine,  
CA 92618

p. (949) 777-1274  
w. haieng.com  
e. hai@haieng.com

November 14, 2019

**Twining Consulting**  
3310 Airport Way,  
Long Beach, CA 90806

Attention: Mr. Steven Chang

**SUBJECT: Laboratory Test Result**  
**Project Name: Kaiser Riverside**  
**Project No.: 190919.3**  
**HAI Project No.: TWI-19-010**

Dear Mr. Chang:

Enclosed is the result of the laboratory testing program conducted on samples from the above referenced project. The testing performed for this program was conducted in general accordance with the following test procedure:

<u>Type of Test</u>	<u>Test Procedure</u>
Moisture Content & Dry Density	ASTM D2216 & D2937
Consolidation	ASTM D2435

Attached are: two (2) Moisture Content & Dry Density test results; and two (2) Consolidation test results.

We appreciate the opportunity to provide our testing services to Twining Consulting. If you have any questions regarding the test results, please contact us.

Sincerely,

HUSHMAND ASSOCIATES, INC.

Kang C. Lin, BS, EIT  
Laboratory Manager

Woongju (MJ) Mun, PhD  
Senior Staff Engineer



## MOISTURE CONTENT AND DRY DENSITY OF RING SAMPLES

### ASTM D2216 & ASTM D2937

**Client:** Twining Consulting  
**Project Name:** Kaiser Riverside  
**Project No.:** 190919.3

**HAI Proj No.:** TWI-19-010  
**Performed by:** KL  
**Checked by:** MJ  
**Date:** 11/6/2019

No.	Boring No.	Sample No.	Depth	Wt of Ring + Soil	Height of Sample	Dia. of Sample	Volume of Sample	Wt of Rings	Wt of Soil	Wet Density	Wt of Cont. + Wet Soil	Wt of Cont. + Dry Soil	Wt of Container	Moisture Content	Dry Density
			ft	gr	in	in	cu.ft	gr	gr	pcf	gr	gr	gr	%	pcf
1	B-4	R	30	203.47	1.07	2.416	0.0028	45.07	158.40	123.6	203.47	184.23	45.07	13.8	108.6
2	B-8	R	30	201.63	1.04	2.416	0.0028	44.86	156.77	125.3	201.63	173.91	44.86	21.5	103.1







# CONSOLIDATION TEST

## ASTM D2435

Client : Twining Consulting  
Project Name: Kaiser Riverside  
Project Number: 190919.3  
Boring No.: B4  
Sample No.: R  
Type of Sample: Undisturbed Ring  
Depth (ft): 30  
Soil Description: Light Olive, Lean Clay with Sand (CL)

HAI Project No.: TWI-19-010  
Tested by: KL  
Checked by: MJ  
Date: 11/06/19









# CONSOLIDATION TEST

## ASTM D2435

Client : Twining Consulting  
Project Name: Kaiser Riverside  
Project Number: 190919.3  
Boring No.: B8  
Sample No.: R  
Type of Sample: Undisturbed Ring  
Depth (ft): 30  
Soil Description: Brown, Fat Clay with Sand (CH)

HAI Project No.: TWI-19-010  
Tested by: KL  
Checked by: MJ  
Date: 11/06/19





Hushmand Associates, Inc.  
250 Goddard, Irvine,  
CA 92618

p. (949) 777-1274  
w. haieng.com  
e. hai@haieng.com

December 27, 2019

**Twining Inc.**  
3310 East Airport Way,  
Long Beach, CA 90806

Attention: Mr. Brian Vollnogle

**SUBJECT: Laboratory Test Result**  
**Project Name: RMC**  
**Project No.: 190919.3**  
**HAI Project No.: TWI-19-013**

Dear Mr. Vollnogle:

Enclosed is the result of the laboratory testing program conducted on samples from the above referenced project. The testing performed for this program was conducted in general accordance with the following test procedure:

<u>Type of Test</u>	<u>Test Procedure</u>
Moisture Content & Dry Density	ASTM D2216 & D2937
Consolidation	ASTM D2435
Unconfined Compression	ASTM D2166

Attached are: eight (8) Moisture Content & Dry Density test results; four (4) Consolidation test results; and eight (8) Unconfined Compression test results.

We appreciate the opportunity to provide our testing services to Twining Inc. If you have any questions regarding the test results, please contact us.

Sincerely,

HUSHMAND ASSOCIATES, INC.

Kang C. Lin, BS, EIT  
Laboratory Manager

Ashkaan Hushmand, PhD, PE  
Project Engineer









# CONSOLIDATION TEST

## ASTM D2435

Client : Twining Inc.  
Project Name: RMC  
Project Number: 190919.3  
Boring No.: B-13  
Sample No.: R  
Type of Sample: Undisturbed Ring  
Depth (ft): 15  
Soil Description: Brown, Lean Clay (CL)

HAI Project No.: TWI-19-013  
Tested by: KL  
Checked by: MJ  
Date: 12/13/19





# UNCONFINED COMPRESSION STRENGTH TEST

## ASTM D2166

**Client:** Twining Inc.

**HAI Project No.:** TWI-19-013

**Project:** RMC

**Tested by:** KL

**Project No.:** 190919.3

**Checked by:** AH

**Boring No.:** B-3

**Date:** 12/13/2019

**Sample No.:** 25

**Soil Description:** Light Brown, Poorly Graded Sand with Silt (SP-SM)


### 1. Initial Specimen Information

Height:	(in)	5.00	Initial Wet Weight:	(g)	629.76
Diameter:	(in)	2.42	Wet Density:	(pcf)	104.7
Area:	(in <sup>2</sup> )	4.58	<b>Moisture Content:</b>	<b>(%)</b>	<b>3.0</b>
Volume:	(in <sup>3</sup> )	22.92	<b>Dry Density:</b>	<b>(pcf)</b>	<b>101.6</b>

### 2. Compression Test Data

**Curing Days:** -

Vertical Displ. (in)	Load (lbs)	q <sub>u</sub> (psf)	Strain (%)
0.0000	0.0	2.0	0.00
0.0009	0.5	16.1	0.02
0.0035	2.3	75.5	0.07
0.0074	3.7	119.5	0.15
0.0100	4.9	157.0	0.20
0.0134	6.7	212.7	0.27
0.0160	7.7	242.5	0.32
0.0186	9.1	285.6	0.37
0.0224	10.4	326.2	0.45
0.0250	12.0	376.2	0.50
0.0284	13.1	412.4	0.57
0.0310	14.1	442.7	0.62
0.0336	14.9	468.2	0.67
0.0375	15.9	496.1	0.75
0.0400	16.5	514.5	0.80
0.0435	17.3	540.2	0.87
0.0461	17.0	530.1	0.92
0.0486	16.9	527.1	0.97
0.0546	16.0	500.4	1.09
0.0620	13.1	408.5	1.24



Failure of the specimen





# UNCONFINED COMPRESSION STRENGTH TEST

## ASTM D2166

**Client:** Twining Inc.

**HAI Project No.:** TWI-19-013

**Project:** RMC

**Tested by:** KL

**Project No.:** 190919.3

**Checked by:** AH

**Boring No.:** B-5

**Date:** 12/13/2019

**Sample No.:** 10

**Soil Description:** Brown, Fat Clay with Sand (CH)


### 1. Initial Specimen Information

Height:	(in)	5.05	Initial Wet Weight:	(g)	823.08
Diameter:	(in)	2.41	Wet Density:	(pcf)	136.1
Area:	(in <sup>2</sup> )	4.57	<b>Moisture Content:</b>	<b>(%)</b>	<b>14.9</b>
Volume:	(in <sup>3</sup> )	23.04	<b>Dry Density:</b>	<b>(pcf)</b>	<b>118.5</b>

### 2. Compression Test Data

**Curing Days:** -

Vertical Displ. (in)	Load (lbs)	q <sub>u</sub> (psf)	Strain (%)
0.0000	0.0	5.3	0.00
0.0051	2.5	83.2	0.10
0.0112	10.7	342.7	0.22
0.0177	23.3	739.1	0.35
0.0238	35.2	1110.3	0.47
0.0316	49.1	1545.7	0.63
0.0377	62.8	1969.9	0.75
0.0442	75.6	2369.5	0.88
0.0507	88.0	2753.0	1.00
0.0758	131.5	4091.0	1.50
0.1062	174.6	5395.4	2.10
0.1313	204.1	6276.6	2.60
0.1565	230.5	7048.8	3.10
0.1816	253.6	7715.2	3.60
0.2068	274.3	8301.9	4.10
0.2371	295.7	8893.0	4.70
0.2775	320.2	9550.1	5.50
0.3911	354.2	10307.1	7.75
0.4037	352.8	10240.9	8.00
0.4540	317.8	9126.3	9.00



Failure of the specimen





# UNCONFINED COMPRESSION STRENGTH TEST

## ASTM D2166

**Client:** Twining Inc.  
**Project:** RMC  
**Project No.:** 190919.3  
**Boring No.:** B-6  
**Sample No.:** 10  
**Soil Description:** Brown, Sandy Fat Clay (CH)

**HAI Project No.:** TWI-19-013  
**Tested by:** KL  
**Checked by:** AH  
**Date:** 12/13/2019


### 1. Initial Specimen Information

Height:	(in)	5.05	Initial Wet Weight:	(g)	762.31
Diameter:	(in)	2.40	Wet Density:	(pcf)	127.0
Area:	(in <sup>2</sup> )	4.53	<b>Moisture Content:</b>	<b>(%)</b>	<b>9.3</b>
Volume:	(in <sup>3</sup> )	22.86	<b>Dry Density:</b>	<b>(pcf)</b>	<b>116.2</b>

### 2. Compression Test Data

**Curing Days: -**

Vertical Displ. (in)	Load (lbs)	q <sub>u</sub> (psf)	Strain (%)
0.0000	0.0	-35.7	0.00
0.0020	0.2	-29.5	0.04
0.0069	0.1	-32.8	0.14
0.0119	5.7	145.9	0.24
0.0171	14.6	426.3	0.34
0.0221	25.3	766.3	0.44
0.0271	35.6	1090.1	0.54
0.0310	43.1	1327.8	0.61
0.0360	52.5	1621.5	0.71
0.0410	63.3	1960.9	0.81
0.0462	76.6	2377.0	0.92
0.0551	101.3	3149.8	1.09
0.0753	160.4	4989.5	1.49
0.0955	220.2	6836.4	1.89
0.1107	261.6	8104.2	2.19
0.1309	309.3	9547.8	2.59
0.1510	349.5	10749.0	2.99
0.1762	388.0	11909.9	3.49
0.1877	371.5	11340.8	3.72
0.2066	328.7	9991.1	4.09



Failure of the specimen





# UNCONFINED COMPRESSION STRENGTH TEST

## ASTM D2166

**Client:** Twining Inc.

**HAI Project No.:** TWI-19-013

**Project:** RMC

**Tested by:** KL

**Project No.:** 190919.3

**Checked by:** AH

**Boring No.:** B-6

**Date:** 12/13/2019

**Sample No.:** 20

**Soil Description:** Borwn, Clayey Sand (SC)


### 1. Initial Specimen Information

Height:	(in)	5.09	Initial Wet Weight:	(g)	765.70
Diameter:	(in)	2.41	Wet Density:	(pcf)	125.4
Area:	(in <sup>2</sup> )	4.58	<b>Moisture Content:</b>	<b>(%)</b>	<b>6.1</b>
Volume:	(in <sup>3</sup> )	23.27	<b>Dry Density:</b>	<b>(pcf)</b>	<b>118.2</b>

### 2. Compression Test Data

**Curing Days:** -

Vertical Displ. (in)	Load (lbs)	q <sub>u</sub> (psf)	Strain (%)
0.0000	0.0	6.9	0.00
0.0023	1.1	40.0	0.05
0.0063	5.4	176.3	0.12
0.0102	11.7	375.2	0.20
0.0139	18.5	588.4	0.27
0.0176	25.2	798.6	0.35
0.0216	32.4	1024.1	0.42
0.0253	39.0	1229.0	0.50
0.0292	45.1	1417.8	0.57
0.0329	51.4	1615.4	0.65
0.0369	58.3	1828.4	0.72
0.0408	66.3	2078.8	0.80
0.0445	74.2	2323.3	0.88
0.0484	82.2	2571.7	0.95
0.0559	97.9	3056.3	1.10
0.0712	127.4	3963.7	1.40
0.0865	152.9	4740.5	1.70
0.1018	167.4	5171.3	2.00
0.1131	158.8	4895.8	2.22
0.1271	98.1	3017.4	2.50



Failure of the specimen





# UNCONFINED COMPRESSION STRENGTH TEST

## ASTM D2166

**Client:** Twining Inc.

**HAI Project No.:** TWI-19-013

**Project:** RMC

**Tested by:** KL

**Project No.:** 190919.3

**Checked by:** AH

**Boring No.:** B-7

**Date:** 12/13/2019

**Sample No.:** 15

**Soil Description:** Borwn, Clayey Sand (SC)

\* The sample height-to-diameter ratio is less than 2.


### 1. Initial Specimen Information

Height:	(in)	4.03	Initial Wet Weight:	(g)	599.75
Diameter:	(in)	2.41	Wet Density:	(pcf)	124.1
Area:	(in <sup>2</sup> )	4.57	<b>Moisture Content:</b>	<b>(%)</b>	<b>11.2</b>
Volume:	(in <sup>3</sup> )	18.41	<b>Dry Density:</b>	<b>(pcf)</b>	<b>111.6</b>

### 2. Compression Test Data

**Curing Days:** -

Vertical Displ. (in)	Load (lbs)	q <sub>u</sub> (psf)	Strain (%)
0.0000	0.0	-0.2	0.00
0.0015	0.8	25.8	0.04
0.0057	2.6	82.9	0.14
0.0097	7.3	229.4	0.24
0.0137	13.9	435.2	0.34
0.0178	21.0	659.1	0.44
0.0218	29.0	907.6	0.54
0.0260	39.2	1226.1	0.64
0.0299	50.0	1561.3	0.74
0.0341	61.8	1928.1	0.85
0.0381	73.5	2292.6	0.95
0.0481	103.5	3219.9	1.19
0.0642	151.5	4694.3	1.59
0.0803	197.2	6086.9	1.99
0.0964	240.6	7396.0	2.39
0.1125	277.9	8504.7	2.79
0.1286	308.1	9391.0	3.19
0.1570	335.8	10161.7	3.90
0.1609	334.6	10115.7	4.00
0.1730	237.4	7153.7	4.30



Failure of the specimen





# UNCONFINED COMPRESSION STRENGTH TEST

## ASTM D2166

**Client:** Twining Inc.  
**Project:** RMC  
**Project No.:** 190919.3  
**Boring No.:** B-13  
**Sample No.:** 5  
**Soil Description:** Borwn, Lean Clay (CL)

**HAI Project No.:** TWI-19-013

**Tested by:** KL

**Checked by:** AH

**Date:** 12/13/2019


### 1. Initial Specimen Information

Height:	(in)	5.05	Initial Wet Weight:	(g)	797.68
Diameter:	(in)	2.40	Wet Density:	(pcf)	132.7
Area:	(in <sup>2</sup> )	4.54	<b>Moisture Content:</b>	<b>(%)</b>	<b>16.4</b>
Volume:	(in <sup>3</sup> )	22.91	<b>Dry Density:</b>	<b>(pcf)</b>	<b>113.9</b>

### 2. Compression Test Data

**Curing Days:** -

Vertical Displ. (in)	Load (lbs)	q <sub>u</sub> (psf)	Strain (%)
0.0000	0.0	8.9	0.00
0.0033	2.5	88.7	0.07
0.0098	6.9	228.0	0.20
0.0163	9.7	317.1	0.32
0.0224	11.9	384.9	0.44
0.0289	13.9	446.5	0.57
0.0350	15.8	507.3	0.69
0.0415	17.6	563.6	0.82
0.0476	19.4	617.3	0.94
0.0654	23.6	747.2	1.30
0.0905	29.2	918.8	1.79
0.1161	33.8	1057.3	2.30
0.1412	38.1	1183.1	2.80
0.1664	41.7	1286.8	3.30
0.1915	44.7	1374.2	3.80
0.2171	47.7	1456.9	4.30
0.2423	49.2	1494.2	4.80
0.2774	50.8	1524.1	5.50
0.3408	47.8	1423.7	6.76
0.4037	41.1	1208.3	8.00



Failure of the specimen



# ANAHEIM TEST LAB, INC

196 Technology Drive, Unit D  
Irvine, CA 92618  
Phone (949)336-6544

TWINING LABS  
3310 AIRPORT WAY  
LONG BEACH, CA 90806

DATE: 12/16/2019

P.O. NO: Soils 121219

LAB NO: C-3446

SPECIFICATION: CTM-417/422/643

MATERIAL: Soil


Project No.: 190919.3  
Project: RMC  
Date sampled: 11/09/2019

## ANALYTICAL REPORT

### CORROSION SERIES SUMMARY OF DATA

	pH	SOLUBLE SULFATES per CT. 417 ppm	SOLUBLE CHLORIDES per CT. 422 ppm	MIN. RESISTIVITY per CT. 643 ohm-cm
B-1 Bulk Sample	7.1	313	104	1,400

RESPECTFULLY SUBMITTED



WES BRIDGER LAB MANAGER

# ANAHEIM TEST LAB, INC

196 Technology Drive, Unit D  
Irvine, CA 92618  
Phone (949)336-6544

TWINING LABS  
3310 AIRPORT WAY  
LONG BEACH, CA 90806

DATE: 3/22/2021

P.O. NO: Soils03172021

LAB NO: C-4646, 1-2

SPECIFICATION: CT-643/417/422

MATERIAL: Soil

---

Project No.: 190919.3  
Project: Kaiser Riverside  
WO#: W01-21-06060  
Sample Date: 3/13/2021

## ANALYTICAL REPORT

### CORROSION SERIES

#### SUMMARY OF DATA

	pH	MIN RESISTIVITY per CT. 643 ohm-cm	SOLUBLE SULFATES per CT. 417 ppm	SOLUBLE CHLORIDES per CT. 422 ppm
1) GP-2 Bulk Sample	6.8	1,600	374	131
2) PT-2 Bulk Sample	6.9	990	427	165

RESPECTFULLY SUBMITTED



---

WES BRIDGER LAB MANAGER



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

# APPENDIX C GEOPHYSICAL STUDY

December 19, 2019

Project No. 119634  
Report No. 1

Mr. Doug Crayton  
Twining, Inc.  
2883 East Spring Street, Suite 300  
Long Beach, California 90806

Subject: GEOPHYSICAL EVALUATION  
RIVERSIDE MEDICAL CENTER  
RIVERSIDE, CALIFORNIA

Dear Mr. Crayton:

In accordance with your authorization, we have performed geophysical study services pertaining to the Riverside Medical Center project (project number: 190919.3) located in Riverside, California (Figure 1). The purpose of our study was to develop a Shear-wave velocity profile to be used for design and construction parameters for a portion of the site. Our services were performed on December 7, 2019. This report presents the study methodology, equipment used, analysis, and findings from our study.

Our scope of services included the performance of a refraction microtremor (ReMi) profile (RL-1) at a preselected area of the project site (see Figure 2). The ReMi technique uses recorded surface waves (specifically Rayleigh waves) that are contained in background noise to develop a Shear-wave velocity profile of the study area down to a depth, in this case, of approximately 100 feet. The depth of exploration is dependent on the length of the line and the frequency content of the background noise. The results of the ReMi method are displayed as a one-dimensional sounding which represents the average condition across the length of the line. The ReMi method does not require an increase of material velocity with depth; therefore, low velocity zones (velocity inversions) are detectable with ReMi.

Our ReMi study included the use of a 24-channel Geometrics Geode seismograph and 24, 4.5-Hz vertical component geophones. The geophones were spaced 10 feet apart for a total line length of 230 feet. Fifteen records, each 32 seconds long, were recorded and then downloaded to a computer. The data were later processed using SeisOpt® ReMi™ software (© Optim LLC, 2005), which uses the refraction microtremor method (Louie, 2001). The program generates phase-velocity dispersion curves for each record and provides an interactive dispersion modeling tool where the users determine the best fitting model. The result is a one-dimensional shear-wave velocity model of the site with roughly 85 to 95 percent accuracy. Figure 3 depicts the general site conditions in the study area.

December 19, 2019

Figure 4 presents the results from our study. Based on our analysis of the collected data, the average characteristic site Shear-wave velocity down to a depth of 100 feet for RL-1 is 1,143 feet per second (CBC, 2016). This value corresponds to site classification of **D**. It should be noted the ReMi results represent the average condition across the length of the line.

The field evaluation and geophysical analyses presented in this report have been conducted in general accordance with current practice and the standard of care exercised by consultants performing similar tasks in the project area. No warranty, express or implied, is made regarding the conclusions and opinions presented in this report. There is no evaluation detailed enough to reveal every subsurface condition. Variations may exist and conditions not observed or described in this report may be present. Uncertainties relative to subsurface conditions can be reduced through additional subsurface exploration. Additional subsurface studying will be performed upon request.

This document is intended to be used only in its entirety. No portion of the document, by itself, is designed to completely represent any aspect of the project described herein. Southwest Geophysics should be contacted if the reader requires additional information or has questions regarding the content, interpretations presented, or completeness of this document. This report is intended exclusively for use by the client. Any use or reuse of the findings, conclusions, and/or recommendations of this report by parties other than the client is undertaken at said parties' sole risk.

We appreciate the opportunity to be of service on this project. Should you have any questions related to this report, please contact the undersigned at your convenience.

Respectfully submitted,  
**SOUTHWEST GEOPHYSICS, LLC**



Stephan A. Callas  
Staff Geophysicist

SAC:PFL:ds


Attachments:      Figure 1 – Site Location Map  
                            Figure 2 – Seismic Line Location Map (RL-1)  
                            Figure 3 – Site Photographs  
                            Figure 4 – ReMi Results (RL-1)



Patrick F. Lehrmann, P.G., Pg.  
Principal Geologist/Geophysicist



(1) Addressee via e-mail: Doug Crayton, dcrayton@twininginc.com



**SITE LOCATION MAP**




Riverside Medical Center  
Riverside, California

Project No.: 119634

Date: 12/19

**SOUTHWEST**  
GEOPHYSICS  
Figure 1



**LINE LOCATION MAP**  
(RL-1)




Riverside Medical Center  
Riverside, California


Project No.: 119634

Date: 12/19



Figure 2





**SITE PHOTOGRAPH**


Riverside Medical Center  
Riverside, California

 **SOUTHWEST  
GEOPHYSICS**  
Figure 3

Project No.: 119634

Date: 12/19

# Vs Model



**ReMi RESULTS  
RL-1**

Riverside Medical Center  
Riverside, California

Project No.: 119634

Date: 12/19

 **SOUTHWEST  
GEOPHYSICS**  
Figure 4



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

# APPENDIX D LIQUEFACTION ANALYSIS



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-1

**Location :** 10800 Magnolia Avenue, Riverside, California

### :: Input parameters and analysis properties ::

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




### F.S. color scheme

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

### LPI color scheme

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	15	65.00	136.00	5.00	No
10.00	16	65.00	136.00	5.00	No
15.00	33	65.00	139.00	5.00	No
20.00	13	68.50	139.00	5.00	Yes
25.00	20	65.00	134.00	5.00	No
30.00	9	55.00	134.00	5.00	No
35.00	16	30.00	120.00	5.00	Yes
40.00	13	55.00	120.00	5.00	No
45.00	46	30.00	110.00	5.00	Yes
50.00	25	35.00	110.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	15	136.00	0.34	0.00	0.34	0.31	1.43	1.25	1.15	0.80	1.20	30	65.00	5.59	36	4.000
10.00	16	136.00	0.68	0.00	0.68	0.34	1.16	1.25	1.15	0.85	1.20	27	65.00	5.59	33	4.000
15.00	33	139.00	1.03	0.00	1.03	0.26	1.01	1.25	1.15	0.95	1.20	54	65.00	5.59	60	4.000
20.00	13	139.00	1.38	0.00	1.38	0.41	0.90	1.25	1.15	0.95	1.20	19	68.50	5.58	25	0.290
25.00	20	134.00	1.71	0.00	1.71	0.35	0.85	1.25	1.15	0.95	1.20	28	65.00	5.59	34	4.000
30.00	9	134.00	2.05	0.00	2.05	0.48	0.73	1.25	1.15	1.00	1.20	11	55.00	5.61	17	4.000
35.00	16	120.00	2.35	0.00	2.35	0.41	0.72	1.25	1.15	1.00	1.20	20	30.00	5.36	25	0.290
40.00	13	120.00	2.65	0.00	2.65	0.45	0.66	1.25	1.15	1.00	1.20	15	55.00	5.61	21	4.000
45.00	46	110.00	2.92	0.00	2.92	0.26	0.77	1.25	1.15	1.00	1.20	61	30.00	5.36	66	4.000
50.00	25	110.00	3.20	0.00	3.20	0.34	0.69	1.25	1.15	1.00	1.20	30	35.00	5.51	36	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{I(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{I(60)cs}$ : Corrected  $N_{I(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	136.00	0.34	0.00	0.34	1.00	1.00	0.382	2.20	36	0.92	0.414	1.10	0.636	2.000 <span style="color: green;">●</span>	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
10.00	136.00	0.68	0.00	0.68	0.98	1.00	0.378	2.19	33	0.92	0.409	1.10	0.628	2.000	●
15.00	139.00	1.03	0.08	0.95	0.97	1.00	0.403	2.20	60	0.92	0.437	1.03	0.715	2.000	●
20.00	139.00	1.38	0.23	1.14	0.96	1.00	0.442	1.72	25	0.95	0.463	0.99	0.792	0.476	●
25.00	134.00	1.71	0.39	1.32	0.94	1.00	0.466	2.20	34	0.92	0.506	0.95	0.904	2.000	●
30.00	134.00	2.05	0.55	1.50	0.92	1.00	0.482	1.38	17	0.98	0.494	0.96	0.871	2.000	●
35.00	120.00	2.35	0.70	1.64	0.90	1.00	0.493	1.72	25	0.95	0.517	0.93	0.942	0.400	●
40.00	120.00	2.65	0.86	1.79	0.88	1.00	0.500	1.53	21	0.97	0.518	0.93	0.945	2.000	●
45.00	110.00	2.92	1.01	1.91	0.86	1.00	0.506	2.20	66	0.92	0.549	0.83	1.122	2.000	●
50.00	110.00	3.20	1.17	2.03	0.84	1.00	0.509	2.20	36	0.92	0.551	0.82	1.137	2.000	●

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	0.476	0.52	6.95	5.00	5.55
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00
35.00	0.400	0.60	4.67	5.00	4.26
40.00	2.000	0.00	3.90	5.00	0.00
45.00	2.000	0.00	3.14	5.00	0.00
50.00	2.000	0.00	2.38	5.00	0.00

**Overall potential I<sub>L</sub>: 9.82**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>Nc</sub> (%)	Δh (ft)	ΔS (in)
5.00	30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	(N <sub>1</sub> ) <sub>60</sub>	T <sub>av</sub>	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>N<sub>c</sub></sub> (%)	Δh (ft)	ΔS (in)

Cumulative settlements: 0.000

**Abbreviations**

- T<sub>av</sub>: Average cyclic shear stress
- p: Average stress
- G<sub>max</sub>: Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- γ: Average shear strain
- ε<sub>15</sub>: Volumetric strain after 15 cycles
- N<sub>c</sub>: Number of cycles
- ε<sub>N<sub>c</sub></sub>: Volumetric strain for number of cycles N<sub>c</sub> (%)
- Δh: Thickness of soil layer (in)
- ΔS: Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	(N <sub>1</sub> ) <sub>60cs</sub>	γ <sub>lim</sub> (%)	F <sub>a</sub>	FS <sub>liq</sub>	γ <sub>max</sub> (%)	e <sub>v</sub> (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)
15.00	60	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
20.00	25	8.88	0.23	0.476	8.88	1.90	5.00	1.138	0.00
25.00	34	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	17	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
35.00	25	8.88	0.23	0.400	8.88	1.90	5.00	1.138	0.00
40.00	21	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
45.00	66	0.00	-2.94	2.000	0.00	0.00	5.00	0.000	0.00
50.00	36	1.86	-0.51	2.000	0.00	0.00	5.00	0.000	0.00

Cumulative settlements: 2.276 0.00

**Abbreviations**

- γ<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- γ<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-2

**Location :** 10800 Magnolia Avenue, Riverside, California

**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




**F.S. color scheme**

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

**LPI color scheme**

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	5	53.40	128.00	5.00	No
10.00	53	55.00	139.00	5.00	No
15.00	34	55.00	139.00	5.00	Yes
20.00	35	55.00	121.00	5.00	Yes
25.00	32	15.00	121.00	5.00	Yes
30.00	18	55.00	127.00	5.00	No

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	5	128.00	0.32	0.00	0.32	0.43	1.68	1.25	1.15	0.80	1.20	12	53.40	5.61	18	4.000
10.00	53	139.00	0.67	0.00	0.67	0.26	1.13	1.25	1.15	0.85	1.20	88	55.00	5.61	94	4.000
15.00	34	139.00	1.01	0.00	1.01	0.26	1.01	1.25	1.15	0.95	1.20	56	55.00	5.61	62	4.000
20.00	35	121.00	1.32	0.00	1.32	0.26	0.94	1.25	1.15	0.95	1.20	54	55.00	5.61	60	4.000
25.00	32	121.00	1.62	0.00	1.62	0.26	0.89	1.25	1.15	0.95	1.20	47	15.00	3.26	50	4.000
30.00	18	127.00	1.94	0.00	1.94	0.37	0.80	1.25	1.15	1.00	1.20	25	55.00	5.61	31	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	128.00	0.32	0.00	0.32	1.00	1.00	0.382	1.42	18	0.97	0.393	1.10	0.603	2.000 ●	
10.00	139.00	0.67	0.00	0.67	0.98	1.00	0.378	2.20	94	0.92	0.409	1.10	0.629	2.000 ●	
15.00	139.00	1.01	0.08	0.94	0.97	1.00	0.403	2.20	62	0.92	0.437	1.04	0.713	2.000 ●	
20.00	121.00	1.32	0.23	1.08	0.96	1.00	0.446	2.20	60	0.92	0.483	0.99	0.822	2.000 ●	
25.00	121.00	1.62	0.39	1.23	0.94	1.00	0.474	2.20	50	0.92	0.514	0.96	0.909	2.000 ●	
30.00	127.00	1.94	0.55	1.39	0.92	1.00	0.492	2.06	31	0.93	0.528	0.94	0.947	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- $T_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_{\alpha}$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>a</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
15.00	62	0.00	-2.59	2.000	0.00	0.00	5.00	0.000	0.00
20.00	60	0.00	-2.42	2.000	0.00	0.00	5.00	0.000	0.00
25.00	50	0.04	-1.59	2.000	0.00	0.00	5.00	0.000	0.00
30.00	31	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements: 0.000 0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-3

**Location :** 10800 Magnolia Avenue, Riverside, California

### :: Input parameters and analysis properties ::

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




### F.S. color scheme

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

### LPI color scheme

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	10	70.00	110.00	5.00	No
10.00	26	75.90	110.00	5.00	No
15.00	31	75.00	122.00	5.00	No
20.00	40	5.10	122.00	5.00	Yes
25.00	31	70.00	107.00	5.00	No
30.00	26	63.60	107.00	5.00	No
35.00	53	15.00	121.00	5.00	Yes
40.00	38	15.00	121.00	5.00	Yes
45.00	42	15.00	113.00	5.00	Yes
50.00	21	81.70	113.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	10	110.00	0.28	0.00	0.28	0.35	1.61	1.25	1.15	0.80	1.20	22	70.00	5.57	28	4.000
10.00	26	110.00	0.55	0.00	0.55	0.26	1.19	1.25	1.15	0.85	1.20	45	75.90	5.56	51	4.000
15.00	31	122.00	0.86	0.00	0.86	0.26	1.06	1.25	1.15	0.95	1.20	54	75.00	5.56	60	4.000
20.00	40	122.00	1.16	0.00	1.16	0.26	0.98	1.25	1.15	0.95	1.20	64	5.10	0.00	64	4.000
25.00	31	107.00	1.43	0.00	1.43	0.26	0.92	1.25	1.15	0.95	1.20	47	70.00	5.57	53	4.000
30.00	26	107.00	1.70	0.00	1.70	0.27	0.88	1.25	1.15	1.00	1.20	39	63.60	5.59	45	4.000
35.00	53	121.00	2.00	0.00	2.00	0.26	0.85	1.25	1.15	1.00	1.20	77	15.00	3.26	80	4.000
40.00	38	121.00	2.30	0.00	2.30	0.26	0.82	1.25	1.15	1.00	1.20	53	15.00	3.26	56	4.000
45.00	42	113.00	2.58	0.00	2.58	0.26	0.79	1.25	1.15	1.00	1.20	57	15.00	3.26	60	4.000
50.00	21	113.00	2.87	0.00	2.87	0.37	0.69	1.25	1.15	1.00	1.20	25	81.70	5.54	31	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{I(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{I(60)cs}$ : Corrected  $N_{I(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	110.00	0.28	0.00	0.28	1.00	1.00	0.382	1.88	28	0.94	0.405	1.10	0.622	2.000 <span style="color: green;">●</span>	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
10.00	110.00	0.55	0.00	0.55	0.98	1.00	0.378	2.20	51	0.92	0.409	1.10	0.629	2.000	●
15.00	122.00	0.86	0.08	0.78	0.97	1.00	0.410	2.20	60	0.92	0.444	1.09	0.688	2.000	●
20.00	122.00	1.16	0.23	0.93	0.96	1.00	0.459	2.20	64	0.92	0.498	1.04	0.809	2.000	●
25.00	107.00	1.43	0.39	1.04	0.94	1.00	0.495	2.20	53	0.92	0.537	1.01	0.902	2.000	●
30.00	107.00	1.70	0.55	1.15	0.92	1.00	0.521	2.20	45	0.92	0.565	0.98	0.978	2.000	●
35.00	121.00	2.00	0.70	1.30	0.90	1.00	0.533	2.20	80	0.92	0.578	0.94	1.039	2.000	●
40.00	121.00	2.30	0.86	1.44	0.88	1.00	0.539	2.20	56	0.92	0.585	0.91	1.087	2.000	●
45.00	113.00	2.58	1.01	1.57	0.86	1.00	0.544	2.20	60	0.92	0.589	0.88	1.127	2.000	●
50.00	113.00	2.87	1.17	1.70	0.84	1.00	0.545	2.06	31	0.93	0.585	0.90	1.099	2.000	●

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00
35.00	2.000	0.00	4.67	5.00	0.00
40.00	2.000	0.00	3.90	5.00	0.00
45.00	2.000	0.00	3.14	5.00	0.00
50.00	2.000	0.00	2.38	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$\tau_{av}$	p	G <sub>max</sub> (tsf)	a	b	$\gamma$	$\epsilon_{15}$	N <sub>c</sub>	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	(N <sub>1</sub> ) <sub>60</sub>	T <sub>av</sub>	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>N<sub>c</sub></sub> (%)	Δh (ft)	ΔS (in)

Cumulative settlements: 0.000

**Abbreviations**

- T<sub>av</sub>: Average cyclic shear stress
- p: Average stress
- G<sub>max</sub>: Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- γ: Average shear strain
- ε<sub>15</sub>: Volumetric strain after 15 cycles
- N<sub>c</sub>: Number of cycles
- ε<sub>N<sub>c</sub></sub>: Volumetric strain for number of cycles N<sub>c</sub> (%)
- Δh: Thickness of soil layer (in)
- ΔS: Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	(N <sub>1</sub> ) <sub>60cs</sub>	γ <sub>lim</sub> (%)	F <sub>a</sub>	FS <sub>liq</sub>	γ <sub>max</sub> (%)	e <sub>v</sub> (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)
15.00	60	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
20.00	64	0.00	-2.77	2.000	0.00	0.00	5.00	0.000	0.00
25.00	53	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	45	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
35.00	80	0.00	-4.20	2.000	0.00	0.00	5.00	0.000	0.00
40.00	56	0.00	-2.08	2.000	0.00	0.00	5.00	0.000	0.00
45.00	60	0.00	-2.42	2.000	0.00	0.00	5.00	0.000	0.00
50.00	31	4.04	-0.16	2.000	0.00	0.00	5.00	0.000	0.00

Cumulative settlements: 0.000 0.00

**Abbreviations**

- γ<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- γ<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






Project title : New Tower at Kaiser Riverside Medical Center

SPT Name: B-4

Location : 10800 Magnolia Avenue, Riverside, California

### :: Input parameters and analysis properties ::

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




### F.S. color scheme

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

### LPI color scheme

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	5	70.00	128.00	5.00	No
10.00	53	83.80	130.00	5.00	No
15.00	34	65.10	130.00	5.00	No
20.00	35	5.10	103.00	5.00	Yes
25.00	32	70.00	103.00	5.00	No
30.00	18	75.00	124.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	5	128.00	0.32	0.00	0.32	0.43	1.68	1.25	1.15	0.80	1.20	12	70.00	5.57	18	4.000
10.00	53	130.00	0.65	0.00	0.65	0.26	1.14	1.25	1.15	0.85	1.20	89	83.80	5.53	95	4.000
15.00	34	130.00	0.97	0.00	0.97	0.26	1.02	1.25	1.15	0.95	1.20	57	65.10	5.59	63	4.000
20.00	35	103.00	1.23	0.00	1.23	0.26	0.96	1.25	1.15	0.95	1.20	55	5.10	0.00	55	4.000
25.00	32	103.00	1.49	0.00	1.49	0.26	0.91	1.25	1.15	0.95	1.20	48	70.00	5.57	54	4.000
30.00	18	124.00	1.80	0.00	1.80	0.36	0.83	1.25	1.15	1.00	1.20	26	75.00	5.56	32	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	128.00	0.32	0.00	0.32	1.00	1.00	0.382	1.42	18	0.97	0.393	1.10	0.603	2.000 ●	
10.00	130.00	0.65	0.00	0.65	0.98	1.00	0.378	2.20	95	0.92	0.409	1.10	0.629	2.000 ●	
15.00	130.00	0.97	0.08	0.89	0.97	1.00	0.405	2.20	63	0.92	0.439	1.05	0.706	2.000 ●	
20.00	103.00	1.23	0.23	0.99	0.96	1.00	0.453	2.20	55	0.92	0.491	1.02	0.814	2.000 ●	
25.00	103.00	1.49	0.39	1.10	0.94	1.00	0.488	2.20	54	0.92	0.529	0.99	0.903	2.000 ●	
30.00	124.00	1.80	0.55	1.25	0.92	1.00	0.507	2.12	32	0.93	0.547	0.96	0.960	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR: Cyclic Stress Ratio
- MSF: Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	89	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- $T_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_{\alpha}$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>a</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
15.00	63	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
20.00	55	0.00	-2.00	2.000	0.00	0.00	5.00	0.000	0.00
25.00	54	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	32	3.50	-0.22	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements: 0.000 0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-5

**Location :** 10800 Magnolia Avenue, Riverside, California

**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




**F.S. color scheme**

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

**LPI color scheme**

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	6	70.00	128.00	5.00	No
10.00	65	70.00	136.00	5.00	No
15.00	17	75.00	136.00	5.00	Yes
20.00	33	10.00	115.00	5.00	Yes
25.00	14	75.00	115.00	5.00	No
30.00	36	15.00	128.00	5.00	Yes
35.00	33	15.00	128.00	5.00	Yes
40.00	16	75.00	120.00	5.00	No
45.00	38	7.50	120.00	5.00	Yes
50.00	65	15.00	106.00	5.00	Yes
55.00	22	10.00	106.00	5.00	Yes
60.00	65	5.00	140.00	5.00	Yes
70.00	15	5.00	140.00	5.00	Yes
80.00	65	15.00	140.00	5.00	Yes
90.00	43	15.00	140.00	5.00	Yes

**Abbreviations**

- Depth: Depth at which test was performed (ft)
- SPT Field Value: Number of blows per foot
- Fines Content: Fines content at test depth (%)
- Unit Weight: Unit weight at test depth (pcf)
- Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)
- Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	6	128.00	0.32	0.00	0.32	0.42	1.65	1.25	1.15	0.80	1.20	14	70.00	5.57	20	4.000
10.00	65	136.00	0.66	0.00	0.66	0.26	1.13	1.25	1.15	0.85	1.20	108	70.00	5.57	114	4.000
15.00	17	136.00	1.00	0.00	1.00	0.34	1.02	1.25	1.15	0.95	1.20	28	75.00	5.56	34	4.000
20.00	33	115.00	1.29	0.00	1.29	0.26	0.95	1.25	1.15	0.95	1.20	51	10.00	1.15	52	4.000
25.00	14	115.00	1.58	0.00	1.58	0.41	0.85	1.25	1.15	0.95	1.20	20	75.00	5.56	26	4.000
30.00	36	128.00	1.90	0.00	1.90	0.26	0.86	1.25	1.15	1.00	1.20	53	15.00	3.26	56	4.000
35.00	33	128.00	2.22	0.00	2.22	0.26	0.82	1.25	1.15	1.00	1.20	47	15.00	3.26	50	4.000
40.00	16	120.00	2.52	0.00	2.52	0.41	0.70	1.25	1.15	1.00	1.20	19	75.00	5.56	25	4.000
45.00	38	120.00	2.82	0.00	2.82	0.26	0.77	1.25	1.15	1.00	1.20	51	7.50	0.23	51	4.000
50.00	65	106.00	3.08	0.00	3.08	0.26	0.75	1.25	1.15	1.00	1.20	85	15.00	3.26	88	4.000
55.00	22	106.00	3.35	0.00	3.35	0.40	0.63	1.25	1.15	1.00	1.20	24	10.00	1.15	25	4.000
60.00	65	140.00	3.70	0.08	3.62	0.26	0.72	1.25	1.15	1.00	1.20	81	5.00	0.00	81	4.000
70.00	15	140.00	4.39	0.39	4.01	0.50	0.51	1.25	1.15	1.00	1.20	13	5.00	0.00	13	4.000
80.00	65	140.00	5.10	0.70	4.39	0.26	0.69	1.25	1.15	1.00	1.20	77	15.00	3.26	80	4.000
90.00	43	140.00	5.80	1.01	4.78	0.26	0.67	1.25	1.15	1.00	1.20	50	15.00	3.26	53	4.000

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>

**Abbreviations**

- $\sigma_v$ : Total stress during SPT test (tsf)
- $u_o$ : Water pore pressure during SPT test (tsf)
- $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)
- m: Stress exponent normalization factor
- $C_N$ : Overburden correction factor
- $C_E$ : Energy correction factor
- $C_B$ : Borehole diameter correction factor
- $C_R$ : Rod length correction factor
- $C_S$ : Liner correction factor
- $N_{I(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio
- $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment
- $N_{I(60)cs}$ : Corrected  $N_{I(60)}$  value for fines content
- CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	128.00	0.32	0.00	0.32	1.00	1.00	0.382	1.49	20	0.97	0.395	1.10	0.606	2.000	●
10.00	136.00	0.66	0.00	0.66	0.98	1.00	0.378	2.20	114	0.92	0.409	1.10	0.629	2.000	●
15.00	136.00	1.00	0.08	0.92	0.97	1.00	0.404	2.20	34	0.92	0.438	1.03	0.715	2.000	●
20.00	115.00	1.29	0.23	1.05	0.96	1.00	0.448	2.20	52	0.92	0.485	1.00	0.819	2.000	●
25.00	115.00	1.58	0.39	1.19	0.94	1.00	0.478	1.77	26	0.95	0.504	0.98	0.868	2.000	●
30.00	128.00	1.90	0.55	1.35	0.92	1.00	0.496	2.20	56	0.92	0.538	0.93	0.979	2.000	●
35.00	128.00	2.22	0.70	1.51	0.90	1.00	0.506	2.20	50	0.92	0.549	0.89	1.037	2.000	●
40.00	120.00	2.52	0.86	1.66	0.88	1.00	0.513	1.72	25	0.95	0.538	0.93	0.981	2.000	●
45.00	120.00	2.82	1.01	1.80	0.86	1.00	0.516	2.20	51	0.92	0.560	0.84	1.122	2.000	●
50.00	106.00	3.08	1.17	1.91	0.84	1.00	0.520	2.20	88	0.92	0.564	0.83	1.153	2.000	●
55.00	106.00	3.35	1.33	2.02	0.82	1.00	0.521	1.72	25	0.95	0.546	0.89	1.032	2.000	●
60.00	140.00	3.70	1.48	2.21	0.80	1.00	0.512	2.20	81	0.92	0.555	0.78	1.199	2.000	●
70.00	140.00	4.39	1.79	2.60	0.76	1.00	0.493	1.26	13	0.98	0.501	0.91	0.933	2.000	●
80.00	140.00	5.10	2.11	2.99	0.72	1.00	0.473	2.20	80	0.92	0.513	0.69	1.250	2.000	●
90.00	140.00	5.80	2.42	3.38	0.69	1.00	0.456	2.20	53	0.92	0.494	0.66	1.270	2.000	●

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
  - $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
  - $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
  - $r_d$ : Nonlinear shear mass factor
  - $\alpha$ : Improvement factor due to stone columns
  - CSR : Cyclic Stress Ratio
  - MSF : Magnitude Scaling Factor
  - CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
  - $K_{\sigma}$ : Effective overburden stress factor
  - CSR\*: CSR fully adjusted (user FS applied)\*\*\*
  - FS: Calculated factor of safety against soil liquefaction
- \*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	$I_L$
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00
35.00	2.000	0.00	4.67	5.00	0.00
40.00	2.000	0.00	3.90	5.00	0.00
45.00	2.000	0.00	3.14	5.00	0.00
50.00	2.000	0.00	2.38	5.00	0.00
55.00	2.000	0.00	1.62	5.00	0.00
60.00	2.000	0.00	0.86	5.00	0.00
70.00	2.000	0.00	0.00	0.00	0.00
80.00	2.000	0.00	0.00	0.00	0.00
90.00	2.000	0.00	0.00	0.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

I<sub>L</sub> = 0.00 - No liquefaction  
 I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable  
 I<sub>L</sub> between 5 and 15 - Liquefaction probable  
 I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	(N <sub>1</sub> ) <sub>60</sub>	τ <sub>av</sub>	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>Nc</sub> (%)	Δh (ft)	ΔS (in)
5.00	14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	108	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- τ<sub>av</sub>: Average cyclic shear stress
- p: Average stress
- G<sub>max</sub>: Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- γ: Average shear strain
- ε<sub>15</sub>: Volumetric strain after 15 cycles
- N<sub>c</sub>: Number of cycles
- ε<sub>Nc</sub>: Volumetric strain for number of cycles N<sub>c</sub> (%)
- Δh: Thickness of soil layer (in)
- ΔS: Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	(N <sub>1</sub> ) <sub>60cs</sub>	γ <sub>lim</sub> (%)	F <sub>a</sub>	FS <sub>liq</sub>	γ <sub>max</sub> (%)	e <sub>v</sub> (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)
15.00	34	2.58	-0.36	2.000	0.00	0.00	5.00	0.000	0.00
20.00	52	0.01	-1.75	2.000	0.00	0.00	5.00	0.000	0.00
25.00	26	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	56	0.00	-2.08	2.000	0.00	0.00	5.00	0.000	0.00
35.00	50	0.04	-1.59	2.000	0.00	0.00	5.00	0.000	0.00
40.00	25	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
45.00	51	0.02	-1.67	2.000	0.00	0.00	5.00	0.000	0.00
50.00	88	0.00	-4.94	2.000	0.00	0.00	5.00	0.000	0.00

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>α</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
55.00	25	8.88	0.23	2.000	0.00	0.00	5.00	0.000	0.00
60.00	81	0.00	-4.29	2.000	0.00	0.00	5.00	0.000	0.00
70.00	13	34.14	0.83	2.000	0.00	0.00	5.00	0.000	0.00
80.00	80	0.00	-4.20	2.000	0.00	0.00	5.00	0.000	0.00
90.00	53	0.00	-1.83	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements: 0.000 0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>α</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-6

**Location :** 10800 Magnolia Avenue, Riverside, California

**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




**F.S. color scheme**

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

**LPI color scheme**

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	11	64.80	128.00	5.00	No
10.00	32	65.00	126.00	5.00	No
15.00	30	70.00	126.00	5.00	No
20.00	31	70.00	127.00	5.00	No
25.00	19	82.20	127.00	5.00	No
30.00	45	15.00	106.00	5.00	Yes
35.00	41	5.00	106.00	5.00	Yes
40.00	16	71.70	118.00	5.00	No
45.00	50	75.00	118.00	5.00	No
50.00	65	75.00	118.00	5.00	No

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	11	128.00	0.32	0.00	0.32	0.35	1.52	1.25	1.15	0.80	1.20	23	64.80	5.59	29	4.000
10.00	32	126.00	0.64	0.00	0.64	0.26	1.14	1.25	1.15	0.85	1.20	54	65.00	5.59	60	4.000
15.00	30	126.00	0.95	0.00	0.95	0.26	1.03	1.25	1.15	0.95	1.20	51	70.00	5.57	57	4.000
20.00	31	127.00	1.27	0.00	1.27	0.26	0.95	1.25	1.15	0.95	1.20	48	70.00	5.57	54	4.000
25.00	19	127.00	1.59	0.00	1.59	0.35	0.87	1.25	1.15	0.95	1.20	27	82.20	5.54	33	4.000
30.00	45	106.00	1.85	0.00	1.85	0.26	0.86	1.25	1.15	1.00	1.20	67	15.00	3.26	70	4.000
35.00	41	106.00	2.12	0.00	2.12	0.26	0.83	1.25	1.15	1.00	1.20	59	5.00	0.00	59	4.000
40.00	16	118.00	2.41	0.00	2.41	0.41	0.71	1.25	1.15	1.00	1.20	20	71.70	5.57	26	4.000
45.00	50	118.00	2.71	0.00	2.71	0.26	0.78	1.25	1.15	1.00	1.20	67	75.00	5.56	73	4.000
50.00	65	118.00	3.00	0.00	3.00	0.26	0.76	1.25	1.15	1.00	1.20	85	75.00	5.56	91	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{I(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{I(60)cs}$ : Corrected  $N_{I(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	128.00	0.32	0.00	0.32	1.00	1.00	0.382	1.94	29	0.94	0.407	1.10	0.625	2.000 <span style="color: green;">●</span>	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS
10.00	126.00	0.64	0.00	0.64	0.98	1.00	0.378	2.20	60	0.92	0.409	1.10	0.629	2.000
15.00	126.00	0.95	0.08	0.87	0.97	1.00	0.406	2.20	57	0.92	0.440	1.06	0.703	2.000
20.00	127.00	1.27	0.23	1.03	0.96	1.00	0.449	2.20	54	0.92	0.487	1.01	0.818	2.000
25.00	127.00	1.59	0.39	1.20	0.94	1.00	0.477	2.19	33	0.92	0.517	0.97	0.900	2.000
30.00	106.00	1.85	0.55	1.30	0.92	1.00	0.501	2.20	70	0.92	0.543	0.94	0.978	2.000
35.00	106.00	2.12	0.70	1.41	0.90	1.00	0.517	2.20	59	0.92	0.561	0.91	1.036	2.000
40.00	118.00	2.41	0.86	1.55	0.88	1.00	0.525	1.77	26	0.95	0.553	0.94	0.999	2.000
45.00	118.00	2.71	1.01	1.69	0.86	1.00	0.528	2.20	73	0.92	0.573	0.86	1.123	2.000
50.00	118.00	3.00	1.17	1.83	0.84	1.00	0.528	2.20	91	0.92	0.573	0.84	1.155	2.000

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00
35.00	2.000	0.00	4.67	5.00	0.00
40.00	2.000	0.00	3.90	5.00	0.00
45.00	2.000	0.00	3.14	5.00	0.00
50.00	2.000	0.00	2.38	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>Nc</sub> (%)	Δh (ft)	ΔS (in)
5.00	23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	54	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	(N <sub>1</sub> ) <sub>60</sub>	T <sub>av</sub>	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>N<sub>c</sub></sub> (%)	Δh (ft)	ΔS (in)

Cumulative settlements: 0.000

**Abbreviations**

- T<sub>av</sub>: Average cyclic shear stress
- p: Average stress
- G<sub>max</sub>: Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- γ: Average shear strain
- ε<sub>15</sub>: Volumetric strain after 15 cycles
- N<sub>c</sub>: Number of cycles
- ε<sub>N<sub>c</sub></sub>: Volumetric strain for number of cycles N<sub>c</sub> (%)
- Δh: Thickness of soil layer (in)
- ΔS: Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	(N <sub>1</sub> ) <sub>60cs</sub>	γ <sub>lim</sub> (%)	F <sub>a</sub>	FS <sub>liq</sub>	γ <sub>max</sub> (%)	e <sub>v</sub> (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)
15.00	57	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
20.00	54	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
25.00	33	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	70	0.00	-3.30	2.000	0.00	0.00	5.00	0.000	0.00
35.00	59	0.00	-2.34	2.000	0.00	0.00	5.00	0.000	0.00
40.00	26	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
45.00	73	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
50.00	91	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00

Cumulative settlements: 0.000 0.00

**Abbreviations**

- γ<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- γ<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-7

**Location :** 10800 Magnolia Avenue, Riverside, California

### :: Input parameters and analysis properties ::

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




### F.S. color scheme

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

### LPI color scheme

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	18	70.00	131.00	5.00	No
10.00	39	78.10	131.00	5.00	No
15.00	31	75.00	125.00	5.00	Yes
20.00	19	15.00	125.00	5.00	Yes
25.00	17	10.00	130.00	5.00	Yes
30.00	11	70.00	130.00	5.00	No

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	18	131.00	0.33	0.00	0.33	0.28	1.39	1.25	1.15	0.80	1.20	35	70.00	5.57	41	4.000
10.00	39	131.00	0.66	0.00	0.66	0.26	1.13	1.25	1.15	0.85	1.20	65	78.10	5.55	71	4.000
15.00	31	125.00	0.97	0.00	0.97	0.26	1.02	1.25	1.15	0.95	1.20	52	75.00	5.56	58	4.000
20.00	19	125.00	1.28	0.00	1.28	0.35	0.94	1.25	1.15	0.95	1.20	29	15.00	3.26	32	4.000
25.00	17	130.00	1.61	0.00	1.61	0.40	0.85	1.25	1.15	0.95	1.20	24	10.00	1.15	25	0.290
30.00	11	130.00	1.93	0.00	1.93	0.45	0.76	1.25	1.15	1.00	1.20	14	70.00	5.57	20	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	131.00	0.33	0.00	0.33	1.00	1.00	0.382	2.20	41	0.92	0.414	1.10	0.636	2.000 ●	
10.00	131.00	0.66	0.00	0.66	0.98	1.00	0.378	2.20	71	0.92	0.409	1.10	0.629	2.000 ●	
15.00	125.00	0.97	0.08	0.89	0.97	1.00	0.405	2.20	58	0.92	0.439	1.05	0.706	2.000 ●	
20.00	125.00	1.28	0.23	1.05	0.96	1.00	0.448	2.12	32	0.93	0.483	1.00	0.815	2.000 ●	
25.00	130.00	1.61	0.39	1.22	0.94	1.00	0.475	1.72	25	0.95	0.499	0.98	0.862	0.437 ●	
30.00	130.00	1.93	0.55	1.38	0.92	1.00	0.492	1.49	20	0.97	0.508	0.96	0.891	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\* : CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	0.437	0.56	6.19	5.00	5.31
30.00	2.000	0.00	5.43	5.00	0.00

**Overall potential I<sub>L</sub> : 5.31**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- $T_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_{\alpha}$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>α</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
15.00	58	0.00	-2.25	2.000	0.00	0.00	5.00	0.000	0.00
20.00	32	3.50	-0.22	2.000	0.00	0.00	5.00	0.000	0.00
25.00	25	8.88	0.23	0.437	8.88	1.90	5.00	1.138	0.00
30.00	20	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements:    1.138    0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>α</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-8

**Location :** 10800 Magnolia Avenue, Riverside, California


**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		



- F.S. color scheme**
- Almost certain it will liquefy
  - Very likely to liquefy
  - Liquefaction and no liq. are equally likely
  - Unlike to liquefy
  - Almost certain it will not liquefy
- LPI color scheme**
- Very high risk
  - High risk
  - Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	5	70.00	120.00	5.00	No
10.00	24	70.00	135.00	5.00	No
15.00	21	75.00	135.00	5.00	No
20.00	17	68.30	120.00	5.00	No
25.00	15	70.00	120.00	5.00	No
30.00	21	70.00	125.00	5.00	No
35.00	42	4.80	125.00	5.00	Yes
40.00	34	5.00	123.00	5.00	Yes
45.00	41	6.50	123.00	5.00	Yes
50.00	65	5.00	105.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	5	120.00	0.30	0.00	0.30	0.43	1.70	1.25	1.15	0.80	1.20	12	70.00	5.57	18	4.000
10.00	24	135.00	0.64	0.00	0.64	0.26	1.14	1.25	1.15	0.85	1.20	40	70.00	5.57	46	4.000
15.00	21	135.00	0.98	0.00	0.98	0.29	1.02	1.25	1.15	0.95	1.20	35	75.00	5.56	41	4.000
20.00	17	120.00	1.27	0.00	1.27	0.35	0.94	1.25	1.15	0.95	1.20	26	68.30	5.58	32	4.000
25.00	15	120.00	1.58	0.00	1.58	0.39	0.85	1.25	1.15	0.95	1.20	21	70.00	5.57	27	4.000
30.00	21	125.00	1.89	0.00	1.89	0.33	0.82	1.25	1.15	1.00	1.20	30	70.00	5.57	36	4.000
35.00	42	125.00	2.20	0.00	2.20	0.26	0.82	1.25	1.15	1.00	1.20	60	4.80	0.00	60	4.000
40.00	34	123.00	2.51	0.00	2.51	0.26	0.80	1.25	1.15	1.00	1.20	47	5.00	0.00	47	4.000
45.00	41	123.00	2.82	0.00	2.82	0.26	0.77	1.25	1.15	1.00	1.20	55	6.50	0.07	55	4.000
50.00	65	105.00	3.08	0.00	3.08	0.26	0.76	1.25	1.15	1.00	1.20	85	5.00	0.00	85	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{I(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{I(60)cs}$ : Corrected  $N_{I(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	120.00	0.30	0.00	0.30	1.00	1.00	0.382	1.42	18	0.97	0.393	1.10	0.603	2.000 <span style="color: green;">●</span>	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS
10.00	135.00	0.64	0.00	0.64	0.98	1.00	0.378	2.20	46	0.92	0.409	1.10	0.629	2.000
15.00	135.00	0.98	0.08	0.90	0.97	1.00	0.405	2.20	41	0.92	0.439	1.05	0.707	2.000
20.00	120.00	1.27	0.23	1.04	0.96	1.00	0.449	2.12	32	0.93	0.484	1.00	0.815	2.000
25.00	120.00	1.58	0.39	1.19	0.94	1.00	0.478	1.82	27	0.95	0.505	0.98	0.872	2.000
30.00	125.00	1.89	0.55	1.34	0.92	1.00	0.497	2.20	36	0.92	0.538	0.93	0.974	2.000
35.00	125.00	2.20	0.70	1.50	0.90	1.00	0.508	2.20	60	0.92	0.550	0.90	1.036	2.000
40.00	123.00	2.51	0.86	1.65	0.88	1.00	0.514	2.20	47	0.92	0.557	0.87	1.084	2.000
45.00	123.00	2.82	1.01	1.80	0.86	1.00	0.516	2.20	55	0.92	0.560	0.84	1.122	2.000
50.00	105.00	3.08	1.17	1.91	0.84	1.00	0.520	2.20	85	0.92	0.564	0.83	1.153	2.000

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq, M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00
35.00	2.000	0.00	4.67	5.00	0.00
40.00	2.000	0.00	3.90	5.00	0.00
45.00	2.000	0.00	3.14	5.00	0.00
50.00	2.000	0.00	2.38	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	(N <sub>1</sub> ) <sub>60</sub>	T <sub>av</sub>	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>N<sub>c</sub></sub> (%)	Δh (ft)	ΔS (in)

Cumulative settlements: 0.000

**Abbreviations**

- T<sub>av</sub>: Average cyclic shear stress
- p: Average stress
- G<sub>max</sub>: Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- γ: Average shear strain
- ε<sub>15</sub>: Volumetric strain after 15 cycles
- N<sub>c</sub>: Number of cycles
- ε<sub>N<sub>c</sub></sub>: Volumetric strain for number of cycles N<sub>c</sub> (%)
- Δh: Thickness of soil layer (in)
- ΔS: Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	(N <sub>1</sub> ) <sub>60cs</sub>	γ <sub>lim</sub> (%)	F <sub>a</sub>	FS <sub>liq</sub>	γ <sub>max</sub> (%)	e <sub>v</sub> (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)
15.00	41	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
20.00	32	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
25.00	27	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	36	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
35.00	60	0.00	-2.42	2.000	0.00	0.00	5.00	0.000	0.00
40.00	47	0.13	-1.35	2.000	0.00	0.00	5.00	0.000	0.00
45.00	55	0.00	-2.00	2.000	0.00	0.00	5.00	0.000	0.00
50.00	85	0.00	-4.66	2.000	0.00	0.00	5.00	0.000	0.00

Cumulative settlements: 0.000 0.00

**Abbreviations**

- γ<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- γ<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






Project title : New Tower at Kaiser Riverside Medical Center

SPT Name: B-9

Location : 10800 Magnolia Avenue, Riverside, California

### :: Input parameters and analysis properties ::

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




### F.S. color scheme

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

### LPI color scheme

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	8	70.00	131.00	5.00	No
10.00	10	70.00	131.00	5.00	No
15.00	9	70.00	124.00	5.00	No
20.00	20	75.00	124.00	5.00	Yes
25.00	22	15.00	130.00	5.00	Yes
30.00	18	70.00	130.00	5.00	No

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	8	131.00	0.33	0.00	0.33	0.39	1.58	1.25	1.15	0.80	1.20	17	70.00	5.57	23	4.000
10.00	10	131.00	0.66	0.00	0.66	0.40	1.21	1.25	1.15	0.85	1.20	18	70.00	5.57	24	4.000
15.00	9	124.00	0.97	0.00	0.97	0.43	1.04	1.25	1.15	0.95	1.20	15	70.00	5.57	21	4.000
20.00	20	124.00	1.27	0.00	1.27	0.32	0.94	1.25	1.15	0.95	1.20	31	75.00	5.56	37	4.000
25.00	22	130.00	1.60	0.00	1.60	0.33	0.87	1.25	1.15	0.95	1.20	31	15.00	3.26	34	4.000
30.00	18	130.00	1.93	0.00	1.93	0.37	0.80	1.25	1.15	1.00	1.20	25	70.00	5.57	31	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	131.00	0.33	0.00	0.33	1.00	1.00	0.382	1.62	23	0.96	0.398	1.10	0.612	2.000 ●	
10.00	131.00	0.66	0.00	0.66	0.98	1.00	0.378	1.67	24	0.96	0.395	1.07	0.621	2.000 ●	
15.00	124.00	0.97	0.08	0.89	0.97	1.00	0.405	1.53	21	0.97	0.420	1.02	0.692	2.000 ●	
20.00	124.00	1.27	0.23	1.04	0.96	1.00	0.449	2.20	37	0.92	0.487	1.00	0.818	2.000 ●	
25.00	130.00	1.60	0.39	1.21	0.94	1.00	0.476	2.20	34	0.92	0.516	0.97	0.902	2.000 ●	
30.00	130.00	1.93	0.55	1.38	0.92	1.00	0.493	2.06	31	0.93	0.529	0.94	0.947	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\* : CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00

**Overall potential I<sub>L</sub> : 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- $T_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_{\alpha}$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>α</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
15.00	21	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
20.00	37	1.56	-0.58	2.000	0.00	0.00	5.00	0.000	0.00
25.00	34	2.58	-0.36	2.000	0.00	0.00	5.00	0.000	0.00
30.00	31	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements: 0.000 0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>α</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






Project title : New Tower at Kaiser Riverside Medical Center

SPT Name: B-10

Location : 10800 Magnolia Avenue, Riverside, California

### :: Input parameters and analysis properties ::

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




### F.S. color scheme

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

### LPI color scheme

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	10	58.90	128.00	5.00	No
10.00	6	55.00	132.00	5.00	No
15.00	18	68.90	132.00	5.00	No
20.00	16	15.00	125.00	5.00	No
25.00	16	55.10	125.00	5.00	No
30.00	19	55.00	127.00	5.00	No

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	10	128.00	0.32	0.00	0.32	0.36	1.54	1.25	1.15	0.80	1.20	21	58.90	5.60	27	4.000
10.00	6	132.00	0.65	0.00	0.65	0.46	1.25	1.25	1.15	0.85	1.20	11	55.00	5.61	17	4.000
15.00	18	132.00	0.98	0.00	0.98	0.32	1.03	1.25	1.15	0.95	1.20	30	68.90	5.58	36	4.000
20.00	16	125.00	1.29	0.00	1.29	0.38	0.93	1.25	1.15	0.95	1.20	24	15.00	3.26	27	4.000
25.00	16	125.00	1.61	0.00	1.61	0.38	0.85	1.25	1.15	0.95	1.20	22	55.10	5.61	28	4.000
30.00	19	127.00	1.92	0.00	1.92	0.36	0.81	1.25	1.15	1.00	1.20	26	55.00	5.61	32	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	128.00	0.32	0.00	0.32	1.00	1.00	0.382	1.82	27	0.95	0.404	1.10	0.620	2.000 ●	
10.00	132.00	0.65	0.00	0.65	0.98	1.00	0.378	1.38	17	0.98	0.387	1.06	0.618	2.000 ●	
15.00	132.00	0.98	0.08	0.90	0.97	1.00	0.405	2.20	36	0.92	0.439	1.04	0.710	2.000 ●	
20.00	125.00	1.29	0.23	1.06	0.96	1.00	0.447	1.82	27	0.95	0.473	1.00	0.799	2.000 ●	
25.00	125.00	1.61	0.39	1.22	0.94	1.00	0.475	1.88	28	0.94	0.504	0.97	0.874	2.000 ●	
30.00	127.00	1.92	0.55	1.38	0.92	1.00	0.493	2.12	32	0.93	0.532	0.94	0.954	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- $T_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_{\alpha}$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>α</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
15.00	36	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
20.00	27	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
25.00	28	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	32	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements: 0.000 0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>α</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






Project title : New Tower at Kaiser Riverside Medical Center

SPT Name: B-11

Location : 10800 Magnolia Avenue, Riverside, California

### :: Input parameters and analysis properties ::

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




### F.S. color scheme

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

### LPI color scheme

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	3	55.00	128.00	5.00	No
10.00	23	55.00	134.00	5.00	No
15.00	26	95.00	134.00	5.00	Yes
20.00	25	95.00	125.00	5.00	Yes
25.00	19	55.00	125.00	5.00	No
30.00	24	55.00	131.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	3	128.00	0.32	0.00	0.32	0.47	1.70	1.25	1.15	0.80	1.20	7	55.00	5.61	13	4.000
10.00	23	134.00	0.66	0.00	0.66	0.27	1.14	1.25	1.15	0.85	1.20	38	55.00	5.61	44	4.000
15.00	26	134.00	0.99	0.00	0.99	0.26	1.02	1.25	1.15	0.95	1.20	43	95.00	5.50	49	4.000
20.00	25	125.00	1.30	0.00	1.30	0.28	0.94	1.25	1.15	0.95	1.20	39	95.00	5.50	45	4.000
25.00	19	125.00	1.62	0.00	1.62	0.35	0.86	1.25	1.15	0.95	1.20	27	55.00	5.61	33	4.000
30.00	24	131.00	1.94	0.00	1.94	0.30	0.83	1.25	1.15	1.00	1.20	34	55.00	5.61	40	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	128.00	0.32	0.00	0.32	1.00	1.00	0.382	1.26	13	0.98	0.389	1.10	0.597	2.000 ●	
10.00	134.00	0.66	0.00	0.66	0.98	1.00	0.378	2.20	44	0.92	0.409	1.10	0.629	2.000 ●	
15.00	134.00	0.99	0.08	0.91	0.97	1.00	0.404	2.20	49	0.92	0.438	1.04	0.709	2.000 ●	
20.00	125.00	1.30	0.23	1.07	0.96	1.00	0.447	2.20	45	0.92	0.484	1.00	0.821	2.000 ●	
25.00	125.00	1.62	0.39	1.23	0.94	1.00	0.475	2.19	33	0.92	0.514	0.97	0.900	2.000 ●	
30.00	131.00	1.94	0.55	1.40	0.92	1.00	0.491	2.20	40	0.92	0.532	0.92	0.980	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR: Cyclic Stress Ratio
- MSF: Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- $T_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_{\alpha}$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>α</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
15.00	49	0.06	-1.51	2.000	0.00	0.00	5.00	0.000	0.00
20.00	45	0.25	-1.19	2.000	0.00	0.00	5.00	0.000	0.00
25.00	33	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	40	0.87	-0.80	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements: 0.000 0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>α</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-12

**Location :** 10800 Magnolia Avenue, Riverside, California

**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




**F.S. color scheme**

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

**LPI color scheme**

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	10	55.00	128.00	5.00	No
10.00	31	55.00	136.00	5.00	No
15.00	49	75.00	136.00	5.00	Yes
20.00	32	75.00	124.00	5.00	Yes
25.00	36	19.40	124.00	5.00	Yes
30.00	19	25.00	127.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	10	128.00	0.32	0.00	0.32	0.36	1.54	1.25	1.15	0.80	1.20	21	55.00	5.61	27	4.000
10.00	31	136.00	0.66	0.00	0.66	0.26	1.13	1.25	1.15	0.85	1.20	51	55.00	5.61	57	4.000
15.00	49	136.00	1.00	0.00	1.00	0.26	1.01	1.25	1.15	0.95	1.20	82	75.00	5.56	88	4.000
20.00	32	124.00	1.31	0.00	1.31	0.26	0.95	1.25	1.15	0.95	1.20	50	75.00	5.56	56	4.000
25.00	36	124.00	1.62	0.00	1.62	0.26	0.89	1.25	1.15	0.95	1.20	53	19.40	4.37	57	4.000
30.00	19	127.00	1.94	0.00	1.94	0.36	0.80	1.25	1.15	1.00	1.20	26	25.00	5.07	31	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	128.00	0.32	0.00	0.32	1.00	1.00	0.382	1.82	27	0.95	0.404	1.10	0.620	2.000 ●	
10.00	136.00	0.66	0.00	0.66	0.98	1.00	0.378	2.20	57	0.92	0.409	1.10	0.629	2.000 ●	
15.00	136.00	1.00	0.08	0.92	0.97	1.00	0.404	2.20	88	0.92	0.438	1.04	0.711	2.000 ●	
20.00	124.00	1.31	0.23	1.08	0.96	1.00	0.446	2.20	56	0.92	0.484	1.00	0.821	2.000 ●	
25.00	124.00	1.62	0.39	1.23	0.94	1.00	0.474	2.20	57	0.92	0.514	0.96	0.909	2.000 ●	
30.00	127.00	1.94	0.55	1.39	0.92	1.00	0.492	2.06	31	0.93	0.528	0.94	0.947	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- $T_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_{\alpha}$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>a</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
15.00	88	0.00	-4.94	2.000	0.00	0.00	5.00	0.000	0.00
20.00	56	0.00	-2.08	2.000	0.00	0.00	5.00	0.000	0.00
25.00	57	0.00	-2.17	2.000	0.00	0.00	5.00	0.000	0.00
30.00	31	4.04	-0.16	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements: 0.000 0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



## SPT BASED LIQUEFACTION ANALYSIS REPORT






**Project title :** New Tower at Kaiser Riverside Medical Center

**SPT Name:** B-13

**Location :** 10800 Magnolia Avenue, Riverside, California

**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	5.00 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




**F.S. color scheme**

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

**LPI color scheme**

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	8	55.00	128.00	5.00	No
10.00	10	55.00	132.00	5.00	No
15.00	36	67.40	132.00	5.00	No
20.00	15	67.40	125.00	5.00	Yes
25.00	23	5.00	125.00	5.00	Yes
30.00	16	55.00	127.00	5.00	No

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	8	128.00	0.32	0.00	0.32	0.39	1.59	1.25	1.15	0.80	1.20	18	55.00	5.61	24	4.000
10.00	10	132.00	0.65	0.00	0.65	0.40	1.22	1.25	1.15	0.85	1.20	18	55.00	5.61	24	4.000
15.00	36	132.00	0.98	0.00	0.98	0.26	1.02	1.25	1.15	0.95	1.20	60	67.40	5.58	66	4.000
20.00	15	125.00	1.29	0.00	1.29	0.38	0.93	1.25	1.15	0.95	1.20	23	67.40	5.58	29	0.429
25.00	23	125.00	1.61	0.00	1.61	0.35	0.87	1.25	1.15	0.95	1.20	33	5.00	0.00	33	4.000
30.00	16	127.00	1.92	0.00	1.92	0.39	0.79	1.25	1.15	1.00	1.20	22	55.00	5.61	28	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	128.00	0.32	0.00	0.32	1.00	1.00	0.382	1.67	24	0.96	0.399	1.10	0.614	2.000 ●	
10.00	132.00	0.65	0.00	0.65	0.98	1.00	0.378	1.67	24	0.96	0.395	1.08	0.620	2.000 ●	
15.00	132.00	0.98	0.08	0.90	0.97	1.00	0.405	2.20	66	0.92	0.439	1.05	0.708	2.000 ●	
20.00	125.00	1.29	0.23	1.06	0.96	1.00	0.447	1.94	29	0.94	0.476	1.00	0.805	0.693 ●	
25.00	125.00	1.61	0.39	1.22	0.94	1.00	0.475	2.19	33	0.92	0.515	0.97	0.900	2.000 ●	
30.00	127.00	1.92	0.55	1.38	0.92	1.00	0.493	1.88	28	0.94	0.523	0.95	0.929	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\* : CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.30

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	0.693	0.31	6.95	5.00	3.26
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00

**Overall potential I<sub>L</sub> : 3.26**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	$G_{max}$ (tsf)	a	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000
10.00	18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00	0.000

**Cumulative settlements: 0.000**

**Abbreviations**

- $T_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_{\alpha}$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth (ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub> (%)</b>	<b>F<sub>a</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub> (%)</b>	<b>e<sub>v</sub> (%)</b>	<b>dz (ft)</b>	<b>S<sub>v-1D</sub> (in)</b>	<b>LDI (ft)</b>
15.00	66	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
20.00	29	5.33	-0.02	0.693	5.33	1.10	5.00	0.657	0.00
25.00	33	3.01	-0.29	2.000	0.00	0.00	5.00	0.000	0.00
30.00	28	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00

**Cumulative settlements: 0.657 0.00**

**Abbreviations**

- Y<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- Y<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



**Twining, Inc.**  
 2883 E. Spring Street, #300  
 Long Beach, California

**SPT BASED LIQUEFACTION ANALYSIS REPORT**






**Project title : KRMC Generator Pad**

**SPT Name: GP-1**

**Location : Riverside, California**


**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	3.28 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		



- F.S. color scheme**
- Almost certain it will liquefy
  - Very likely to liquefy
  - Liquefaction and no liq. are equally likely
  - Unlikely to liquefy
  - Almost certain it will not liquefy
- LPI color scheme**
- Very high risk
  - High risk
  - Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	22	55.00	120.00	5.00	No
10.00	41	55.00	120.00	5.00	No
15.00	16	25.00	120.00	5.00	Yes
20.00	21	75.00	120.00	5.00	Yes
25.00	10	65.00	120.00	5.00	No
30.00	36	45.00	120.00	5.00	Yes
35.00	18	10.00	120.00	5.00	Yes
40.00	36	10.00	120.00	5.00	Yes
45.00	41	5.00	120.00	5.00	Yes
50.00	46	5.00	120.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	22	120.00	0.30	0.00	0.30	0.26	1.39	1.25	1.15	0.75	1.20	40	55.00	5.61	46	4.000
10.00	41	120.00	0.60	0.00	0.60	0.26	1.16	1.25	1.15	0.85	1.20	70	55.00	5.61	76	4.000
15.00	16	120.00	0.90	0.00	0.90	0.36	1.06	1.25	1.15	0.85	1.20	25	25.00	5.07	30	0.485
20.00	21	120.00	1.20	0.00	1.20	0.31	0.96	1.25	1.15	0.95	1.20	33	75.00	5.56	39	4.000
25.00	10	120.00	1.50	0.00	1.50	0.45	0.85	1.25	1.15	0.95	1.20	14	65.00	5.59	20	4.000
30.00	36	120.00	1.80	0.00	1.80	0.26	0.87	1.25	1.15	1.00	1.20	54	45.00	5.61	60	4.000
35.00	18	120.00	2.10	0.00	2.10	0.40	0.76	1.25	1.15	1.00	1.20	24	10.00	1.15	25	0.290
40.00	36	120.00	2.40	0.00	2.40	0.26	0.81	1.25	1.15	1.00	1.20	50	10.00	1.15	51	4.000
45.00	41	120.00	2.70	0.00	2.70	0.26	0.78	1.25	1.15	1.00	1.20	55	5.00	0.00	55	4.000
50.00	46	120.00	3.00	0.00	3.00	0.26	0.76	1.25	1.15	1.00	1.20	60	5.00	0.00	60	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{I(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{I(60)cs}$ : Corrected  $N_{I(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	120.00	0.30	0.00	0.30	1.00	1.00	0.382	2.20	46	0.92	0.414	1.10	0.377	2.000 <span style="color: green;">●</span>	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
10.00	120.00	0.60	0.00	0.60	0.98	1.00	0.378	2.20	76	0.92	0.409	1.10	0.372	2.000	●
15.00	120.00	0.90	0.08	0.82	0.97	1.00	0.408	2.00	30	0.94	0.436	1.05	0.415	1.170	●
20.00	120.00	1.20	0.23	0.97	0.96	1.00	0.455	2.20	39	0.92	0.493	1.03	0.481	2.000	●
25.00	120.00	1.50	0.39	1.11	0.94	1.00	0.486	1.49	20	0.97	0.502	0.99	0.506	2.000	●
30.00	120.00	1.80	0.55	1.25	0.92	1.00	0.507	2.20	60	0.92	0.549	0.95	0.578	2.000	●
35.00	120.00	2.10	0.70	1.40	0.90	1.00	0.519	1.72	25	0.95	0.545	0.95	0.570	0.508	●
40.00	120.00	2.40	0.86	1.54	0.88	1.00	0.526	2.20	51	0.92	0.570	0.89	0.642	2.000	●
45.00	120.00	2.70	1.01	1.69	0.86	1.00	0.529	2.20	55	0.92	0.573	0.86	0.665	2.000	●
50.00	120.00	3.00	1.17	1.83	0.84	1.00	0.528	2.20	60	0.92	0.573	0.84	0.683	2.000	●

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.00

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	1.170	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00
35.00	0.508	0.49	4.67	5.00	3.50
40.00	2.000	0.00	3.90	5.00	0.00
45.00	2.000	0.00	3.14	5.00	0.00
50.00	2.000	0.00	2.38	5.00	0.00

**Overall potential I<sub>L</sub>: 3.50**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$T_{av}$	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>Nc</sub> (%)	Δh (ft)	ΔS (in)
5.00	40	0.11	0.20	0.72	0.14	13179.75	0.00	0.00	17.10	0.01	5.00	0.014
10.00	70	0.23	0.40	1.20	0.15	8695.39	0.00	0.00	17.10	0.01	5.00	0.007

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	(N <sub>1</sub> ) <sub>60</sub>	T <sub>av</sub>	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>N<sub>c</sub></sub> (%)	Δh (ft)	ΔS (in)

Cumulative settlements: 0.021

**Abbreviations**

- T<sub>av</sub>: Average cyclic shear stress
- p: Average stress
- G<sub>max</sub>: Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- γ: Average shear strain
- ε<sub>15</sub>: Volumetric strain after 15 cycles
- N<sub>c</sub>: Number of cycles
- ε<sub>N<sub>c</sub></sub>: Volumetric strain for number of cycles N<sub>c</sub> (%)
- Δh: Thickness of soil layer (in)
- ΔS: Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	(N <sub>1</sub> ) <sub>60cs</sub>	γ <sub>lim</sub> (%)	F <sub>a</sub>	FS <sub>liq</sub>	γ <sub>max</sub> (%)	e <sub>v</sub> (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)
15.00	30	4.65	-0.09	1.170	2.51	0.50	5.00	0.300	0.00
20.00	39	1.07	-0.73	2.000	0.00	0.00	5.00	0.000	0.00
25.00	20	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	60	0.00	-2.42	2.000	0.00	0.00	5.00	0.000	0.00
35.00	25	8.88	0.23	0.508	8.88	1.90	5.00	1.138	0.00
40.00	51	0.02	-1.67	2.000	0.00	0.00	5.00	0.000	0.00
45.00	55	0.00	-2.00	2.000	0.00	0.00	5.00	0.000	0.00
50.00	60	0.00	-2.42	2.000	0.00	0.00	5.00	0.000	0.00

Cumulative settlements: 1.437 0.00

**Abbreviations**

- γ<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- γ<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)



**SPT BASED LIQUEFACTION ANALYSIS REPORT**






**Project title : KRMC Generator Pad**

**SPT Name: GP-2**

**Location : Riverside, California**

**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	3.28 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		




**F.S. color scheme**

- Almost certain it will liquefy
- Very likely to liquefy
- Liquefaction and no liq. are equally likely
- Unlike to liquefy
- Almost certain it will not liquefy

**LPI color scheme**

- Very high risk
- High risk
- Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	23	55.00	120.00	5.00	No
10.00	27	55.00	120.00	5.00	No
15.00	27	25.00	120.00	5.00	Yes
20.00	23	75.00	120.00	5.00	Yes
25.00	17	65.00	120.00	5.00	No
30.00	18	45.00	120.00	5.00	Yes
35.00	48	10.00	120.00	5.00	Yes
40.00	40	10.00	120.00	5.00	Yes
45.00	65	5.00	120.00	5.00	Yes
50.00	42	5.00	120.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	23	120.00	0.30	0.00	0.30	0.26	1.39	1.25	1.15	0.75	1.20	41	55.00	5.61	47	4.000
10.00	27	120.00	0.60	0.00	0.60	0.26	1.16	1.25	1.15	0.85	1.20	46	55.00	5.61	52	4.000
15.00	27	120.00	0.90	0.00	0.90	0.26	1.04	1.25	1.15	0.85	1.20	41	25.00	5.07	46	4.000
20.00	23	120.00	1.20	0.00	1.20	0.29	0.96	1.25	1.15	0.95	1.20	36	75.00	5.56	42	4.000
25.00	17	120.00	1.50	0.00	1.50	0.37	0.88	1.25	1.15	0.95	1.20	25	65.00	5.59	31	4.000
30.00	18	120.00	1.80	0.00	1.80	0.36	0.83	1.25	1.15	1.00	1.20	26	45.00	5.61	32	4.000
35.00	48	120.00	2.10	0.00	2.10	0.26	0.83	1.25	1.15	1.00	1.20	69	10.00	1.15	70	4.000
40.00	40	120.00	2.40	0.00	2.40	0.26	0.81	1.25	1.15	1.00	1.20	56	10.00	1.15	57	4.000
45.00	65	120.00	2.70	0.00	2.70	0.26	0.78	1.25	1.15	1.00	1.20	88	5.00	0.00	88	4.000
50.00	42	120.00	3.00	0.00	3.00	0.26	0.76	1.25	1.15	1.00	1.20	55	5.00	0.00	55	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{I(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{I(60)cs}$ : Corrected  $N_{I(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	120.00	0.30	0.00	0.30	1.00	1.00	0.382	2.20	47	0.92	0.414	1.10	0.377	2.000 <span style="color: green;">●</span>	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
10.00	120.00	0.60	0.00	0.60	0.98	1.00	0.378	2.20	52	0.92	0.409	1.10	0.372	2.000	●
15.00	120.00	0.90	0.08	0.82	0.97	1.00	0.408	2.20	46	0.92	0.442	1.07	0.411	2.000	●
20.00	120.00	1.20	0.23	0.97	0.96	1.00	0.455	2.20	42	0.92	0.493	1.03	0.481	2.000	●
25.00	120.00	1.50	0.39	1.11	0.94	1.00	0.486	2.06	31	0.93	0.522	0.99	0.528	2.000	●
30.00	120.00	1.80	0.55	1.25	0.92	1.00	0.507	2.12	32	0.93	0.546	0.96	0.568	2.000	●
35.00	120.00	2.10	0.70	1.40	0.90	1.00	0.519	2.20	70	0.92	0.563	0.92	0.613	2.000	●
40.00	120.00	2.40	0.86	1.54	0.88	1.00	0.526	2.20	57	0.92	0.570	0.89	0.642	2.000	●
45.00	120.00	2.70	1.01	1.69	0.86	1.00	0.529	2.20	88	0.92	0.573	0.86	0.665	2.000	●
50.00	120.00	3.00	1.17	1.83	0.84	1.00	0.528	2.20	55	0.92	0.573	0.84	0.683	2.000	●

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.00

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00
25.00	2.000	0.00	6.19	5.00	0.00
30.00	2.000	0.00	5.43	5.00	0.00
35.00	2.000	0.00	4.67	5.00	0.00
40.00	2.000	0.00	3.90	5.00	0.00
45.00	2.000	0.00	3.14	5.00	0.00
50.00	2.000	0.00	2.38	5.00	0.00

**Overall potential I<sub>L</sub>: 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$\tau_{av}$	p	G <sub>max</sub> (tsf)	$\alpha$	b	$\gamma$	$\epsilon_{15}$	N <sub>c</sub>	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	41	0.11	0.20	0.72	0.14	13179.75	0.00	0.00	17.10	0.01	5.00	0.013
10.00	46	0.23	0.40	1.06	0.15	8695.39	0.00	0.00	17.10	0.01	5.00	0.015

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	(N <sub>1</sub> ) <sub>60</sub>	T <sub>av</sub>	p	G <sub>max</sub> (tsf)	a	b	γ	ε <sub>15</sub>	N <sub>c</sub>	ε <sub>N<sub>c</sub></sub> (%)	Δh (ft)	ΔS (in)

Cumulative settlements: 0.028

**Abbreviations**

- T<sub>av</sub>: Average cyclic shear stress
- p: Average stress
- G<sub>max</sub>: Maximum shear modulus (tsf)
- a, b: Shear strain formula variables
- γ: Average shear strain
- ε<sub>15</sub>: Volumetric strain after 15 cycles
- N<sub>c</sub>: Number of cycles
- ε<sub>N<sub>c</sub></sub>: Volumetric strain for number of cycles N<sub>c</sub> (%)
- Δh: Thickness of soil layer (in)
- ΔS: Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	(N <sub>1</sub> ) <sub>60cs</sub>	γ <sub>lim</sub> (%)	F <sub>a</sub>	FS <sub>liq</sub>	γ <sub>max</sub> (%)	e <sub>v</sub> (%)	dz (ft)	S <sub>v-1D</sub> (in)	LDI (ft)
15.00	46	0.19	-1.27	2.000	0.00	0.00	5.00	0.000	0.00
20.00	42	0.56	-0.96	2.000	0.00	0.00	5.00	0.000	0.00
25.00	31	0.00	0.00	2.000	0.00	0.00	5.00	0.000	0.00
30.00	32	3.50	-0.22	2.000	0.00	0.00	5.00	0.000	0.00
35.00	70	0.00	-3.30	2.000	0.00	0.00	5.00	0.000	0.00
40.00	57	0.00	-2.17	2.000	0.00	0.00	5.00	0.000	0.00
45.00	88	0.00	-4.94	2.000	0.00	0.00	5.00	0.000	0.00
50.00	55	0.00	-2.00	2.000	0.00	0.00	5.00	0.000	0.00

Cumulative settlements: 0.000 0.00

**Abbreviations**

- γ<sub>lim</sub>: Limiting shear strain (%)
- F<sub>a</sub>/N: Maximum shear strain factor
- γ<sub>max</sub>: Maximum shear strain (%)
- e<sub>v</sub>: Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>: Estimated vertical settlement (in)
- LDI: Estimated lateral displacement (ft)

## SPT BASED LIQUEFACTION ANALYSIS REPORT



**Project title : KRMC Generator Pad**

**SPT Name: PT-1**

**Location : Riverside, California**


**:: Input parameters and analysis properties ::**

Analysis method:	Boulanger & Idriss, 2014	G.W.T. (in-situ):	57.50 ft
Fines correction method:	Boulanger & Idriss, 2014	G.W.T. (earthq.):	12.50 ft
Sampling method:	Sampler wo liners	Earthquake magnitude $M_w$ :	7.70
Borehole diameter:	200mm	Peak ground acceleration:	0.59 g
Rod length:	3.28 ft	Eq. external load:	0.00 tsf
Hammer energy ratio:	1.25		



- F.S. color scheme**
- Almost certain it will liquefy
  - Very likely to liquefy
  - Liquefaction and no liq. are equally likely
  - Unlike to liquefy
  - Almost certain it will not liquefy
- LPI color scheme**
- Very high risk
  - High risk
  - Low risk

**:: Overall Liquefaction Assessment Analysis Plots ::**



:: Field input data ::					
Test Depth (ft)	SPT Field Value (blows)	Fines Content (%)	Unit Weight (pcf)	Infl. Thickness (ft)	Can Liquefy
5.00	25	49.00	120.00	5.00	No
10.00	19	49.00	120.00	5.00	Yes
15.00	30	49.00	120.00	5.00	Yes
20.00	19	62.00	120.00	5.00	Yes

**Abbreviations**

Depth: Depth at which test was performed (ft)  
 SPT Field Value: Number of blows per foot  
 Fines Content: Fines content at test depth (%)  
 Unit Weight: Unit weight at test depth (pcf)  
 Infl. Thickness: Thickness of the soil layer to be considered in settlements analysis (ft)  
 Can Liquefy: User defined switch for excluding/including test depth from the analysis procedure

:: Cyclic Resistance Ratio (CRR) calculation data ::																
Depth (ft)	SPT Field Value	Unit Weight (pcf)	$\sigma_v$ (tsf)	$u_o$ (tsf)	$\sigma'_{vo}$ (tsf)	m	$C_N$	$C_E$	$C_B$	$C_R$	$C_S$	$(N_1)_{60}$	FC (%)	$\Delta(N_1)_{60}$	$(N_1)_{60cs}$	CRR <sub>7.5</sub>
5.00	25	120.00	0.30	0.00	0.30	0.26	1.39	1.25	1.15	0.75	1.20	45	49.00	5.61	51	4.000
10.00	19	120.00	0.60	0.00	0.60	0.30	1.19	1.25	1.15	0.85	1.20	33	49.00	5.61	39	4.000
15.00	30	120.00	0.90	0.00	0.90	0.26	1.04	1.25	1.15	0.85	1.20	46	49.00	5.61	52	4.000
20.00	19	120.00	1.20	0.00	1.20	0.33	0.96	1.25	1.15	0.95	1.20	30	62.00	5.60	36	4.000

**Abbreviations**

$\sigma_v$ : Total stress during SPT test (tsf)  
 $u_o$ : Water pore pressure during SPT test (tsf)  
 $\sigma'_{vo}$ : Effective overburden pressure during SPT test (tsf)  
 m: Stress exponent normalization factor  
 $C_N$ : Overburden correction factor  
 $C_E$ : Energy correction factor  
 $C_B$ : Borehole diameter correction factor  
 $C_R$ : Rod length correction factor  
 $C_S$ : Liner correction factor  
 $N_{1(60)}$ : Corrected  $N_{SPT}$  to a 60% energy ratio  
 $\Delta(N_1)_{60}$ : Equivalent clean sand adjustment  
 $N_{1(60)cs}$ : Corrected  $N_{1(60)}$  value for fines content  
 CRR<sub>7.5</sub>: Cyclic resistance ratio for M=7.5

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::															
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq, M=7.5</sub>	$K_{\sigma}$	CSR*	FS	
5.00	120.00	0.30	0.00	0.30	1.00	1.00	0.382	2.20	51	0.92	0.414	1.10	0.377	2.000 ●	
10.00	120.00	0.60	0.00	0.60	0.98	1.00	0.378	2.20	39	0.92	0.409	1.10	0.372	2.000 ●	
15.00	120.00	0.90	0.08	0.82	0.97	1.00	0.408	2.20	52	0.92	0.442	1.07	0.411	2.000 ●	
20.00	120.00	1.20	0.23	0.97	0.96	1.00	0.455	2.20	36	0.92	0.493	1.03	0.481	2.000 ●	

:: Cyclic Stress Ratio calculation (CSR fully adjusted and normalized) ::														
Depth (ft)	Unit Weight (pcf)	$\sigma_{v,eq}$ (tsf)	$u_{o,eq}$ (tsf)	$\sigma'_{vo,eq}$ (tsf)	$r_d$	$\alpha$	CSR	MSF <sub>max</sub>	$(N_1)_{60cs}$	MSF	CSR <sub>eq,M=7.5</sub>	$K_{\sigma}$	CSR*	FS

**Abbreviations**

- $\sigma_{v,eq}$ : Total overburden pressure at test point, during earthquake (tsf)
- $u_{o,eq}$ : Water pressure at test point, during earthquake (tsf)
- $\sigma'_{vo,eq}$ : Effective overburden pressure, during earthquake (tsf)
- $r_d$ : Nonlinear shear mass factor
- $\alpha$ : Improvement factor due to stone columns
- CSR : Cyclic Stress Ratio
- MSF : Magnitude Scaling Factor
- CSR<sub>eq,M=7.5</sub>: CSR adjusted for M=7.5
- $K_{\sigma}$ : Effective overburden stress factor
- CSR\*: CSR fully adjusted (user FS applied)\*\*\*
- FS: Calculated factor of safety against soil liquefaction

\*\*\* User FS: 1.00

:: Liquefaction potential according to Iwasaki ::					
Depth (ft)	FS	F	wz	Thickness (ft)	I <sub>L</sub>
5.00	2.000	0.00	9.24	5.00	0.00
10.00	2.000	0.00	8.48	5.00	0.00
15.00	2.000	0.00	7.71	5.00	0.00
20.00	2.000	0.00	6.95	5.00	0.00

**Overall potential I<sub>L</sub> : 0.00**

- I<sub>L</sub> = 0.00 - No liquefaction
- I<sub>L</sub> between 0.00 and 5 - Liquefaction not probable
- I<sub>L</sub> between 5 and 15 - Liquefaction probable
- I<sub>L</sub> > 15 - Liquefaction certain

:: Vertical settlements estimation for dry sands ::												
Depth (ft)	$(N_1)_{60}$	$\tau_{av}$	p	$G_{max}$ (tsf)	$\alpha$	b	$\gamma$	$\epsilon_{15}$	$N_c$	$\epsilon_{Nc}$ (%)	$\Delta h$ (ft)	$\Delta S$ (in)
5.00	45	0.11	0.20	0.74	0.14	13179.75	0.00	0.00	17.10	0.01	5.00	0.011
10.00	33	0.23	0.40	0.96	0.15	8695.39	0.00	0.00	17.10	0.02	5.00	0.025

**Cumulative settlements: 0.037**

**Abbreviations**

- $\tau_{av}$ : Average cyclic shear stress
- p: Average stress
- $G_{max}$ : Maximum shear modulus (tsf)
- $\alpha, b$ : Shear strain formula variables
- $\gamma$ : Average shear strain
- $\epsilon_{15}$ : Volumetric strain after 15 cycles
- $N_c$ : Number of cycles
- $\epsilon_{Nc}$ : Volumetric strain for number of cycles  $N_c$  (%)
- $\Delta h$ : Thickness of soil layer (in)
- $\Delta S$ : Settlement of soil layer (in)

:: Vertical & Lateral displacements estimation for saturated sands ::									
Depth (ft)	$(N_1)_{60cs}$	$\gamma_{lim}$ (%)	$F_a$	FS <sub>liq</sub>	$\gamma_{max}$ (%)	$e_v$ (%)	dz (ft)	$S_{v-1D}$ (in)	LDI (ft)
15.00	52	0.01	-1.75	2.000	0.00	0.00	5.00	0.000	0.00
20.00	36	1.86	-0.51	2.000	0.00	0.00	5.00	0.000	0.00

<b>:: Vertical &amp; Lateral displacements estimation for saturated sands ::</b>									
<b>Depth</b> <b>(ft)</b>	<b>(N<sub>1</sub>)<sub>60cs</sub></b>	<b>Y<sub>lim</sub></b> <b>(%)</b>	<b>F<sub>a</sub></b>	<b>FS<sub>liq</sub></b>	<b>Y<sub>max</sub></b> <b>(%)</b>	<b>e<sub>v</sub></b> <b>(%)</b>	<b>dz</b> <b>(ft)</b>	<b>S<sub>v-1D</sub></b> <b>(in)</b>	<b>LDI</b> <b>(ft)</b>

**Cumulative settlements:    0.000       0.00**

**Abbreviations**

- Y<sub>lim</sub>:    Limiting shear strain (%)
- F<sub>a</sub>/N:    Maximum shear strain factor
- Y<sub>max</sub>:    Maximum shear strain (%)
- e<sub>v</sub>:        Post liquefaction volumetric strain (%)
- S<sub>v-1D</sub>:    Estimated vertical settlement (in)
- LDI:       Estimated lateral displacement (ft)

## References

- Ronald D. Andrus, Hossein Hayati, Nisha P. Mohanan, 2009. Correcting Liquefaction Resistance for Aged Sands Using Measured to Estimated Velocity Ratio, *Journal of Geotechnical and Geoenvironmental Engineering*, Vol. 135, No. 6, June 1
- Boulanger, R.W. and Idriss, I. M., 2014. CPT AND SPT BASED LIQUEFACTION TRIGGERING PROCEDURES. DEPARTMENT OF CIVIL & ENVIRONMENTAL ENGINEERING COLLEGE OF ENGINEERING UNIVERSITY OF CALIFORNIA AT DAVIS
- Dipl.-Ing. Heinz J. Priebe, Vibro Replacement to Prevent Earthquake Induced Liquefaction, *Proceedings of the Geotechnique-Colloquium at Darmstadt, Germany, on March 19th, 1998* (also published in *Ground Engineering*, September 1998), Technical paper 12-57E
- Robertson, P.K. and Cabal, K.L., 2007, *Guide to Cone Penetration Testing for Geotechnical Engineering*. Available at no cost at <http://www.geologismiki.gr/>
- Youd, T.L., Idriss, I.M., Andrus, R.D., Arango, I., Castro, G., Christian, J.T., Dobry, R., Finn, W.D.L., Harder, L.F., Hynes, M.E., Ishihara, K., Koester, J., Liao, S., Marcuson III, W.F., Martin, G.R., Mitchell, J.K., Moriwaki, Y., Power, M.S., Robertson, P.K., Seed, R., and Stokoe, K.H., Liquefaction Resistance of Soils: Summary Report from the 1996 NCEER and 1998 NCEER/NSF Workshop on Evaluation of Liquefaction Resistance of Soils, ASCE, *Journal of Geotechnical & Geoenvironmental Engineering*, Vol. 127, October, pp 817-833
- Zhang, G., Robertson. P.K., Brachman, R., 2002, Estimating Liquefaction Induced Ground Settlements from the CPT, *Canadian Geotechnical Journal*, 39: pp 1168-1180
- Zhang, G., Robertson. P.K., Brachman, R., 2004, Estimating Liquefaction Induced Lateral Displacements using the SPT and CPT, ASCE, *Journal of Geotechnical & Geoenvironmental Engineering*, Vol. 130, No. 8, 861-871
- Pradel, D., 1998, Procedure to Evaluate Earthquake-Induced Settlements in Dry Sandy Soils, ASCE, *Journal of Geotechnical & Geoenvironmental Engineering*, Vol. 124, No. 4, 364-368
- R. Kayen, R. E. S. Moss, E. M. Thompson, R. B. Seed, K. O. Cetin, A. Der Kiureghian, Y. Tanaka, K. Tokimatsu, 2013. Shear-Wave Velocity–Based Probabilistic and Deterministic Assessment of Seismic Soil Liquefaction Potential, *Journal of Geotechnical and Geoenvironmental Engineering*, Vol. 139, No. 3, March 1



2883 East Spring Street  
Suite 300  
Long Beach CA 90806

Tel 562.426.3355  
Fax 562.426.6424

# APPENDIX E

## SELECT PROJECT PLANS

**PARKING DESIGNATION LEGEND**

- STAFF & GENERAL CONTRACTOR PARKING
- GENERAL CONTRACTOR PARKING



**PEP BOYS LOT**  
STALL COUNT: 157




**FILLMORE LOT**  
STALL COUNT: 657



**Phase 1 – Offsite Make Ready**


Improvement of off-campus lots at 11510 Magnolia Ave (Fillmore) and 10861 Magnolia Ave (Pep Boys). The Fillmore parking lot will accommodate displacement of staff parking during the construction of the new parking structure and General Contractor parking during hospital construction. The Pep Boys lot will be improved for use by the General Contractor.




**1 EXISTING SITE PLAN**  
1" = 100'-0"

- CIRCULATION LEGEND**
- AMBULANCE ROUTE
  - MEMBER ROUTE
  - STAFF ROUTE
  - SERVICE ROUTE

EXISTING PARKING MATRIX	2,543
CODE REQ'D:	2,842
PROVIDED:	



Existing Site Plan



**2 PH 2.0**  
1" = 100'-0"

PHASE 2 PARKING MATRIX	2,543
CODE REQ'D:	2,745
PROVIDED:	

<span style="background-color: #4682B4; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 454 ACCESSIBLE: 26 ACCESSIBLE VAN: 0 <b>LOT TOTAL: 480</b>	<span style="background-color: #FF69B4; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 7 ACCESSIBLE: 0 ACCESSIBLE VAN: 0 <b>LOT TOTAL: 7</b>	<span style="background-color: #32CD32; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 65 ACCESSIBLE: 0 ACCESSIBLE VAN: 0 <b>LOT TOTAL: 65</b>	<span style="background-color: #FF8C00; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 643 ACCESSIBLE: 15 ACCESSIBLE VAN: 4 <b>LOT TOTAL: 662</b>	<span style="background-color: #FF0000; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 190 ACCESSIBLE: 0 ACCESSIBLE VAN: 0 <b>LOT TOTAL: 190</b>
<span style="background-color: #6A5ACD; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 359 ACCESSIBLE: 36 ACCESSIBLE VAN: 7 <b>LOT TOTAL: 402</b>	<span style="background-color: #00008B; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 288 ACCESSIBLE: 45 ACCESSIBLE VAN: 1 <b>LOT TOTAL: 334</b>	<span style="background-color: #FFFF00; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 249 ACCESSIBLE: 42 ACCESSIBLE V/13: <b>LOT TOTAL: 304</b>	<span style="background-color: #800080; border: 1px solid black; display: inline-block; width: 20px; height: 10px;"></span> STANDARD: 11 ACCESSIBLE: 0 ACCESSIBLE V/2: <b>LOT TOTAL: 13</b>	

<b>SHEET TOTAL:</b>	
STANDARD:	2268
COMPACT:	0
UNDER 8'-6":	0
ACCESSIBLE:	169
ACCESSIBLE VAN:	22
<b>ON SITE TOTAL:</b>	<b>2459</b>
OFFSITE STALLS:	286
<b>TOTAL:</b>	<b>2745</b>

**Phase 2: On-Site Parking Re-Stripe**  
Re-striping of onsite parking lots to convert all compact and sub-standard parking stalls to standard parking stalls. Convert parking lot south of Park Sierra's entry drive into accessible parking lot.


**SITE PHASING - 2**

1" = 100'-0"  
JULY 19, 2021



**RIVERSIDE MEDICAL CENTER**


Sheet: <b>A 1.21</b>	CITY OF RIVERSIDE
Site Development Plan Number:	PHONE: 626.405.6333
OWNER: Kaiser Foundation Hospitals	ADDRESS: 393 E. Walnut Street Pasadena, CA 91188
ARCHITECT, ENGINEER, DESIGNER: CO Architects, Michael Baker International, Ridge Landscape Architects, Glumac	PHONE: 323.525.0500 (Architect)
ADDRESS: 5955 Wilshire Blvd. 9th Floor, Los Angeles CA 90036 (Architect)	LOCATION: 10800 Magnolia Ave. Riverside, CA 92505
TYPE OF DEVELOPMENT: XXXXX	ACCESSOR'S PARCEL NUMBER: 138-470-010
ZONE: XXXXX	




- CIRCULATION LEGEND**
- AMBULANCE ROUTE
  - MEMBER ROUTE
  - STAFF ROUTE
  - SERVICE ROUTE
- PHASING LEGEND**
- NEW
  - CONSTRUCTION AREA

1 PH 3.0  
1" = 100'-0"

PHASE 3 PARKING MATRIX	
CODE REQ'D:	2,543
PROVIDED:	2,961




**Phase 3 - Shortened Ambulance Drive and Parking Structure Laydown**  
Shorten the ambulance and patient drop off loop, removing 2 parking stalls.



2 PH 4.0  
1" = 100'-0"

PHASE 4 PARKING MATRIX	
CODE REQ'D:	2,543
PROVIDED:	2,961



**Phase 4 - Temporary Ambulance Drop-off and Upgrade CUP**  
Install new temporary ambulance drop-off area and canopy.  
Upgrades to the Central Utility Plant (CUP) and utility connections from the CUP to the new Hospital Tower location.

**SITE PHASING - 3,4**

1" = 100'-0"

JULY 19, 2021




**RIVERSIDE MEDICAL CENTER**

Sheet: **A 1.22**

CITY OF RIVERSIDE

Site Development Plan Number:	
OWNER: Kaiser Foundation Hospitals	PHONE: 626.405.6333
ADDRESS: 393 E. Walnut Street Pasadena, CA 91188	
ARCHITECT, ENGINEER, DESIGNER: CO Architects, Michael Baker International, Ridge Landscape Architects, Glumac	PHONE: 323.525.0500 (Architect)
ADDRESS: 5055 Wilshire Blvd. 9th Floor, Los Angeles CA 90036 (Architect)	LOCATION: 10800 Magnolia Ave. Riverside, CA 92505
TYPE OF DEVELOPMENT: XXXXX	ACCESSOR'S PARCEL NUMBER: 138-470-010
ZONE: XXXXX	




- CIRCULATION LEGEND**
- AMBULANCE ROUTE
  - MEMBER ROUTE
  - STAFF ROUTE
  - SERVICE ROUTE
- PHASING LEGEND**
- NEW
  - CONSTRUCTION AREA

1 PH 5.0  
1" = 100'-0"

PHASE 5 PARKING MATRIX	
CODE REQ'D:	2,543
PROVIDED:	2,961

**Phase 5 – Temporary Ambulance Drop off and Patient Drop off**  
 New temporary Ambulance Drop off.  
 New Temporary Patient Drop off.



2 PH 6.0  
1" = 100'-0"

PHASE 6 PARKING MATRIX	
CODE REQ'D:	2,543
PROVIDED:	3,251

**Phase 6 - Hospital New Tower (NT)**  
 (NT), Hospital Tower construction, and correlating site work. The construction sequence and methods are as follows:  
**Demo and Grading**  
 Sitework - Underground Utilities including relocating outside the building footprint, connections from the CUP to new Hospital Tower, and underground tanks.  
**Shoring and Mass Excavation**  
 NT Underground – Cast-in-place reinforced concrete walls with spread footings, underground utilities, and waterproofing installation  
 NT Superstructure – Structural steel columns & beams including Sideplate moment frames and reinforced concrete slab on metal decks  
 NT Exterior façade – Glass and Aluminum Curtainwall system with select areas of stick built glass and aluminum storefront system and light gauge framed penthouses with metal panels  
 NT Building Interiors – Light gauge framing and drywall and mechanical, electrical, plumbing and fire protection systems, medical equipment, interior specialties & finishes  
 Landscaping - Planting and site concrete, exterior lighting, signage, site structures, and driveways and parking


**SITE PHASING - 5,6**

1" = 100'-0"  
JULY 19, 2021



**RIVERSIDE MEDICAL CENTER**


Sheet: <b>A 1.23</b>	CITY OF RIVERSIDE
Site Development Plan Number:	
OWNER: Kaiser Foundation Hospitals	PHONE: 626.405.6333
ADDRESS: 393 E. Walnut Street Pasadena, CA 91188	
ARCHITECT, ENGINEER, DESIGNER: CO Architects, Michael Baker International, Ridge Landscape Architects, Glumac	PHONE: 323.525.0500 (Architect)
ADDRESS: 5055 Wilshire Blvd. 9th Floor, Los Angeles CA 90036 (Architect)	LOCATION: 10800 Magnolia Ave. Riverside, CA 92505
TYPE OF DEVELOPMENT: XXXXX	ACCESSOR'S PARCEL NUMBER: 138-470-010
ZONE: XXXXX	



- CIRCULATION LEGEND**
- AMBULANCE ROUTE
  - MEMBER ROUTE
  - STAFF ROUTE
  - SERVICE ROUTE
- PHASING LEGEND**
- NEW
  - CONSTRUCTION AREA


1 PH 7.0  
1" = 100'-0"

PHASE 7 PARKING MATRIX	
CODE REQ'D:	2,543
PROVIDED:	3,058




**Phase 7 – Hospital Construction and New Parking Lot Configuration**

Phase 7 extends scope of construction to the NE parking lot where a new parking configuration will be constructed to accommodate the New Tower.



2 SITE FINISHED - PLAN - FINAL SITE PLAN ENTITLEMENT  
PHASING  
1" = 100'-0"

**Final Site Plan**



**SITE PHASING - 7**

1" = 100'-0"

JULY 19, 2021




**RIVERSIDE MEDICAL CENTER**

Sheet: **A 1.24**

CITY OF RIVERSIDE


Site Development Plan Number:	PHONE: 626.405.6333
OWNER: Kaiser Foundation Hospitals	ADDRESS: 393 E. Walnut Street Pasadena, CA 91188
ARCHITECT, ENGINEER, DESIGNER: CO Architects, Michael Baker International, Ridge Landscape Architects, Glumac	PHONE: 323.525.0500 (Architect)
ADDRESS: 5055 Wilshire Blvd. 9th Floor, Los Angeles CA 90036 (Architect)	LOCATION: 10800 Magnolia Ave. Riverside, CA 92505
TYPE OF DEVELOPMENT: XXXXX	ACCESSOR'S PARCEL NUMBER: 138-470-010
ZONE: XXXXX	



VICINITY MAP

**LEGEND**

RIGHT OF WAY	---
PROPERTY LINE	---
CURB AND GUTTER	---
AC PAVEMENT	▨
CONCRETE PAVEMENT	▨
DECORATIVE CONCRETE PAVEMENT (PER LANDSCAPE PLANS)	▨
PROPOSED BUILDING	▨
ROOF OVERHANG	▨



EMERGENCY ENTRANCE DETAIL

SCALE: 1" = 20'

