



NOTICE OF EXEMPTION

TO: Alameda County Clerk-Recorder's Office 1106 Madison Street Oakland, CA 94607	FROM: (LEAD AGENCY) EAST BAY MUNICIPAL UTILITY DISTRICT Office of the Secretary - (510) 287-0404 375 Eleventh Street, MS 806 Oakland, CA 94607-4240 <input checked="" type="checkbox"/> Lead Agency is the Project Applicant <input checked="" type="checkbox"/> Lead Agency is Public Agency Approving Project <input checked="" type="checkbox"/> Lead Agency is Carrying Out Project
---	---

PROJECT INFORMATION

- TITLE: Power Generation Station 1 Emergency Generator Replacement Project
- LOCATION: *(City, County, and specific location)*
Oakland, Alameda County, Main Wastewater Treatment Plant, 2020 Wake Ave
- DESCRIPTION: The project will replace the existing antiquated, undersized 150 kilowatts (kW) diesel generator at the Main Wastewater Treatment Plant (MWWTP) with a new diesel generator. The new generator will be rated for 275 kW standby power and will be pad-mounted at the Power Generation Station 1 site at the MWWTP. The new generator will provide greater reliability to start one of the internal combustion engines and required auxiliary equipment when Pacific Gas and Electric power is not available.

EXEMPTION FINDING (Check one)

This project is exempt from CEQA because:

- Activity is not a project
- Activity is Ministerial (Sec.21080(b)(1); Guideline 15268)
- Activity is a Declared Emergency (Sec.21080(b)(3); Guideline 15269(a))
- Activity is an Emergency Project (Sec.21080(b)(4); Guideline 15269(b)(c))
- Activity is Categorically Exempt Under Guideline 14 CCR 15301(b)
- Activity is Statutorily Exempt Under Guideline _____
- Reasons why project is exempt: The project consists of the repair and maintenance of existing public facilities as specified in the exemption.

APPROVAL BY INITIATING UNIT: 926 Wastewater Planning

<u>7/22/2021</u>	<u>Jennifer Ku <i>JK</i></u>	<u>Matthew R. Hoelt <i>MH</i></u>
1. DATE PREPARED	2. PREPARED BY (initial)	3. REVIEWED BY (Unit Supv. initial)
<u>Douglas Y. Higashi</u>	<u><i>Douglas Y. Higashi</i></u>	
4. RECOMMENDED BY (Division/Section Manager)		
<u>Matthew R. Hoelt</u>	<u>702</u>	<u>Senior Civil Engineer</u>
5. CONTACT PERSON	MAIL SLOT #	TITLE
		<u>510-287-0214</u>
		PHONE

NOTICE OF EXEMPTION APPROVED FOR FILING WITH THE COUNTY CLERK

<u>9/8/2021</u>	<u>Eileen M. White</u>	<u><i>Eileen M. White</i></u>
DATE	DEPARTMENT DIRECTOR	
<u>9/20/21</u>	<u>Rischa Cole</u>	<u><i>Rischa S. Cole</i></u>
DATE FORWARDED TO COUNTY CLERK	SECRETARY OF THE DISTRICT	