Summary Form for Electronic Document Submittal

SCH#:

Form F

Lead agencies may include 15 hardcopies of this document when submitting electronic copies of Environmental Impact Reports, Negative Declarations, Mitigated Negative Declarations, or Notices of Preparation to the State Clearinghouse (SCH). The SCH also accepts other summaries, such as EIR Executive Summaries prepared pursuant to CEQA Guidelines Section 15123. Please include one copy of the Notice of Completion Form (NOC) with your submission and attach the summary to each electronic copy of the document.

Project Title: Wells 81A, B, C North Antelope/Poker Project	
Lead Agency: Sacramento Suburban Water Agency	
Contact Name: Dave Morrow, P.E.	
Email: dmorrow@sswd.org	Phone Number: (916) 679-3988
Project Location: Antelope	Sacramento
City	County
Project Description (Proposed actions, location, and/or consequences).	
SSWD proposes the construction of water supply well facilities to serve as replacement potable water supply sources for SSWDs North Service Area. The proposed Project components would include underground and above ground facilities, including three 600-foot-deep water supply wells, wellheads, a 2-million-gallon potable water storage reservoir, an 80-foot by 30-foot equipment building, a manganese treatment system, a 300-gallon setting tank, a 350kV emergency natural gas generator, and an 8-foot-high concrete masonry unit bloc perimeter wall. Each well would produce approximately 1,500 to 2,000 gallons per minute (GPM) of water. minute (GPM) of water.	

Identify the project's significant or potentially significant effects and briefly describe any proposed mitigation measures that would reduce or avoid that effect.

or the Wells 81A, B, C North Antelope/Poker Project (Proposed Project), SSWD proposes the construction of water supply well facilities to serve as replacement potable water supply sources for SSWD's North Service Area. The proposed Project components would include underground and above ground facilities, including three 600-foot-deep water supply wells, wellheads, a 2-million-gallon potable water storage reservoir, an 80-foot by 30-foot equipment building, a manganese treatment system, a 300-gallon setting tank, a 350kV emergency natural gas generator, and an 8-foot-high concrete masonry unit bloc perimeter wall. Each well would produce approximately 1,500 to 2,000 gallons per

If applicable, describe any of the project's areas of controversy known to the Lead Agency, including issues raised by agencies and the public.

Less-than-Significant Impact with Mitigation Incorporated. As described in the preceding impact discussions, the impacts related to the potential of the Proposed Project to substantially degrade the environment would be less than significant with incorporated mitigation measures. As described in this IS/MND, the Proposed Project has the potential for impacts related to biological resources, cultural resources, and paleontological resources. However, these impacts would be avoided or reduced to a less-than-significant level with the incorporation of avoidance and mitigation measures discussed in each section.

- b) Less-than-Significant Impact. Given the small size of the Proposed Project, activities are not expected to contribute to cumulatively significant impacts. Additionally, any other past, current, or future projects would be subject to many of the same federal, state, and local laws and regulations during the construction and operation phases of those potential projects. Given the limited duration of the Proposed Project construction and the incorporated design features to reduce impacts, the Proposed Project 's potential to contribute to cumulative significant impact would be less than significant.
- c) Less-than-Significant Impact. The only environmental impacts created as a result of the Proposed Project with the potential to have substantial adverse effects on human beings would be air quality and noise-related impacts. As stated in Section 2.2, Air Quality, the Proposed Project would not generate emissions that would exceed the SMAQMD established thresholds; therefore, these impacts are not considered cumulatively considerable. Additionally, as stated in Section 2.10, Noise, the Proposed Project would minimize noise-related impacts by utilizing residential rated equipment; therefore, the noise-related impacts would not be cumulatively considerable and would be less than significant.

Provide a list of the responsible or trustee agencies for the project.

Sacramento Suburban Water Agency
Air Resources Control Board
Regional WQCB #5
SWRCB Water Quality
Sacramento County