

CITY OF LOS ANGELES
 OFFICE OF THE CITY CLERK
 ROOM 395, CITY HALL
 LOS ANGELES, CALIFORNIA 90012
 CALIFORNIA ENVIRONMENTAL QUALITY ACT

NOTICE OF EXEMPTION

(City CEQA Guidelines)

Submission of this form is optional. The form shall be filed with the County Clerk, 12400 Imperial Highway, Norwalk, CA 90650, pursuant to Public Resources Code Section 21152(b). Pursuant to Public Resources Code Section 21168(d), the filing of this notice starts a 35-day statute of limitations on Court challenges to the approval of the project. Failure to file the notice results in the statute of limitations being extended to 180 days.

LEAD CITY AGENCY AND ADDRESS: Los Angeles Department of Water and Power (LADWP) 111 N. Hope Street, Room 1044 Los Angeles, CA 90012	COUNCIL DISTRICT 6 – Martinez
---	---

PROJECT TITLE Truesdale Training Facility Solar Carport Project	LOG REFERENCE
---	----------------------

PROJECT LOCATION
 11781 West Truesdale Street, Sun Valley, CA 90051 (11740-11797 West Truesdale, 9430-9542 North San Fernando Road, 12000 West Wentworth Street, 11801-11813 West Sheldon Street). See attached map.

DESCRIPTION OF NATURE, PURPOSE, AND BENEFICIARIES OF PROJECT:
 It is LADWP's goal to reach 1500 MW of distributed solar by 2036 as set by the Integrated Resource Plan. In addition, California State Senate passed SB100 on September 10, 2018, also known as "The 100 Percent Clean Energy Act of 2017." The bill plans for 100 percent of total retail sales of electricity in California to come from eligible renewable energy resources and zero-carbon resources by December 31, 2045. In order to achieve this mandate, SB100 sets targets of total retail sales of electricity in which renewable energy resources must account 55 percent by December 31, 2025, 60 percent by December 31, 2030, and 70 percent by December 31, 2036. With grid-connected solar projects, LADWP would be eligible for Renewable Energy Credits to count towards its Renewable Portfolio Standard (RPS) mandates. The Los Angeles Department of Water and Power (DWP) is committed to expand its renewable resource portfolio. To meet these goals, a portion of these renewable sources are being fulfilled by installing photovoltaic module systems on existing DWP property.

The Truesdale Training Facility Solar Carport Project will consist of installing solar photovoltaic (PV) power systems in the existing parking lot around the Training Facility and Shops Buildings. The proposed solar installation is a series of carports, with columns spaced at 27'. This will include a double row of solar carports, and a minimum clearance height of 8'6". Footings of the carport system are 2'-6" in diameter. This component is estimated to generate approximately 625MWh of clean, renewable energy annually.

CONTACT PERSON James R. Howe	AREA CODE (213)	TELEPHONE NUMBER 367-0414	EXT.
--	---------------------------	-------------------------------------	-------------

EXEMPT STATUS:
 Categorical Exemption under CEQA Guidelines Section 15301, Class 1 (Existing Facilities) and Section 15303, Class 3 (New Construction or Conversion of Small Structures); Statutory Exemption under CEQA Guidelines Section 21080.35


JUSTIFICATION FOR PROJECT EXEMPTION:
 In accordance with the California Environmental Quality Act, the installation of carport solar PV at an existing facility/parking lot is categorically exempt pursuant to CEQA Guidelines Section 15301, Class 1 (Existing Facilities), Section 15303, Class 3 (New Construction or Conversion of Small Structures), and statutorily exempt pursuant to Public Resources Code (PRC) Section 21080.35. Section 15301, Class 1 consists of the operation, repair, maintenance, permitting, leasing, licensing, or minor alteration of existing public or private structures, facilities, mechanical equipment, or topographical features, involving negligible or no expansion of the existing or former use. Section 15303, Class 3 consists of construction and location of limited numbers of new, small facilities or structures; installation of small new equipment and facilities in small structures; and the conversion of existing small structures from one use to another where only minor modifications are made in the exterior of the structure. PRC Section 21080.35 applies in cases where a solar energy project is proposed to be installed at an existing parking lot which has been designated and used for parking vehicles for at least the previous two years and does not involve removal of a required or native tree over 25 years old, and associated solar equipment meets certain size, location, and other conditions. The proposal to install solar carport PV infrastructure meets the requirements of the exemption; therefore, no further CEQA review is required.

IF FILED BY APPLICANT, ATTACH CERTIFIED DOCUMENT OF EXEMPTION FINDING

SIGNATURE Charles C. Holloway	for	TITLE: Manager of Environmental Planning and Assessment	DATE 10/28/2021
FEE: \$75.00	RECEIPT NO.	REC'D BY	DATE


ENCLOSURES

Vicinity Map



Map and image data provided by: Google Maps

Truesdale Training Facility Solar Carport Site



Truesdale Training Facility Solar Carport Site



LEGEND:

Proposed Solar Carports



Double Cantilever

D

Single Cantilever

S

Training Facility Building

1