

## Well Test Report

Jacinto Bautista  
2450 Huasna Rd  
Arroyo Grande, Ca 93420

10/13/2021

Re: 4 Hr Well Test 2450 Huasna , Arroyo Grande

<u>Time</u>	<u>GPM</u>	<u>PWL</u>
9:00	33.8	39'
9:04	33.8	42'
9:10	33.8	49'
9:30	33.8	49'
10:00	33.8	49'
10:30	33.8	49'
11:00	33.8	49'
11:30	33.8	49'
12:00	33.8	49'
12:30	33.8	49'
1:00	33.8	49'
Recovery		
1:02	0	49'
1:10	0	41'

Static Water Level: 39'

Test was conducted using a water meter

Water Level with Electric Sounder (PWL = *pumping water level*)

**Thank You For Allowing Me To Be Of Assistance To Your Water Needs**

Wes Mello / Owner



Mello & Son's Pumps & Motors  
2773 Southview Ave.  
Arroyo Grande, CA 93420  
Office (805) 481-1286  
Cell (805) 886-8293



# Invoice

DATE	INVOICE #
10/14/2021	6304

2773 Southview Ave  
 Arroyo Grande, CA.93420  
 805-481-1286 886-8293  
 h2owes.com Lic#725485

BILL TO
Jacinto Bautista 2450 Huasna Rd Arroyo Grande, Ca 93420

WELL INFORMATION

LOCATION	TERMS	CONTACT
2450 Husana	Due on receipt	Jacinto

QTY	DESCRIPTION	PRICE EACH	AMOUNT
1	Conduct 4 hour well test at 2450 Huasna Rd. Collect bacteria water sample and take to lab.	700.00	700.00
	Sales Tax San Luis Obispo County	7.75%	0.00

Thank you for your business.	<b>Total</b>	\$700.00
------------------------------	--------------	----------

**Abalone Coast Analytical, Inc**

141 Suburban Road, Suite C-1 San Luis Obispo CA, 93401  
Phone: 595-1080 Fax: 595-1075  
ELAP #2661

Order #: 21-5036

Date/Time Rec'd: 10/15/21 0952

**Mello & Son's**  
2773 Southview Ave  
Arroyo Grande, CA 93420

**Contact: Wes Mello**  
**Phone: 805-481-1286**  
**Sampler: Wes Mello**

Project:

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	2450	10/15/21 0915	Total Coliform	SM 9223 B.	Absent	/100ml	1	10/16/21
			<i>E-coli</i>	IDEXX	Absent	/100ml	1	10/16/21
-2	8515	10/15/21 0800	Total Coliform	SM 9223 B.	Absent	/100ml	1	10/16/21
			<i>E-coli</i>	IDEXX	Absent	/100ml	1	10/16/21

This sample passes water quality standards for Total Coliform and E. Coli Bacteria

Report Completion date: 10/18/21

Reviewed: \_\_\_\_\_



Amanda Smith, Lab Director

**Definitions:**

Absent = Less than 1 CFU/100mLs

Present = 1

CFU = Colony Forming Unit

RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.