

## **Burris Basin GWRS Turnout Project**

Draft Preliminary Design Report



Prepared for:  
Orange County Water District  
18700 Ward Street  
Fountain Valley, CA 92780  
Contact Fernando Almario, P.E.

Prepared by:  
Stantec Consulting Services Inc.  
38 Technology Drive, Suite 100  
Irvine, CA 92618  
Contact: Kevin Brandt, P.E.

July 1, 2019

## Table of Contents

<b>EXECUTIVE SUMMARY</b> .....	<b>I</b>
<b>1.0 INTRODUCTION</b> .....	<b>1.1</b>
1.1 BACKGROUND .....	1.1
1.2 PROPOSED IMPROVEMENTS .....	1.2
<b>2.0 EXISTING CONDITIONS</b> .....	<b>2.3</b>
2.1 PROJECT SITE .....	2.3
2.2 PROPERTY OWNERSHIP .....	2.4
2.3 SITE TOPOGRAPHY .....	2.4
2.4 UTILITIES .....	2.5
2.5 CONSTRAINTS .....	2.5
<b>3.0 BASIS OF DESIGN</b> .....	<b>3.6</b>
3.1 DESIGN CRITERIA .....	3.6
3.1.1 Basin Grading .....	3.6
3.1.2 Site Grading .....	3.6
3.1.3 Mechanical Design Criteria .....	3.6
3.1.4 Structural Design Criteria .....	3.7
3.1.5 Electrical, Instrumentation and SCADA Design Criteria .....	3.8
3.2 HYDRAULIC MODELING .....	3.9
3.3 GEOTECHNICAL INVESTIGATION .....	3.11
<b>4.0 ALTERNATIVES</b> .....	<b>4.12</b>
4.1 ALTERNATIVES OVERVIEW .....	4.12
4.2 ALTERNATIVES ANALYSIS .....	4.13
<b>5.0 PROJECT ADMINISTRATION</b> .....	<b>5.14</b>
5.1 PERMITS .....	5.14
5.2 TECHNICAL SPECIFICATIONS .....	5.14
<b>6.0 REFERENCES</b> .....	<b>6.17</b>

### LIST OF TABLES

Table 2.1 Existing Utilities .....	2.5
Table 3.1 GWRS Operational Scenarios .....	3.10
Table 3.2 Model Results .....	3.11
Table 4.1 Alternatives .....	4.12
Table 4.2 Alternatives Analysis .....	4.13
Table 5.1 Permits .....	5.14
Table 5.2 Technical Specifications .....	5.14

# BURRIS BASIN GWRS TURNOUT PROJECT

## LIST OF FIGURES

Figure 1 Location Map .....	1.1
Figure 2 Existing Site Map .....	2.3

## LIST OF APPENDICES

<b>APPENDIX A</b> .....	<b>A.1</b>
A.1 GWRS HYDRAULIC MODELING RESULTS .....	A.1
<b>APPENDIX B</b> .....	<b>B.2</b>
B.1 PRELIMINARY OPINION OF PROBABLE COSTS .....	B.2
<b>APPENDIX C</b> .....	<b>C.3</b>
C.1 PIPE WALL THICKNESS DESIGN .....	C.3
<b>APPENDIX D</b> .....	<b>D.4</b>
D.1 SCHEMATIC DESIGNS .....	D.4
<b>APPENDIX E</b> .....	<b>E.5</b>
E.1 CATALOGUE CUT SHEETS .....	E.5

### Executive Summary

Orange County Water District (OCWD) currently owns and operates approximately 1,200 acres of recharge spreading facilities in and adjacent to the Santa Ana River, Carbon Creek, and Santiago Creek. A significant part of the operations entails the pumping of purified water from the Ground Water Replenishment System (GWRS) water treatment plant in Fountain Valley northward to a series of four recharge basins (Miller, Kraemer, Miraloma and La Palma Basins) located in Anaheim via the GWRS pipeline. The GWRS plant is currently undergoing a “Final Expansion” which, when completed in 2023, will allow OCWD to produce up to 130 MGD of purified water. Of the 130 MGD produced, approximately 100 MGD will be delivered to the northern recharge basins with the balance of purified water used for the Mid Basin Injection (MBI) Turnout and Talbert seawater intrusion barrier.

With increased GWRS production, and the desire for additional operational flexibility, OCWD has determined a turnout from the GWRS pipeline to Burris Basin is warranted. The new turnout will allow OCWD to divert flows to Burris Basin ranging from 7 MGD up to a maximum of 100 MGD. During maximum flow diversions of 100 MGD, OCWD will be able to take three of the northerly recharge basins offline for maintenance during this operational scenario (Miller, Kraemer and Miraloma Basins).

The following items will be discussed in more detail in this PDR:

1. Introduction – Project background and proposed improvements / objectives.
2. Existing Conditions – Summarizes the existing conditions at the project site and surrounding area. Project constraints are discussed including center levee requirements, basin improvements, basin operations and existing utilities.
3. Basis of Design – Establishes the design criteria to be used for the final design of the various proposed improvements. Also includes hydraulic modeling results for the GWRS system.
4. Alternatives – Summarizes advantages / disadvantages of the alternative designs developed for the proposed project.
5. Project Administration – Summarizes the permits required for construction of the proposed improvements and a listing of the recommended technical specifications required for the bid construction documents.
6. References

Also included in the attached Appendix are schematic designs, supporting calculations, catalogue cut sheets with quotes for the various materials / instrumentation / devices, hydraulic modeling data, and preliminary opinion of probable costs.

# BURRIS BASIN GWRS TURNOUT PROJECT

INTRODUCTION  
July 1, 2019

## 1.0 INTRODUCTION

### 1.1 BACKGROUND

The proposed Burris Basin turnout is located at the southern end of Burris Basin, north of Ball Road and west of the Santa Ana River. Burris Basin provides some recharge but is primarily a reservoir for storing water that is pumped to the Santiago Basins. Burris basin is separated from the Santa Ana River by the existing Santa Ana River Levee, commonly referred to as the "center levee". The existing GWRS pipeline is located within the center levee and all proposed work within or influenced by the center levee is under Army Corps of Engineers (ACOE) jurisdiction and subject to their review. The GWRS line is located within property owned by Orange County Flood Control District (OCFCD) and all proposed work within OCFCD property will also need to be reviewed / approved by OCFCD.




Figure 1 Location Map

# BURRIS BASIN GWRS TURNOUT PROJECT

## INTRODUCTION

July 1, 2019

## 1.2 PROPOSED IMPROVEMENTS

Proposed improvements include grading, pipes, valves, meters and structures. The improvements, and associated objectives are summarized below:

### Grading

- Provide a graded pad area that will allow for OCWD operations and maintenance access to the proposed facilities;
- Balance site from an earthwork standpoint (materials will be generated from the Burris Basin floor and per the Geotech's recommended offset from the center levee);
- Graded slopes at ratio per geotechnical recommendations;
- Graded ramp that will allow ingress and egress to the basin floor; and
- Improvements that do not impact the center levee and in conformance with Corps requirements.

### Pipeline

- Provide a pipe configuration that will allow for the diversion of GWRS water into Burris Basin given the variable flow scenarios ranging from about 7 MGD to 100 MGD;
- Consider use of parallel piping to reduce valve and meter sizes and increase operational /maintenance flexibility; and
- Use of steel pipe with cement coating and epoxy lined to resist corrosion;

### Appurtenances

- Provide a manual isolation valve between the GWRS pipeline and turnout assembly;
- Motor operated valves for "throttling" flow rates to the basin;
- Meters to track quantity of water delivered; and
- Water level sensor in air gap structure for back-up flow measurement.

### Structures

- Air-gap structure designed to prevent siphoning of basin water into GWRS pipeline; and
- Dissipation structure designed to prevent basin shore erosion.

### Electrical and Instrumentation

- Provide power needed to operate and monitor proposed devices / instrumentation;
- Provide remote monitoring and control of various facility devices including motor operated valves, flow meters, and water level sensors; and
- Ensure new devices are integrated into the District's existing SCADA system.

# BURRIS BASIN GWRS TURNOUT PROJECT

EXISTING CONDITIONS

July 1, 2019

## 2.0 EXISTING CONDITIONS

### 2.1 PROJECT SITE

The project site is located near the southeasterly corner of Burris Basin and is bounded by Ball Road to the south and the Santa Ana River to the east. The site is separated from the Santa Ana River by a levee (center levee). Additional information as follows:

- the existing GWRS pipeline is located within the center levee;
- a fiber optic run for GWRS signal / control is located adjacent to the mainline pipe;
- the GWRS pipeline is a 66" diameter CMC&CL pipe which reduces to a 60" diameter followed by a 60" tee located at the proposed turnout location;
- there is an existing 60" mainline BFV just downstream of the tee which when closed allows for mainline draining via a 12" pipe to Burris Basin;
- above ground equipment includes meter pedestal / power distribution panel and RTU
- earthen access ramp from the center levee to bottom of Burris Basin;
- 16" crude oil line (not anticipated to be a conflict); and
- abandoned 36" CMP SD line that runs perpendicular to the GWRS line (to be removed if there's a conflict with the proposed improvements).

Burris Basin is operated at a normal water surface elevation of 165.0 and has an overflow spillway located at the southwesterly corner of the basin at elevation 174.0.




Figure 2 Existing Site Map

## **BURRIS BASIN GWRS TURNOUT PROJECT**

EXISTING CONDITIONS

July 1, 2019

### **2.2 PROPERTY OWNERSHIP**

Burriss Basin is owned and operated by OCWD. Burriss Basin is adjacent to the Santa Ana River which is owned and operated by Orange County Flood Control District (OCFCD). Within the center levee, OCWD has an easement over the GWRS pipeline granted by OCFCD.

### **2.3 SITE TOPOGRAPHY**

The existing site and surrounding terrain have been mapped by generating an aerial topo compiled at a 2-foot contour interval. OCWD has provided the topo and it has been used previously to construct the Burriss and Lincoln Basins Reconfiguration Project (circa 2010) and more recently the Burriss Basin Pump Station Project.

The project vertical and horizontal control are based on the following:

#### **BASIS OF BEARINGS**

THE BEARINGS SHOWN HEREON ARE BASED ON THE GRID BEARING "**N 01°05'12" E**" BETWEEN O.C.S. HORIZONTAL CONTROL STATION GPS NO. **3282** AND GPS NO. **5247R1** PER RECORDS ON FILE IN THE OFFICE OF THE ORANGE COUNTY SURVEYOR.

#### **DATUM STATEMENT**

COORDINATES ARE BASED ON THE CALIFORNIA COORDINATE SYSTEM (CCS83) ZONE VI, NAD 83 (2007.00 EPOCH ADJUSTMENT), AS PER RECORDS ON FILE IN THE OFFICE OF THE ORANGE COUNTY SURVEYOR.

#### **BENCHMARK**

THE ELEVATIONS SHOWN ARE BASED ON O.C.S. BENCHMARK 1L-57-82, USING NAVD88 ELEVATION OF 190.113', PER RECORDS ON FILE IN THE OFFICE OF THE ORANGE COUNTY SURVEYOR.

#### **FIELD SURVEYS**

Supplemental topography will be generated by Stantec field survey crews to verify the existing topography and obtain precise information at specific key features and join points. Surveyors will also be on-site when potholing occurs to capture horizontal and vertical location of potholed items.

Stantec's mapping specialist will research existing record maps / monumentation prior to field crews visiting the site. The survey crew will locate the monuments and confirm the basis of bearing calculated is accurate. The mapping base will be oriented / adjusted to match the field verified data.



# BURRIS BASIN GWRS TURNOUT PROJECT

EXISTING CONDITIONS

July 1, 2019

## 2.4 UTILITIES

Existing utilities located within the project site have been identified on the schematic design. A DigAlert search was conducted resulting in a list of potential purveyors with utilities in the local vicinity of the project. The purveyors were contacted, and record information requested. The only utility known at this time to be in close proximity of the proposed improvements is included in the table below:

**Table 2.1 Existing Utilities**

<b>Agency/Utility</b>	<b>Contact</b>	<b>Email</b>	<b>Phone Number</b>
16" Crude Oil Line	Cole Wright	cole.wright@dominionenergy.com	(307) 352-7115
12" GWRS Drain Line	Fernando Almario	falmario@ocwd.com	(714) 378-8220

## 2.5 CONSTRAINTS

Known project constraints that may affect the project design features include the following:

- Center levee
- Burris Basin operations
- OCFCD operations
- Existing GWRS pipeline and associated appurtenances

## BURRIS BASIN GWRS TURNOUT PROJECT

BASIS OF DESIGN  
July 1, 2019

### 3.0 BASIS OF DESIGN

#### 3.1 DESIGN CRITERIA

The following subsections detail the design criteria to be used for the proposed improvements design.

##### 3.1.1 Basin Grading

- 2:1 slopes minimum;
- positive drainage;
- 0.3% minimum slope for basin floor; and
- adherence to geotechnical recommendations.

##### 3.1.2 Site Grading

- Adequate pad area for operations and maintenance;
- earthen ramps to basin floor at 15 feet wide;
- minimum inside turning radius of 30 feet;
- maximum slope of 10% for ramps; and
- fill material excavated from basin floor.

##### 3.1.3 Mechanical Design Criteria

###### Pipeline design criteria:

- Material: steel with cement mortar coating and epoxy lining;
- corrosion protection commensurate with Geotech findings;
- Minimum cover: 48";
- Minimum slope: 0.0% for pressure lines;
- Steel wall thickness based on AWWA M11 5<sup>th</sup> edition (see Appendix for preliminary pipe wall thickness calculations):
  - internal pressure,
  - deflection, and
  - buckling
- Pipe diameter based on:
  - maximum design flow rate of about 155 cfs;
  - maximum velocity of 8 fps
  - Hazen Williams Equation and roughness coefficient  $C = 130$

## BURRIS BASIN GWRS TURNOUT PROJECT

BASIS OF DESIGN

July 1, 2019

### Valve design criteria:

#### Butterfly Valves

- worm gear operators;
- electric motor and manual actuators; and
- Pratt or Dezurik BFVs and AUMA actuators or approved equal.

A single 60" isolation BFV is proposed at the existing GWRS pipeline 60" tee. This valve will be manually operated and buried.

#### Ball Valves

- Metal seated; and
- Pratt or Dezurik dependent upon available sizes.

Ball valves are proposed for all schematic design alternatives (see Section 4) for control of flow rates through the turnout structure. In alternatives 1 & 2, both ball valves will be controlled in tandem to achieve desired flow rate.

### Meter design criteria:

- magnetic type with forward and reverse flow measurement capability;
- no bends, valves etc. within five pipe diameters upstream and three pipe diameters downstream (or per selected manufacturer's recommendations); and
- Khrono Tidaflex 4000 Series or approved equal.

Two mag meters are proposed for the 36" & 48" pipes in schematic design alternatives 1 & 2 (see Section 4), or a single mag meter for the 60" pipe in alternative 3.

### Level sensor design criteria:

- Pressure transducer type (Druck) and / or ultrasonic type (Siemens AG) dependent upon installation location.

Water level sensors are proposed within the air gap structure (ultrasonic) and Burris Basin near the proposed dissipator structure (transducer).

### 3.1.4 Structural Design Criteria

Structures will include an air-gap and dissipator and will be designed to meet the following current edition criteria:

- California Building Code; and
- ACI 318-11 Building Code Requirements for Structural Concrete

## BURRIS BASIN GWRS TURNOUT PROJECT

### BASIS OF DESIGN

July 1, 2019

Material properties will meet the following:

- Concrete strength,  $f'c = 4,000$  psi;
- Concrete cement type per project's Geotech Report corrosivity test results (Type II or V cement);
- Reinforcing steel, ASTM 615, Gr. 60,  $f_y = 60,000$  psi;
- Seismic Design Criteria obtained from USGS and the project's Geotechnical Report; and
- Soil design parameters obtained from the project's Geotechnical Report.

### 3.1.5 Electrical, Instrumentation and SCADA Design Criteria

#### Electrical design criteria:

- Comply with edition of the NEC recognized by the Authority Having Jurisdiction.
- Utilize the existing 100A, 277Y/480V electric service. The serving electric utility company is the City of Anaheim. The electric utility meter number is 58S422NKS.
- Expand the power distribution system that emanates from the existing electric service. The existing system consists of a 100A, 277Y/480 panelboard and a 10kVA, 480V:120/240V single phase transformer with 40A, 120/240V panelboard in the form of an integrated unit. A second similar integrated unit will be added if enough spare 120V circuits do not exist.

#### Instrumentation design criteria:

##### Control Panel

- Comply with edition of the NEC recognized by the Authority Having Jurisdiction.
- Expand the existing system Control Panel CPC-003 (GWRS Pipeline Valve Vault #3 Panel) to provide for additional level, flow and valve monitoring and control.
- The existing Phoenix Contact Inline Bus Coupler FL IL 24 BK-PAC – 2862314 has since reached obsolescence and will need to be replaced. Existing modular I/O modules shall be reviewed for reuse.

##### Flow Control Ball Valves

- Provide I/O and connections for monitoring and control of two electric actuators associated with the flow control ball valves - valve control, position, limits and alerts etc.

##### Flow Meters

- Khrono Tidaflex 4000 Series or approved equal magnetic type with forward and reverse flow measurement capability; (Two FM's Design Alt. 1 & 2 or one FM for Design Alt. 3).

##### Level Measurement

- One Pressure transducer type (Druck) and / or ultrasonic type (Siemens AG) dependent upon final installation location.

## BURRIS BASIN GWRS TURNOUT PROJECT

BASIS OF DESIGN

July 1, 2019

### SCADA design criteria:

- Communications between the project site and the District's Central SCADA system located at the District's Field Headquarters is existing and makes use of fiber optic;
- Local PLCs will be Phoenix Contact InLine Series, Ethernet capable with standard PLC I/O and communication to level sensors, flow meters and motor operated valves;
- Data acquisition through the SCADA system to include air-gap structure water level, basin water level, flow rates, valve motor on/off and valve positioning;
- Remote control of valve motor on/off and valve positioning; and
- Automatic valve motor on/off in relationship to water level in the basin.

## 3.2 HYDRAULIC MODELING

Hydraulic modeling was conducted to determine water distribution effects due to the proposed Burris Basin turnout. Utilizing Innovyze InfoWater, the GWRS pipeline network model was updated to run the following scenarios:

- Scenario 1 – The proposed Burris Basin turnout is closed and not being utilized.
- Scenarios 2A & 2B – Considered "typical" operational ranges for the various basins, except for Kraemer Basin, which is closed under Scenarios 2A & 2B.
- Scenario 3 – Assumes MET imports to Kraemer and Miller Basins and therefore no GWRS water to these basins.
- Scenario 4 – This scenario delivers 100 mgd to Burris Basin and allows for Miraloma, Kraemer, and Miller to be placed offline for maintenance. La Palma Basin is allowed to flow at 13 mgd. This scenario would also apply if the groundwater producers stop pumping from the basin and are purchasing "in-lieu" water from MET (groundwater elevations in the basin would rise, thus Talbert Barrier injection would be ramped down).

## BURRIS BASIN GWRS TURNOUT PROJECT

BASIS OF DESIGN

July 1, 2019

The table below summarizes actual water delivery flow rates analyzed.

**Table 3.1 GWRS Operational Scenarios**

	GWRS FLOW SCENARIOS (MGD)				
	1	2A	2B	3	4
<b>MBI Turnout</b>	8	8	8	8	8
<b>Burris</b>	0	7	10	25	100
<b>La Palma</b>	65	65	65	65	13
<b>Miraloma</b>	13	13	13	13	0
<b>Kraemer</b>	25	0	0	0	0
<b>Miller</b>	0	20	15	0	0
<b>Total GWRS Pumped Flow*</b>	111	113	111	111	121
<b>Talbert Seawater Barrier</b>	19	17	19	19	9
<b>TOTAL</b>	130	130	130	130	130

*\*Note: Total GWRS Pumped Flow assumes an additional water source from the proposed Huntington Beach Desalination Plant. A total of 100 MGD will be the maximum GWRS Water Purification Plant output after final expansion.*

Variable Speed Pump Control was added to the pumps in the model to simulate the existing variable frequency drive (VFD) system and to adjust the downstream pressure setting. In this analysis, the downstream pressure was set to 130 psi. The roughness coefficient was set at 130 for the transmission mains in the hydraulic model. In addition, the following weir heights were entered into the model.

La Palma: 231  
 Miraloma: 231  
 Miller: 234  
 Kraemer: 229

Appendix A.1 includes a hydraulic model exhibit and a representative pump curve. Since the total GWRS pumped flows do not vary much from one scenario to another, pump curves for a single scenario is included in Appendix A.1 and is intended to be representative of all provided scenarios.

In each of the five scenarios described in Table 3.1, the resulting pressures at Burris Basin, at the proposed elevations of 184 feet and 194 feet, were verified and summarized in Table 3.2 below. The analysis also verified that there would be sufficient pressure (i.e. positive pressure) for water to flow over the weir at each of the four existing basins. Model results in Table 3.2 below indicate the existing GWRS system will function as desired under the various flow scenarios. These results assume head needed to pump to the upper basins is available; however, the District understands a booster pump would be necessary to achieve the desired flow rates. Currently the booster pump is envisioned to reside at Burris Basin and would tie into the proposed GWRS Turnout infrastructure.

## BURRIS BASIN GWRS TURNOUT PROJECT

BASIS OF DESIGN  
July 1, 2019

**Table 3.2 Model Results**

Scenario	Meets GWRS Flow Scenarios*	Pressure (psi)		Head Loss at Burris Basin Turnout	Burris Basin Turnout 60" CMC&EL Pipeline Velocity (ft/s)
		at 194 msel	at 184 msel		
1	Yes	19	24	-	-
2A	Yes	18	22	0.02 ft/1000ft	0.55
2B	Yes	19	24	0.04 ft/1000ft	0.79
3	Yes	19	24	0.20 ft/1000ft	1.97
4	Yes	9	14	2.57 ft/1000ft	7.88

\*Note: "Yes" in this category indicates that the GWRS system has adequate pressure to deliver water per the flow scenarios defined in Table 3.1 above.

### 3.3 GEOTECHNICAL INVESTIGATION

Stantec subconsultant, Ninyo & Moore (N&M), will conduct a geotechnical investigation. A "Drilling Program Plan" will be prepared for Corps of Engineers review prior to conducting the field work. The geotechnical recommendations will be incorporated into design criteria.

# BURRIS BASIN GWRS TURNOUT PROJECT

ALTERNATIVES  
July 1, 2019

## 4.0 ALTERNATIVES

### 4.1 ALTERNATIVES OVERVIEW

Stantec has developed two alternatives for OCWD consideration, a summary of which is presented below

**Table 4.1 Alternatives**

Alternative Number	Description
1	<ul style="list-style-type: none"><li>• Graded pad on Burris side of center levee large enough to allow access around turnout structure and air-gap structure.</li><li>• Earthen ramp allowing access to basin floor.</li><li>• 60" CMC&amp;EL line and 60" butterfly valve connects to existing flange.</li><li>• 60" line runs northward and flanges into underground 60"x36" tee.<ul style="list-style-type: none"><li>◦ 48" CMC&amp;EL steel pipe on tee run.</li><li>◦ 36" CMC&amp;EL steel pipe on tee branch.</li></ul></li><li>• 36" and 48" line bend vertically out of ground.</li><li>• 48" &amp; 36" lines outlet into Air Gap structure with 15' wide weir 10'± above graded pad. Level sensor within Air Gap.</li><li>• Air Gap structure outlets to dissipation structure.</li></ul>
2	<ul style="list-style-type: none"><li>• Graded pad on Burris side of center levee large enough to allow access around turnout structure and air-gap structure.</li><li>• Earthen ramp allowing access to basin floor.</li><li>• 60" CMC&amp;EL line and 60" butterfly valve connects to existing flange.</li><li>• 60" line runs northward and is entirely underground.</li><li>• Metering and valving on 60" line within vaults.</li><li>• 60" lines outlet into Air Gap structure with 15' wide weir 10'± above graded pad. Level sensor within Air Gap.</li><li>• Air Gap structure outlets to dissipation structure.</li></ul>

Additionally, an "option" is presented for OCWD's consideration. This option may apply to one or more above alternative:

- For both alternatives, an option to provide a blind flanged tee for future pump station connection is available to OCWD.



## BURRIS BASIN GWRS TURNOUT PROJECT

ALTERNATIVES  
July 1, 2019

### 4.2 ALTERNATIVES ANALYSIS

OCWD operational needs and cost will be considered in this decision. A matrix of considerations is presented below in Table 4.2.

**Table 4.2 Alternatives Analysis**

	<b>Alternative 1</b> 36" & 48" parallel lines	<b>Alternative 2</b> Single 60" line
Design Objectives Met	3	3
Site Constraints Met	3	3
Cost	TBD	TBD
OCWD Operational Flexibility	3	2
Total Score	9	8

Note: "1" – Least Ideal, "2" – Sufficient and "3" – Most Ideal

Alternative 1 ranks the highest and is the recommended alternative for final design. This is primarily due to the greater operational flexibility it provides OCWD. Pipes in parallel act as bypasses if maintenance on either line is needed. Also, above ground assembly prevents the need for OCWD to work in a confined space. Preliminary Opinions of Probable Costs for each alternative have been prepared and are summarized below (see Appendix for line item costs):

- Alternative 1 - \$xxx
- Alternative 2 - \$xxx

## BURRIS BASIN GWRS TURNOUT PROJECT

PROJECT ADMINISTRATION

July 1, 2019

### 5.0 PROJECT ADMINISTRATION

#### 5.1 PERMITS

A summary of anticipated permits required for the project are included Table 5.1 below.

**Table 5.1 Permits**

Permit Type	Description
OCFCD Property Encroachment Permit	An encroachment permit is necessary for the proposed improvements considering the existing tee falls within OC property.
Army Corps 408 Permit	A 408 Permit will be required considering the proposed improvements fall with the center levee and therefore subject to Corps review.
401 / 404 Permit	TBD
1600 Permit	TBD

#### 5.2 TECHNICAL SPECIFICATIONS

The following is a preliminary list of anticipated technical specifications to be developed for the project construction documents:

**Table 5.2 Technical Specifications**

Section	Description
Division 1 – General Project Provisions	
01000	General Safety Requirements
01045	Existing Facilities
01150	Measurement and Payment
01300	Submittals
01310	Project Control Schedule
01430	Maintenance Manual Requirements
Division 2 – Construction/Installation Provisions	
02100	Site Preparation
02140	Dewatering and Drainage
02201	Earthwork
02220	Structure Backfill
02221	Demolition and Salvage
02223	Trenching, Backfilling, and Compacting

## BURRIS BASIN GWRS TURNOUT PROJECT

PROJECT ADMINISTRATION

July 1, 2019

Section	Description
02271	Rip-Rap
02433	Reinforced Concrete Pipe
02444	Fencing
02718	Installation of Water Pipeline
<b>Division 3 – Concrete Provisions</b>	
03150	Formwork for Cast-in-place Concrete
03200	Reinforcing
03260	Concrete Joints and Waterstops
03300	Cast-in-Place Concrete
03345	Concrete Finishing, Curing and Waterproofing
03462	Precast Concrete Vaults and Meter Boxes
<b>Division 5 - Metals</b>	
05120	Structural Steel
05125	Miscellaneous Metals
<b>Division 9 – Finishes (Coatings)</b>	
09900	Painting and Protective Coatings
09960	Protective Coating for Concrete Structures
<b>Division 11 – Equipment</b>	
11005	General Mechanical and Equipment Provisions
11293	Motor Operators
11300	Meters
11400	Level Sensors
11500	Equipment House
<b>Division 15 – Mechanical</b>	
15042	Hydrostatic Testing of Pressure Pipelines
15043	Leakage and Infiltration Testing of Non-Pressure Pipelines
15051	Installation of Pressure Pipelines
15076	Epoxy Lined and Cement Coated Steel Pipe
15089	Air Valves
15100	Butterfly Valves
15101	Motor Operators
15151	Water Facilities Identification
15180	Flow Meters
<b>Division 16 – Electrical</b>	
16010	General Electrical Requirements
16111	Metal Conduit and Fittings
16112	Plastic Conduit and Fittings
16121	Low Voltage Wire and Cable
16130	Boxes
16190	Supports and Fasteners
16195	Identification
16450	Grounding
16461	Dry-Type Transformers
16470	Panelboards

## BURRIS BASIN GWRS TURNOUT PROJECT

PROJECT ADMINISTRATION

July 1, 2019

<b>Section</b>	<b>Description</b>
16475	Molded Case Circuit Breakers
Division 17 – Programmable System Provisions	
17000	General Instrumentation Control Requirements
17110	Identification Tags
17200	Miscellaneous Instrumentation Equipment
17300	PLCs and Programmable Operator Interfaces
17330	SCADA System Hardware and Software

## BURRIS BASIN GWRS TURNOUT PROJECT

### REFERENCES

July 1, 2019

## 6.0 REFERENCES

1. Record Drawings for "Groundwater Replenishment Pipeline Unit III, Contract No. GWRS-2003-03", dated April 2003, prepared by Tetra Tech Inc.

## **BURRIS BASIN GWRS TURNOUT PROJECT**


Appendix A  
July 1, 2019

# **Appendix A**

## **A.1 GWRS HYDRAULIC MODELING RESULTS**

GWR Model Layout Exhibit

Typical Flow Scenario – GWR Pump Curves




MAP DOCUMENT PATH: V:\2042\active\2042499000\design\analysis\Burriss Basin Analysis\Burriss\_Basin\_2.mxd SA VEB: 7/1/2019 1:27:54 PM BY: ml

Exhibit Path: V:\2042\active\2042499000\design\analysis\Burriss Basin Analysis\Figures\Figure 3-1 Hydraulic Model.pdf




# Pump 5003 at 00:00 hrs







# Pump 5009 at 00:00 hrs




# Pump 5013 at 00:00 hrs



# Pump 5015 at 00:00 hrs



# Pump 5017 at 00:00 hrs



## **Appendix B**

### **B.1 PRELIMINARY OPINION OF PROBABLE COSTS**

Alternative 1 OPC

Alternative 2 OPC

Alternative 3 OPC

## **BURRIS BASIN GWRS TURNOUT PROJECT**

Appendix C  
July 1, 2019

# **Appendix C**

## **C.1 PIPE WALL THICKNESS DESIGN**

Client: (Client Name here)  
 Project: (Project Name Here)  
 Description: (Description of what is being calculated, specific building, system, discipline, etc...)

Sheet: \_\_\_\_\_ of \_\_\_\_\_  
 Date: mm/dd/yy  
 Job No: xxxxxx  
 By: (Author) Chkd By: xxx

Steel Pipe Wall Design - Trench Condition

Steel Pipe Wall Design - Trench Condition  
 Steel Cylinder Structural Calculations per AWWA M11 - Fourth Edition (2004)

Input Section		Output Section	
Nominal Diameter of Pipe (DN, in.) =	48.000	Allowable Stress, Working ( $s_w$ , psi), $Y_1/SF_w$ =	16,500
Select type of Lining =	Epoxy	Allowable Stress, Transient ( $s_t$ , psi), $Y_2/SF_s$ =	22,000
Internal Working Pressure ( $p_w$ , psi) =	24.00	Allowable Stress, Test/Shutoff ( $s$ , psi), $Y_3/SF_t$ =	22,000
Test Pressure- ( $p_t$ , psi) =	150.00		
Transient Pressure ( $p_t$ , psi) [Limit to 1.33 $p_w$ ] (See note 1) =	31.92		
Pump Shutoff Pressure ( $p_{sh}$ , psi) =	300.00		
Specified Minimum Yield Point of Steel ( $Y_s$ , psi) (See note 2) =	33,000	Mortar Lining Thickness ( $t_l$ , in.) =	0.000
Safety Factor, Working ( $SF_w$ ) =	2.0	Internal Diameter (ID, in.) =	48.00
Safety Factor, Transient Pressure ( $SF_s$ ) =	1.5	ID requirement based on (see note 2A) =	MWH
Safety Factor, Test Pressure/Pump Shutoff ( $SF_t$ ) =	1.5		

**Legend**  
 Red Numbers = Input required

**Sheet Notes:**

- MWH surge allowance is limited to 1.33  $p_w$  - Use actual surge value if higher. (See Hydraulic Lead/Surge report for surge values)
- Yield Stress -  $Y_s$  limited to:  
 33,000 psi - Mortar Lined and Coated pipe  
 42,000 psi - Mortar Lined - Flexible Coated pipe  
 50,000 psi - Flexible Lined and Coated pipe
- Use OD/t = 240 for handling, unless justified otherwise, for mortar lined pipe.
- Use OD/t ≤ 288 for OD up to 54" (M11 Eq 4-5). For OD ≥ 54", use  $t_z$  (OD+20)/400 (M11 Eq 4-6).
- Use the maximum of the wall thicknesses calculated by pressure, handling or the minimum thickness shown for the pipe or fitting.
- Minimum allowable pressure to avoid vapor pressure of fluid and associated cavitation is -5.00 psi

Input Section		Output Section	
Wall thickness to use in design ( $t_w$ , in) =	0.5000	Mean Dia (D, in), OD - $t_w$ - $t_l$ =	48.50
Mortar Coating Thickness ( $t_c$ , in) (See note 7) =	1.00	Cylinder Outside Dia (OD, in), ID + 2 $t_c$ + 2 $t_l$ =	49.00
Soil backfill type	Sand & gravel	Pipe Outside Dia ( $B_o$ , ft), OD + 2 $t_c$ =	4.250
Depth of soil cover (H, ft) =	5.50	Wall stiffness (EI, in <sup>4</sup> /in), $30E10^6 I_s + 4E10^6 (I_l + I_c)$ =	645,833
Distance beyond pipe OD to trench wall (m, ft) =	1.00	Steel moment of inertia ( $I_s$ , in <sup>4</sup> /linear in), $t_w^3/12$ =	0.0104
Trench width at top of the pipe ( $B_g$ , ft) = $B_o$ + 2m	6.25	Lining moment of inertia ( $I_l$ , in <sup>4</sup> /linear in), $t_l^3/12$ =	0.0000
Transition width ( $B_{tr}$ , ft) (Go to "transition" tab to calculate $B_{tr}$ )	7.05	Coating moment of inertia ( $I_c$ , in <sup>4</sup> /linear in), $t_c^3/12$ =	0.0833
Included additional load to apply to pipe	distributed load	Mean radius (r, in), D/2 =	24.25
Load, (Y, lbs)	67,500.0	$B_o/B_c$ =	1.47
Length of loaded surface area, a (ft)	3.40	Distributed load impact factor, I =	1.00
Width of loaded surface area, b (ft)	2.01	Surcharge load (W <sub>y</sub> , psf), $Y \cdot I / [(a+H)(b+H)]$ =	1,010
Unit weight of soil (w, pcf) =	120.00	Lane loading (LL, psf) =	0
Height of water surface above top of pipe ( $h_w$ , ft) =	0.00	Wheel load spread width (A, ft), $5.67+H$ =	0.00
Include saturated soil weight in deflection calc (Y/N) (see note 10) =	No	Wheel load spread length (B, ft), $0.83+H$ =	0.00
Live load (HS-20 Single/HS-20 ALT./E80/NA) =	NA	Alternate live load backfill factor (f) =	0.00
Modulus of soil reaction, $E'$ =	Per AWWA M11 500.00	Gov'n dimension parallel to long axis of pipe (L, ft) =	0.00
Modulus of the soil reaction ( $E'$ , psi) (See table 6-1 and note 8) =	500.00	$E'_s/E'_b$ =	NA
Native soil modulus ( $E'_s$ , psi) (See table 5-6) =	0.00	Modulus of soil reaction ( $E'$ , psi) =	500.00
Modulus of the backfill soil ( $E'_b$ , psi) (See table 6-1 and note 8) =	0.00	Bedding constant (K) =	0.110
Soil support combining factor ( $S_c$ ) (See table 5-5) =	0.00		
Deflection lag factor ( $D_L$ , 1.0-1.5) (See note 9) =	1.50		
Select bedding angle ( $\theta$ , degree) =	0		

**Notes for Designer:**

- Limit Mortar Coating to 1" max in  $\Delta x$  Calculations
- Selection of  $E'$  value from Table 6-1 shall be limited to 85% relative compaction effort, unless otherwise approved by Geotechnical Engineer. Coordinate with Geotechnical Report for suitable  $E'$  value for pipeline design.
- The deflection Lag factor is 1.0 for a pressurized pipe, however, if the pipe will sit empty for periods of time the value would be greater than 1.0.
- Saturated soil weight is accounted for using buoyancy reduction factor ( $R_w$ ).

Determination of External Load and Deflection for Trench Condition	
Earth load for trench condition ( $W_c$ , lb/linear in.), Non-saturated soil: $0.0361h_w B_c + R_w H w B_g / 12$ =	233.75
<b>Determination of Live Load for HS-20 wheel Or Cooper E-80 Railroad Loading</b>	
Highway loading per AWWA M11	
Single HS-20 truck live load on pipe from table 6-3 ( $P_L$ , psf) =	0.00
Single HS-20 truck live load on pipe ( $W_L$ , lb/linear in.), $P_L B_c / 12$ =	0.00
Alternate Highway loading per AASHTO	
Impact factor for highway ( $I_h$ , %), $33 \cdot (1 - 0.125H) / 100$ =	0%
Total wheel load applied at the surface ( $P_s$ , lbs) =	0
Total live load assuming truck travel transverse to pipe centerline ( $W_T$ , lbs), $[P(1+I_h)/(AB)+LL] \cdot A \cdot \text{Min}(B, B_c)$ =	0
Total live load assuming truck travel parallel to pipe centerline ( $W_P$ , lbs), $[P(1+I_h)/(AB)+LL] \cdot B \cdot \text{Min}(A, B_c)$ =	0
HS-20 ALT, Maximum AASHTO HS-20 Passing truck live load on pipe ( $W_L$ , lb/linear in.), $\{ \text{Max}(W_T, W_P) / [L + 1.75(0.75B_c)] \} / 12$ =	0.00
Railroad loading per AWWA M11	
Railroad loading on pipe from table 6-3 ( $W_L$ , lb/linear in.) =	0.00
Surcharge loading	
Surcharge loading on pipe ( $W_y$ , lb/linear in.) =	357.67
<b>Total External Load</b>	
Total external load on pipe ( $W$ , lb/linear in.) =	591.42
<b>Deflection Results (Eqn 6-5, AWWA M11)</b>	
Vertical/Horizontal deflection of the pipe ( $\Delta x$ , in), $D_L [KW^3 / (EI + 0.061E'r^3)]$ =	1.29
Percent deflection, $\Delta x/D$ =	2.65%
This is not a standard type of pipe	

**Notes for Designer:**

- Allowable deflections used herein are set at 75% of allowable deflections shown in AWWA M11, consistent with MWH standards.
- Where internal vacuum occurs with cover depth less than 4 ft but not less than 2 ft care should be exercised in defining allowable buckling pressure. (AWWA M11 buckling footnote)
- Design factor  $FS=2.0$  is recommended by AWWA M11 4th Ed for all depths in buckling calculation. AWWA M11 3rd Ed recommended  $FS=3.0$  for  $H/B_c < 2.0$  and  $FS=2.5$  for  $H/B_c \geq 2.0$ .
- Total negative pressure does not include surcharge load.

Input Section		Output Section	
Include internal vacuum pressure	Yes	Water buoyancy factor ( $R_w$ ), $1 - (0.33(h_w/H))$ =	1.00
Internal vacuum pressure ( $P_v$ , psi) =	14.70	Elastic support coefficient, (B), $1 / (1 + 4e^{-0.0001B})$ =	0.26
Buckling factor of safety based on AWWA M-11 (3rd Ed/4th Ed)	4th Ed (2004)	$H/B_c$ =	1.29
		Buckling factor of safety, FS (See note 13) =	2.0
		Allowable buckling pressure ( $q_a$ , psi), $(1/FS) [32 R_w B^2 E' (EI/B_c)]^{0.5}$ =	71.61
		Total Negative Pressure, live load condition (psi), $0.0361h_w + R_w W_{clay} / B_c + W_L / B_c$ (See note 14) =	4.58
		Total Negative Pressure, vacuum condition (psi), $0.0361h_w + R_w W_{clay} / B_c + P_v$ (See note 14) =	19.28

**Deflection Result : Deflection is Within Allowable Limits**

**Buckling Result : Pipe stiffness acceptable**

Bedding Constant K	
Bedding Angle (degree)	Bedding Constant
0	0.11
30	0.108
45	0.105
60	0.102
90	0.096
120	0.090
180	0.083

MWH Min. Wall Thickness Requirements	
24" Dia. & under - 3/16" =	0.1875
25" to 48" Dia. - 1/4" =	0.2500
Over 48" Dia. - 5/16" =	0.3125

Min. Pipe Can - Thickness	
ND, (in)	Min. t, (in)
6	0.1345
12	0.1345
18	0.1345
24	0.1345
30	0.1345
36	0.1500
42	0.1750
48	0.2000
54	0.2250
60	0.2500
66	0.2750
72	0.3000
78	0.3250
84	0.3500
90	0.3750
96	0.4000
102	0.4250
108	0.4500
114	0.4750
120	0.5000

Mortar Lining Thickness			
MWH			
Diameter (in)	Lining Thickness (in)	Diameter (in)	Lining Thickness (in)
4	0.25	60	0.5
6	0.25	66	0.5
8	0.25	72	0.5
10	0.25	78	0.5
12	0.313	84	0.5
14	0.313	90	0.5
16	0.313	96	0.5
18	0.313	102	0.5
20	0.313	108	0.5
24	0.375	114	0.5
26	0.375	120	0.5
28	0.375	126	0.5
30	0.375	132	0.5
32	0.375	138	0.5
34	0.375	144	0.5
36	0.375		
38	0.5		
40	0.5		
42	0.5		
44	0.5		
46	0.5		
48	0.5		
50	0.5		
52	0.5		
54	0.5		
56	0.5		
58	0.5		

**Backfill Materials:**  
 Table 6-1 Values\* of modulus of soil reaction,  $E'$  (psi) based on depth of cover, type of soil, and relative compaction

Type of Soil†	Standard AASHTO relative compaction‡									
	Depth of Cover		85%		90%		95%		100%	
	ft	(m)	psi	(kPa)	psi	(kPa)	psi	(kPa)	psi	(kPa)
Fine-grained soils with less than 25% sand content (CL, ML, CL-ML)	2-5	(0.6-1.5)	500	(3,450)	700	(4,830)	1,000	(6,895)	1,500	(10,340)
Coarse-grained soils with fines (SM, SC)	5-10	(1.5-3.1)	600	(4,140)	1,000	(6,895)	1,400	(9,655)	2,000	(13,790)
Coarse-grained soils with little or no fines (SP, SM, GP, GW)	10-15	(3.1-4.6)	700	(4,830)	1,200	(8,275)	1,600	(11,030)	2,300	(15,860)
	15-20	(4.6-6.1)	800	(5,520)	1,300	(8,965)	1,800	(12,410)	2,600	(17,930)
	2-5	(0.6-1.5)	600	(4,140)	1,000	(6,895)	1,200	(8,275)	1,900	(13,100)
	5-10	(1.5-3.1)	900	(6,205)	1,400	(9,655)	1,800	(12,410)	2,700	(18,615)
	10-15	(3.1-4.6)	1,000	(6,895)	1,500	(10,340)	2,100	(14,480)	3,200	(22,065)
	15-20	(4.6-6.1)	1,100	(7,585)	1,600	(11,030)	2,400	(16,545)	3,700	(25,510)
	2-5	(0.6-1.5)	700	(4,830)	1,000	(6,895)	1,600	(11,030)	2,500	(17,235)
	5-10	(1.5-3.1)	1,000	(6,895)	1,500	(10,340)	2,200	(15,170)	3,300	(22,750)
	10-15	(3.1-4.6)	1,050	(7,240)	1,600	(11,030)	2,400	(16,545)	3,600	(24,820)
	15-20	(4.6-6.1)	1,100	(7,585)	1,700	(11,720)	2,500	(17,235)	3,800	(26,200)

**Native Soils:**  
 Table 5-6 Values for the modulus of soil reaction  $E'_s$  for the native soil at pipe zone elevation

Native in Situ Soils*				
Granular		Cohesive		$E'_s$ (psf)
Blows/ft†	Description	$q_u$ (Tons/sf)	Description	
>0-1	very, very loose	>0-0.125	very, very soft	50
1-3	very loose	0.125-0.25	very soft	200
2-4		0.25-0.50	soft	700
4-8	loose	0.50-1.0	medium	1,600
8-15	slightly compact	1.0-2.0	stiff	3,000
15-30	compact	2.0-4.0	very stiff	5,000
30-60	dense	4.0-6.0	hard	10,000
>60	very dense	>6.0	very hard	20,000

**Composite  $E'$  Coefficients:**  
 Table 5-5 Values for the soil support combining factor  $S_c$

$M_{max}/M_{sb}$	$B_g/D = 1.25$	$B_g/D = 1.5$	$B_g/D = 1.75$	$B_g/D = 2$	$B_g/D = 2.5$	$B_g/D = 3$	$B_g/D = 4$	$B_g/D = 5$
0.005	0.02	0.05	0.08	0.12	0.23	0.43	0.72	1.00
0.01	0.03	0.07	0.11	0.15	0.27	0.47	0.74	1.00
0.02	0.05	0.10	0.15	0.20	0.32	0.52	0.77	1.00
0.05	0.10	0.15	0.20	0.27	0.38	0.58	0.80	1.00
0.1	0.15	0.20	0.27	0.35	0.46	0.65	0.84	1.00
0.2	0.25	0.30	0.38	0.47	0.58	0.75	0.88	1.00
0.4	0.45	0.50	0.56	0.64	0.75	0.85	0.93	1.00
0.6	0.65	0.70	0.75	0.81	0.87	0.94	0.98	1.00
0.8	0.84	0.87	0.90	0.93	0.96	0.98	1.00	1.00
1	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.5	1.40	1.30	1.20	1.12	1.06	1.03	1.00	1.00
2	1.70	1.50	1.40	1.30	1.20	1.10	1.05	1.00
3	2.20	1.80	1.65	1.50	1.35	1.20	1.10	1.00
≥5	3.00	2.20	1.90	1.70	1.50	1.30	1.15	1.00

NOTE: In-between values of  $S_c$  may be determined by straight-line interpolation from adjacent values.

Table 6-3; AWWA M11			
Highway HS-20 Load	Soil Cover	Railroad E-80 Load	Soil Cover
	ft		ft
1	1800	2	3800
2	800	5	2400
3	600	8	1600
4	400	10	1100
5	250	12	800
6	200	15	600
7	176	20	300
8</			

Client: *(Client Name here)*  
 Project: *(Project Name Here)*  
 Description: *(Description of what is being calculated, specific building, system, discipline, etc...)*

Sheet: \_\_\_\_\_ of \_\_\_\_\_  
 Date: *mm/dd/yy*  
 Job No: *xxxxxx*  
 By: *(Author)* Chkd By: *xxx*

**Steel Pipe Wall Design - Trench Condition**
**Steel Pipe Wall Design - Trench Condition**

Equations used	
<p><b>Barlow Formula - Hoop Stress</b></p> $t = \frac{pd}{2s}$ <p>Where:  <math>t</math> = minimum pipe wall thickness for the specified internal design pressure, in. (mm)  <math>p</math> = internal design pressure, psi (kPa)  <math>d</math> = outside diameter of pipe steel cylinder (not including coatings), in. (mm)  <math>s</math> = allowable design stress, psi (kPa)</p>	<p><b>EARTH LOADING</b>                      Embankment Condition</p> $W_c = C_c w B_c^2$ <p>Where:  <math>C_c</math> = coefficient for embankment conditions, a function of soil properties.                      For flexible pipe, the settlement ratio (Spangler 1947) is assumed to be zero, in which case</p> <p>Where:  <math>H_c</math> = height of fill above top of pipe in ft (m)</p> <p>Then:</p> $W_c = \frac{H_c}{B_c} w B_c^2 = w H_c B_c$
<p><b>Buckling Equations</b></p> <p>Allowable Buckling Pressure</p> $q_a = \left( \frac{1}{FS} \right) \left( 32 R_w B_c^3 \frac{EI}{D^3} \right)^{1/2}$ <p>Vacuum Press/Live Load Pressure</p> $\gamma_w h_w + R_w \frac{W_c}{D} + \frac{W_L}{D} \leq \gamma_w h_w + R_w \frac{W_c}{D} + P_v \leq q_a$ <p>Where:  <math>h_w</math> = height of water above conduit in in. (mm)  <math>\gamma_w</math> = specific weight of water = 0.0361 lb/cu in. (0.0098 kPa/mm<sup>3</sup>)  <math>P_v</math> = internal vacuum pressure in psi (kPa) = atmospheric pressure less absolute pressure inside pipe, in psi (kPa)  <math>W_c</math> = vertical soil load on pipe per unit length, in lb/in. (kPa/mm)</p>	<p><b>PIPE DEFLECTION</b></p> $\text{Deflx} = \frac{D, K W r^3}{EI + 0.0614E'r^3}$ <p>Where:</p> <p>Deflx = Vertical deflection of pipe in inches, (not to exceed 0.015 times the nominal diameter for mortar-lined and coated pipe, 0.025 times the nominal diameter for mortar-lined and dielectric coated pipe and 0.05 times the nominal diameter for dielectric lined and coated pipe.)</p> <p>DL = Deflection lag factor.                      K = Bedding constant                      W = Vertical load on pipe, lb/in.                      r = Mean radius of pipe shell, inches                      EI = Pipe stiffness, lb in.                      E' = Modulus of soil reaction, lb/in<sup>2</sup> A specific, rational method must be used to develop this number for soils at the site. The method must be reviewed.</p>



## Burris Basin - 36" Line

$$ID = 36''$$

$$OD = 36.5''$$

$$D_c = 38.5''$$

$$D = ID + t_L + t_s = 36.25''$$

$$t_s = .25''$$

$$t_c = 1''$$

$$t_L = 0''$$

$$r = .5D = 18.125''$$

$$r_o = .5OD = 18.25''$$

$$H_c = 5.5$$

$$H_w = 0$$

$$w = 120 \text{ lb/ft}^2$$

$$D_i = 1.5$$

$$k = .1$$

$$I_x = t_x^3 / 12$$

$$E_s = 30 \times 10^6$$

$$E_c = 4 \times 10^6$$

$$* EI = E_s I_s + E_c (I_L + I_c) \rightarrow 30 \times 10^6 \left( \frac{.25^3}{12} \right) + 4 \times 10^6 \left( \frac{1^3}{12} \right) \rightarrow 372396$$

$$* E = 500$$

$$C_n = 55$$

$$\phi_s = 9$$

$$k_v = .74$$

$$FS_B = 2$$

$$\gamma_w = 62.4 \text{ lb/ft}^3$$

$$P_v = 14.7 \text{ lb/in}^2$$

\* Note:  $E'$  taken from table 5-3. Assume most conservative SC@90% compaction. Apply a F.S. of 2 (1/2).

### Earth Load & Live Load

$$W_c = W H_c \left( \frac{D_c}{12} \right) \quad (\text{Eq. 5.3})$$

$$= (120)(5.5) \left( \frac{38.5}{12} \right) \rightarrow 2117.5 \text{ lb/ft} \text{ or } 176.46 \text{ lb/in}$$

### Live Load — Cat 657

$$P = 135,000 \quad (\text{axle load})$$

$$\frac{P}{2} = 67,500 \quad (\text{single tire})$$

$$\text{tire dimension} = 40.8'' \times 24.12''$$

$$\text{Surface Area} = (40.8 \times 24.12) / 144 \rightarrow 6.834 \text{ ft}^2$$

$$\text{Surface Pressure} = (67,500 / 6.834) \rightarrow 9877.09 \text{ lb/ft}^2$$

$$A_r = .5 \left( \frac{40.8}{12} \right) \rightarrow 1.7$$

$$B_r = .5 \left( \frac{24.12}{12} \right) \rightarrow 1.0$$

$$m = A_r / H_c \rightarrow 1.7 / 5.5 \rightarrow .31$$

$$n = B_r / H_c \rightarrow 1 / 5.5 \rightarrow .18$$

Use table 5-2 for Newmark Vertical influence Coefficients  
= .026

$$W_L = (4)(.026)(9877.09) \rightarrow 1027.21 \text{ lb/ft}^2$$

$$W_y = W_L \left( \frac{D_c}{12} \right) \rightarrow 1027.21 \left( \frac{38.5}{12} \right) \rightarrow 3,295.63 \text{ lb/ft} \text{ or } 274.64 \text{ lb/in}$$

$$W = W_c + W_L \rightarrow 176.46 + 274.64 \rightarrow \boxed{451.10 \text{ lb/in}}$$

Deflection

$$\Delta x = \left( \frac{D \cdot K W r^3}{EI + .61 E' r^3} \right) \quad (\text{Eq. 5.4})$$

$$= \left[ \frac{(1.5)(.1)(451.10)(18.125)^3}{(372396) + (.061(500)(18.125)^3)} \right] \text{---...}$$

$$\dots \longrightarrow \left( \frac{402900.80}{554003.54} \right) \longrightarrow .73 \text{ in}$$

$$\% \text{ Deflection} = \frac{\Delta x}{OD} \longrightarrow \frac{.73}{36.5} \longrightarrow 2.0\%$$

Buckling

$$q_a = \frac{(1.2C_n)(EI)^{.33}(\phi_s E' K_v)^{.67} R_H}{(FS_B) r_o}$$

$$= \frac{(1.2(.55))(372396)^{.33}((.9)(500)(.74))^{.67} R_H}{(2)(18.25)} \dots$$

$$\dots \rightarrow \frac{2228.50 R_H}{36.5} \rightarrow 61.05 R_H \rightarrow \boxed{60.26 \text{ lb/in}^2}$$

$$R_H = \frac{11.4}{11 + \left(\frac{2r}{H_c}\right)} \rightarrow \frac{11.4}{11 + \left(\frac{2(18.125)}{(5.5 \times 12)}\right)} \rightarrow .987$$

$$q_a \cong \frac{\delta_w}{1728} H_w + R_w \frac{W_c}{12 D_o} + P_v$$

$$\cong \frac{(62.4)}{1728} (0) + R_w \frac{(176.46 \times 12)}{12 \times (36.5)} + (14.7) \dots$$

$$\dots \rightarrow 4.83 R_w + 14.7 \rightarrow \boxed{19.53 \text{ lb/in}^2}$$

$$R_w = 1 - .33 \left(\frac{H_w}{H_c}\right) \rightarrow 1 - .33 \left(\frac{0}{5.5}\right) \rightarrow 1$$

$$60.26 \geq 19.53 \quad \checkmark$$

Table 6-4 Influence coefficients for rectangular areas

$m = A/H$ or $n = B/H$	$n = B/H$ or $m = A/H$								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.005	0.009	0.013	0.017	0.020	0.022	0.024	0.026	0.027
0.2	0.009	0.018	0.026	0.033	0.039	0.043	0.047	0.050	0.053
0.3	0.013	0.026	0.037	0.047	0.056	0.063	0.069	0.073	0.077
0.4	0.017	0.033	0.047	0.060	0.071	0.080	0.087	0.093	0.098
0.5	0.020	0.039	0.056	0.071	0.084	0.095	0.103	0.110	0.116
0.6	0.022	0.043	0.063	0.080	0.095	0.107	0.117	0.125	0.131
0.7	0.024	0.047	0.069	0.087	0.103	0.117	0.128	0.137	0.144
0.8	0.026	0.050	0.073	0.093	0.110	0.125	0.137	0.146	0.154
0.9	0.027	0.053	0.077	0.098	0.116	0.131	0.144	0.154	0.162
1.0	0.028	0.055	0.079	0.101	0.120	0.136	0.149	0.160	0.168
1.2	0.029	0.057	0.083	0.106	0.126	0.143	0.157	0.168	0.178
1.5	0.030	0.059	0.086	0.110	0.131	0.149	0.164	0.176	0.186
2.0	0.031	0.061	0.089	0.113	0.135	0.153	0.169	0.181	0.192
2.5	0.031	0.062	0.090	0.115	0.137	0.155	0.170	0.183	0.194
3.0	0.032	0.062	0.090	0.115	0.137	0.156	0.171	0.184	0.195
5.0	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196
10.0	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196
$\infty$	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196

	1.0	1.2	1.5	2.0	2.5	3.0	5.0	10.0	$\infty$
0.1	0.028	0.029	0.030	0.031	0.031	0.032	0.032	0.032	0.032
0.2	0.055	0.057	0.059	0.061	0.062	0.062	0.062	0.062	0.062
0.3	0.079	0.083	0.086	0.089	0.090	0.090	0.090	0.090	0.090
0.4	0.101	0.106	0.110	0.113	0.115	0.115	0.115	0.115	0.115
0.5	0.120	0.126	0.131	0.135	0.137	0.137	0.137	0.137	0.137
0.6	0.136	0.143	0.149	0.153	0.155	0.156	0.156	0.156	0.156
0.7	0.149	0.157	0.164	0.169	0.170	0.171	0.172	0.172	0.172
0.8	0.160	0.168	0.176	0.181	0.183	0.184	0.185	0.185	0.185
0.9	0.168	0.178	0.186	0.192	0.194	0.195	0.196	0.196	0.196
1.0	0.175	0.185	0.193	0.200	0.202	0.203	0.204	0.205	0.205
1.2	0.185	0.196	0.205	0.212	0.215	0.216	0.217	0.218	0.218
1.5	0.193	0.205	0.215	0.223	0.226	0.228	0.229	0.230	0.230
2.0	0.200	0.212	0.223	0.232	0.236	0.238	0.239	0.240	0.240
2.5	0.202	0.215	0.226	0.236	0.240	0.242	0.244	0.244	0.244
3.0	0.203	0.216	0.228	0.238	0.242	0.244	0.246	0.247	0.247
5.0	0.204	0.217	0.229	0.239	0.244	0.246	0.249	0.249	0.249
10.0	0.205	0.218	0.230	0.240	0.244	0.247	0.249	0.250	0.250
$\infty$	0.205	0.218	0.230	0.240	0.244	0.247	0.249	0.250	0.250

Source: Newmark, N.M., Simplified Computation of Vertical Pressures in Elastic Foundations. *Circ. 24. Engrg. Exp. Stn., Univ. of Illinois (1935)*.

Table 6-1 Values\* of modulus of soil reaction,  $E'$  (psi) based on depth of cover, type of soil, and relative compaction

Type of Soil <sup>†</sup>	Standard AASHTO relative compaction <sup>‡</sup>									
	Depth of Cover		85%		90%		95%		100%	
	<i>ft</i>	<i>(m)</i>	<i>psi</i>	<i>(kPa)</i>	<i>psi</i>	<i>(kPa)</i>	<i>psi</i>	<i>(kPa)</i>	<i>psi</i>	<i>(kPa)</i>
Fine-grained soils with less than 25% sand content (CL, ML, CL-ML)	2-5	(0.06-1.5)	500	(3,450)	700	(4,830)	1,000	(6,895)	1,500	(10,340)
	5-10	(1.5-3.1)	600	(4,140)	1,000	(6,895)	1,400	(9,655)	2,000	(13,790)
	10-15	(3.1-4.6)	700	(4,830)	1,200	(8,275)	1,600	(11,030)	2,300	(15,860)
	15-20	(4.6-6.1)	800	(5,520)	1,300	(8,965)	1,800	(12,410)	2,600	(17,930)
Coarse-grained soils with fines (SM, SC)	2-5	(0.06-1.5)	600	(4,140)	1,000	(6,895)	1,200	(8,275)	1,900	(13,100)
	5-10	(1.5-3.1)	900	(6,205)	1,400	(9,655)	1,800	(12,410)	2,700	(18,615)
	10-15	(3.1-4.6)	1,000	(6,895)	1,500	(10,340)	2,100	(14,480)	3,200	(22,065)
	15-20	(4.6-6.1)	1,100	(7,585)	1,600	(11,030)	2,400	(16,545)	3,700	(25,510)
Coarse-grained soils with little or no fines (SP, SM, GP, GW)	2-5	(0.06-1.5)	700	(4,830)	1,000	(6,895)	1,600	(11,030)	2,500	(17,235)
	5-10	(1.5-3.1)	1,000	(6,895)	1,500	(10,340)	2,200	(15,170)	3,300	(22,750)
	10-15	(3.1-4.6)	1,050	(7,240)	1,600	(11,030)	2,400	(16,545)	3,600	(24,820)
	15-20	(4.6-6.1)	1,100	(7,585)	1,700	(11,720)	2,500	(17,235)	3,800	(26,200)

\* Hartley, James D. and Duncan, James M., "E' and its Variation with Depth." *Journal of Transportation*, Division of ASCE, Sept. 1987.

<sup>†</sup> Soil type symbols are from the Unified Classification System.

<sup>‡</sup> *Soil compaction.* When specifying the amount of compaction required, it is very important to consider the degree of soil compaction that is economically obtainable in the field for a particular installation. The density and supporting strength of the native soil should be taken into account. The densification of the backfill envelope must include the haunches under the pipe to control both the horizontal and vertical pipe deflections. Specifying an unobtainable soil compaction value can result in inadequate support and injurious deflection. Therefore, a conservative assumption of the supporting capability of a soil is recommended, and good field inspection should be provided to verify that design assumptions are met.

Table 6-2 Unified soil classification

Symbol	Description
GW	Well-graded gravels, gravel-sand mixtures, little or no fines
GP	Poorly graded gravels, gravel-sand mixtures, little or no fines
GM	Silty gravels, poorly graded gravel-sand-silt mixtures
GC	Clayey gravels, poorly graded gravel-sand-clay mixtures
SW	Well-graded sands, gravelly sands, little or no fines
SP	Poorly graded sands, gravelly sands, little or no fines
SM	Silty sands, poorly graded sand-silt mixtures
SC	Clayey sands, poorly graded sand-clay mixtures
ML	Inorganic silts and very fine sand, silty or clayey fine sands
CL	Inorganic clays of low to medium plasticity
MH	Inorganic silts, micaceous or diatomaceous fine sandy or silty soils, elastic silts
CH	Inorganic clays of high plasticity, fat clays
OL	Organic silts and organic silt-clays of low plasticity
OH	Organic clays of medium to high plasticity
Pt	Peat and other highly organic soils


Source: Classification of Soils for Engineering Purposes. ASTM Standard D2487-69, ASTM, Philadelphia, Pa. (1969).

Client: (Client Name here)  
Project: (Project Name Here)  
Description: (Description of what is being calculated, specific building, system, discipline, etc...)

Sheet: \_\_\_\_\_ of \_\_\_\_\_  
Date: mm/dd/yy  
Job No: xxxxxx  
By: (Author) Chkd By: xxx

Steel Pipe Wall Design - Trench Condition

Steel Pipe Wall Design - Trench Condition  
Steel Cylinder Structural Calculations per AWWA M11 - Fourth Edition (2004)

Input Section		Output Section	
Nominal Diameter of Pipe (DN, in.) =	48.000	Allowable Stress, Working ( $s_w$ , psi), $Y_1/SF_w$ =	16,500
Select type of Lining =	Epoxy	Allowable Stress, Transient ( $s_t$ , psi), $Y_2/SF_s$ =	22,000
Internal Working Pressure ( $p_w$ , psi) =	24.00	Allowable Stress, Test/Shutoff ( $s$ , psi), $Y_3/SF_t$ =	22,000
Test Pressure- ( $p_t$ , psi) =	150.00		
Transient Pressure ( $p_t$ , psi) [Limit to 1.33 $p_w$ ] (See note 1) =	31.92		
Pump Shutoff Pressure ( $p_{so}$ , psi) =	300.00		
Specified Minimum Yield Point of Steel ( $Y_s$ , psi) (See note 2) =	33,000	Mortar Lining Thickness ( $t_l$ , in.) =	0.000
Safety Factor, Working ( $SF_w$ ) =	2.0	Internal Diameter (ID, in.) =	48.00
Safety Factor, Transient Pressure ( $SF_s$ ) =	1.5	ID requirement based on (see note 2A) =	MWH
Safety Factor, Test Pressure/Pump Shutoff ( $SF_t$ ) =	1.5		
<b>Legend</b>			
Red Numbers =		Input required	
<b>Minimum Thickness for Internal Pressure (Eqn 4-1, AWWA M11)</b>			
			
<b>Pipe Wall Thickness due to Pressure:</b>			
Min Steel Thickness from Working Pressure Calc ( $t_w$ , in), $p_w OD/(2s_w)$ =		0.0356	
Min Steel Thickness from Test Pressure Calc ( $t_t$ , in), $p_t OD/(2s_t)$ =		0.1670	
Min Steel Thickness from Transient Pressure Calc ( $t_s$ , in), $p_t OD/(2s_s)$ =		0.0355	
Min Steel Thickness from Shutoff Pressure Calc ( $t_{so}$ , in), $p_{so} OD/(2s_s)$ =		0.3341	
<b>Pipe Wall Thickness due to Handling/Constructability:</b>			
User Defined OD/t =		200	
Min Steel Thickness for Handling (OD/t ≤ 240, mortar lining) (see note 3) =		0.2042	
Min Steel Thickness for Handling (OD/t ≤ 288, flexible lining) (see note 4) =		0.1701	
Min Steel Thickness for Constructability (from 'Min. Pipe Can' table) =		0.2000	
Min Steel Thickness for User Specified Handling (OD/t ≤ 200) =		0.2450	
<b>Pipe Wall Thickness Results:</b>			
Min Pipe Wall Thickness Required ( $t_{min}$ , in) (see note 5) =		0.3341	
Standard Pipe Wall Thickness per AWWA M11 Table A-1 ( $t_{std}$ , in) =		0.3750	
Design OD/t = 98			

**Sheet Notes:**

- MWH surge allowance is limited to 1.33  $p_w$  - Use actual surge value if higher. (See Hydraulic Lead/Surge report for surge values)
- Yield Stress -  $Y_s$  limited to:  
33,000 psi - Mortar Lined and Coated pipe  
42,000 psi - Mortar Lined - Flexible Coated pipe  
50,000 psi - Flexible Lined and Coated pipe
- 2A. MWH ID requirement is based on ID for 14" dia and larger.
- Use OD/t = 240 for handling, unless justified otherwise, for mortar lined pipe.  
Use OD/t ≤ 288 for OD up to 54" (M11 Eq 4-5).  
For OD ≥ 54", use  $t_z$  (OD+20)/400 (M11 Eq 4-6).
- Use the maximum of the wall thicknesses calculated by pressure, handling or the minimum thickness shown for the pipe or fitting.
- Minimum allowable pressure to avoid vapor pressure of fluid and associated cavitation is -5.00 psi

**Pipe Reference Data**

Bedding Constant K	
Bedding Angle (degree)	Bedding Constant
0	0.11
30	0.108
45	0.105
60	0.102
90	0.096
120	0.090
180	0.083

**MWH Min. Wall Thickness Requirements**

Fittings and Specials - Thickness	
24" Dia. & under - 3/16" =	0.1875
25" to 48" Dia. - 1/4" =	0.2500
Over 48" Dia. - 5/16" =	0.3125

**Min. Pipe Can - Thickness**

ND, (in)	Min. t, (in)
6	0.1345
12	0.1345
18	0.1345
24	0.1345
30	0.1345
36	0.1500
42	0.1750
48	0.2000
54	0.2250
60	0.2500
66	0.2750
72	0.3000
78	0.3250
84	0.3500
90	0.3750
96	0.4000
102	0.4250
108	0.4500
114	0.4750
120	0.5000

**Mortar Lining Thickness**

MWH			
Diameter (in)	Lining Thickness (in)	Diameter (in)	Lining Thickness (in)
4	0.25	60	0.5
6	0.25	66	0.5
8	0.25	72	0.5
10	0.25	78	0.5
12	0.313	84	0.5
14	0.313	90	0.5
16	0.313	96	0.5
18	0.313	102	0.5
20	0.313	108	0.5
24	0.375	114	0.5
26	0.375	120	0.5
28	0.375	126	0.5
30	0.375	132	0.5
32	0.375	138	0.5
34	0.375	144	0.5
36	0.375		
38	0.5		
40	0.5		
42	0.5		
44	0.5		
46	0.5		
48	0.5		
50	0.5		
52	0.5		
54	0.5		
56	0.5		
58	0.5		

**Backfill Materials:**

Table 6-1 Values\* of modulus of soil reaction,  $E'$  (psi) based on depth of cover, type of soil, and relative compaction

Type of Soil†	Depth of Cover	Standard AASHTO relative compaction‡			
		85%	90%	95%	100%
Fine-grained soils with less than 25% sand content (CL, ML, CL-ML)	2-5 (0.6-1.5)	500 (3,450)	700 (4,830)	1,000 (6,895)	1,500 (10,340)
	5-10 (1.5-3.1)	600 (4,140)	1,000 (6,895)	1,400 (9,655)	2,000 (13,790)
	10-15 (3.1-4.6)	700 (4,830)	1,200 (8,275)	1,600 (11,030)	2,300 (15,860)
	15-20 (4.6-6.1)	800 (5,520)	1,300 (8,965)	1,800 (12,410)	2,600 (17,930)
Coarse-grained soils with fines (SM, SC)	2-5 (0.6-1.5)	600 (4,140)	1,000 (6,895)	1,200 (8,275)	1,900 (13,100)
	5-10 (1.5-3.1)	900 (6,205)	1,400 (9,655)	1,800 (12,410)	2,700 (18,615)
	10-15 (3.1-4.6)	1,000 (6,895)	1,500 (10,340)	2,100 (14,480)	3,200 (22,065)
	15-20 (4.6-6.1)	1,100 (7,585)	1,600 (11,030)	2,400 (16,545)	3,700 (25,510)
Coarse-grained soils with little or no fines (SP, SM, GP, GW)	2-5 (0.6-1.5)	700 (4,830)	1,000 (6,895)	1,600 (11,030)	2,500 (17,235)
	5-10 (1.5-3.1)	1,000 (6,895)	1,500 (10,340)	2,200 (15,170)	3,300 (22,750)
	10-15 (3.1-4.6)	1,050 (7,240)	1,600 (11,030)	2,400 (16,545)	3,600 (24,820)
	15-20 (4.6-6.1)	1,100 (7,585)	1,700 (11,720)	2,500 (17,235)	3,800 (26,200)

**Native Soils:**

Table 5-6 Values for the modulus of soil reaction  $E'_s$  for the native soil at pipe zone elevation

Granular		Cohesive		$E'_s$ (psf)
Blows/ft†	Description	$q_u$ (Tons/ft)	Description	
>0-1	very, very loose	>0-0.125	very, very soft	50
1-3	very loose	0.125-0.25	very soft	200
2-4		0.25-0.50	soft	700
4-8	loose	0.50-1.0	medium	1,600
8-15	slightly compact	1.0-2.0	stiff	3,000
15-30	compact	2.0-4.0	very stiff	5,000
30-60	dense	4.0-6.0	hard	10,000
>60	very dense	>6.0	very hard	20,000

**Composite  $E'$  Coefficients:**

Table 5-5 Values for the soil support combining factor  $S_c$

$M_{max}/M_{allow}$	$B_d/D = 1.25$	$B_d/D = 1.5$	$B_d/D = 1.75$	$B_d/D = 2$	$B_d/D = 2.5$	$B_d/D = 3$	$B_d/D = 4$	$B_d/D = 5$
0.005	0.02	0.05	0.08	0.12	0.23	0.43	0.72	1.00
0.01	0.03	0.07	0.11	0.15	0.27	0.47	0.74	1.00
0.02	0.05	0.10	0.15	0.20	0.32	0.52	0.77	1.00
0.05	0.10	0.15	0.20	0.27	0.38	0.58	0.80	1.00
0.1	0.15	0.20	0.27	0.35	0.46	0.65	0.84	1.00
0.2	0.25	0.30	0.38	0.47	0.58	0.75	0.88	1.00
0.4	0.45	0.50	0.56	0.64	0.75	0.85	0.93	1.00
0.6	0.65	0.70	0.75	0.81	0.87	0.94	0.98	1.00
0.8	0.84	0.87	0.90	0.93	0.96	0.98	1.00	1.00
1	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.5	1.40	1.30	1.20	1.12	1.06	1.03	1.00	1.00
2	1.70	1.50	1.40	1.30	1.20	1.10	1.05	1.00
3	2.20	1.80	1.65	1.50	1.35	1.20	1.10	1.00
≥5	3.00	2.20	1.90	1.70	1.50	1.30	1.15	1.00

NOTE: In-between values of  $S_c$  may be determined by straight-line interpolation from adjacent values.

Input Section		Output Section	
Wall thickness to use in design ( $t_w$ , in) =	0.5000	Mean Dia (D, in), OD - $t_s$ - $t_l$ =	48.50
Mortar Coating Thickness ( $t_c$ , in) (See note 7) =	1.00	Cylinder Outside Dia (OD, in), ID + 2 $t_c$ + 2 $t_l$ =	49.00
Soil backfill type	Sand & gravel	Pipe Outside Dia ( $B_o$ , ft), OD + 2 $t_c$ =	4.250
Depth of soil cover (H, ft) =	5.50	Wall stiffness (EI, in <sup>4</sup> /in), $30E10^6 I_s + 4E10^6 (I_l + I_c)$ =	645,833
Distance beyond pipe OD to trench wall (m, ft) =	1.00	Steel moment of inertia ( $I_s$ , in <sup>4</sup> /linear in), $t_s^3/12$ =	0.0104
Trench width at top of the pipe ( $B_d$ , ft) = $B_o$ + 2m	6.25	Lining moment of inertia ( $I_l$ , in <sup>4</sup> /linear in), $t_l^3/12$ =	0.0000
Transition width ( $B_{tr}$ , ft) (Go to "transition" tab to calculate $B_{tr}$ )	7.05	Coating moment of inertia ( $I_c$ , in <sup>4</sup> /linear in), $t_c^3/12$ =	0.0833
Included additional load to apply to pipe	distributed load	Mean radius (r, in), D/2 =	24.25
Load, (Y, lbs)	67,500.0	$B_d/B_o$ =	1.47
Length of loaded surface area, a (ft)	3.40	Distributed load impact factor, I =	1.00
Width of loaded surface area, b (ft)	2.01	Surcharge load (W <sub>y</sub> , psf), $Y \cdot I / [(a+H)(b+H)]$ =	1,010
Unit weight of soil (w, pcf) =	120.00	Lane loading (LL, psf) =	0
Height of water surface above top of pipe ( $h_w$ , ft) =	0.00	Wheel load spread width (A, ft), $5.67+H$ =	0.00
Include saturated soil weight in deflection calc (Y/N) (see note 10) =	No	Wheel load spread length (B, ft), $0.83+H$ =	0.00
Live load (HS-20 Single/HS-20 ALT./E80/NA) =	NA	Alternate live load backfill factor (f) =	0.00
Modulus of soil reaction, $E'$ =	Per AWWA M11 500.00	Gov'n dimension parallel to long axis of pipe (L, ft) =	0.00
Modulus of the soil reaction ( $E'$ , psi) (See table 6-1 and note 8) =	500.00	$E'_s/E'_b$ =	NA
Native soil modulus ( $E'_s$ , psi) (See table 5-6) =	0.00	Modulus of soil reaction ( $E'$ , psi) =	500.00
Modulus of the backfill soil ( $E'_b$ , psi) (See table 6-1 and note 8) =	0.00	Bedding constant (K) =	0.110
Soil support combining factor ( $S_c$ ) (See table 5-5) =	0.00		
Deflection lag factor ( $D_L$ , 1.0-1.5) (See note 9) =	1.50		
Select bedding angle ( $\theta$ , degree) =	0		

**Notes for Designer:**

- Limit Mortar Coating to 1" max in  $\Delta x$  Calculations
- Selection of  $E'$  value from Table 6-1 shall be limited to 85% relative compaction effort, unless otherwise approved by Geotechnical Engineer. Coordinate with Geotechnical Report for suitable  $E'$  value for pipeline design.
- The deflection Lag factor is 1.0 for a pressurized pipe, however, if the pipe will sit empty for periods of time the value would be greater than 1.0.
- Saturated soil weight is accounted for using buoyancy reduction factor ( $R_w$ ).

**Determination of External Load and Deflection for Trench Condition**

Earth load	
Earth load for trench condition ( $W_e$ , lb/linear in.), Non-saturated soil: $0.0361h_w B_o + R_w H w B_o / 12$ =	233.75
<b>Determination of Live Load for HS-20 wheel Or Cooper E-80 Railroad Loading</b>	
<b>Highway loading per AWWA M11</b>	
Single HS-20 truck live load on pipe from table 6-3 ( $P_L$ , psf) =	0.00
Single HS-20 truck live load on pipe ( $W_L$ , lb/linear in.), $P_L B_o / 12$ =	0.00
<b>Alternate Highway loading per AASHTO</b>	
Impact factor for highway ( $I_h$ , %), $33 \cdot (1 - 0.125H) / 100$ =	0%
Total wheel load applied at the surface ( $P_s$ , lbs) =	0
Total live load assuming truck travel transverse to pipe centerline ( $W_T$ , lbs), $[P(1+I_h)/(AB) + LL] \cdot A \cdot \text{Min}(B, B_o)$ =	0
Total live load assuming truck travel parallel to pipe centerline ( $W_P$ , lbs), $[P(1+I_h)/(AB) + LL] \cdot B \cdot \text{Min}(A, B_o)$ =	0
HS-20 ALT, Maximum AASHTO HS-20 Passing truck live load on pipe ( $W_L$ , lb/linear in.), $\{ \text{Max}(W_T, W_P) / [L + 1.75(0.75B_o)] \} / 12$ =	0.00
<b>Railroad loading per AWWA M11</b>	
Railroad loading on pipe from table 6-3 ( $W_L$ , lb/linear in.) =	0.00
<b>Surcharge loading</b>	
Surcharge loading on pipe ( $W_y$ , lb/linear in.) =	357.67
<b>Total External Load</b>	Total external load on pipe ( $W$ , lb/linear in.) = 591.42
<b>Deflection Results (Eqn 6-5, AWWA M11)</b>	
Vertical/Horizontal deflection of the pipe ( $\Delta x$ , in), $D_L [KW^3 / (EI + 0.061E'r^3)]$ =	1.29
Percent deflection, $\Delta x/D$ =	2.65%
This is not a standard type of pipe	

**Non-saturated soil**

11. Allowable deflections used herein are set at 75% of allowable deflections shown in AWWA M11, consistent with MWH standards.

**Deflection Result : Deflection is Within Allowable Limits**

Input Section		Output Section	
Include internal vacuum pressure	Yes	Water buoyancy factor ( $R_w$ ), $1 - (0.33(h_w/H))$ =	1.00
Internal vacuum pressure ( $P_v$ , psi) =	14.70	Elastic support coefficient, (B), $1 / (1 + 4e^{-0.0001B})$ =	0.26
Buckling factor of safety based on AWWA M-11 (3rd Ed/4th Ed)	4th Ed (2004)	$H/B_o$ =	1.29
		Buckling factor of safety, FS (See note 13) =	2.0
Allowable buckling pressure ( $q_a$ , psi), $(1/FS) [32 R_w B^2 E' (EI/B_o)]^{0.5}$ =			
Total Negative Pressure, live load condition (psi), $0.0361h_w + R_w W_{clay} / B_o + W_L / B_o$ (See note 14) =		4.58	
Total Negative Pressure, vacuum condition (psi), $0.0361h_w + R_w W_{clay} / B_o + P_v$ (See note 14) =		19.28	

12. Where internal vacuum occurs with cover depth less than 4 ft but not less than 2 ft care should be exercised in defining allowable buckling pressure. (AWWA M11 buckling footnote)

13. Design factor  $FS=2.0$  is recommended by AWWA M11 4th Ed for all depths in buckling calculation. AWWA M11 3rd Ed recommended  $FS=3.0$  for  $H/B_o < 2.0$  and  $FS=2.5$  for  $H/B_o \geq 2$ .

14. Total negative pressure does not include surcharge load.

**Buckling Result : Pipe stiffness acceptable**

**Table 6-3; AWWA M11**

Highway HS-20 Load		Railroad E-80 Load	
Soil Cover	Load	Soil Cover	Load
ft	psf	ft	psf
1	1800	2	3800
2	800	5	2400
3	600	8	1600
4	400	10	1100
5	250	12	800
6	200	15	600
7	176	20	300
8	100	30	100

Note: Neglect live load when less than 100 psf; use dead load only.




Figure 4.3. Trench Condition.

Client: *(Client Name here)*  
 Project: *(Project Name Here)*  
 Description: *(Description of what is being calculated, specific building, system, discipline, etc...)*

Sheet: \_\_\_\_\_ of \_\_\_\_\_  
 Date: *mm/dd/yy*  
 Job No: *xxxxxx*  
 By: *(Author)* Chkd By: *xxx*

**Steel Pipe Wall Design - Trench Condition**
**Steel Pipe Wall Design - Trench Condition**

Equations used	
<p><b>Barlow Formula - Hoop Stress</b></p> $t = \frac{pd}{2s}$ <p>Where:  <math>t</math> = minimum pipe wall thickness for the specified internal design pressure, in. (mm)  <math>p</math> = internal design pressure, psi (kPa)  <math>d</math> = outside diameter of pipe steel cylinder (not including coatings), in. (mm)  <math>s</math> = allowable design stress, psi (kPa)</p>	<p><b>EARTH LOADING</b>                      Embankment Condition</p> $W_c = C_c w B_c^2$ <p>Where:  <math>C_c</math> = coefficient for embankment conditions, a function of soil properties.                      For flexible pipe, the settlement ratio (Spangler 1947) is assumed to be zero, in which case</p> <p>Where:  <math>H_c</math> = height of fill above top of pipe in ft (m)</p> <p>Then:</p> $W_c = \frac{H_c}{B_c} w B_c^2 = w H_c B_c$
<p><b>Buckling Equations</b></p> <p>Allowable Buckling Pressure</p> $q_a = \left( \frac{1}{FS} \right) \left( 32 R_w B^3 E' \frac{EI}{D^3} \right)^{1/2}$ <p>Vacuum Pres/Live Load Pressure</p> $\gamma_w h_w + R_w \frac{W_c}{D} + \frac{W_L}{D} \leq \gamma_w h_w + R_w \frac{W_c}{D} + P_v \leq q_a$ <p>Where:  <math>h_w</math> = height of water above conduit in in. (mm)  <math>\gamma_w</math> = specific weight of water = 0.0361 lb/cu in. (0.0098 kPa/mm<sup>3</sup>)  <math>P_v</math> = internal vacuum pressure in psi (kPa) = atmospheric pressure less absolute pressure inside pipe, in psi (kPa)  <math>W_c</math> = vertical soil load on pipe per unit length, in lb/in. (kPa/mm)</p>	<p><b>PIPE DEFLECTION</b></p> $\text{Deflx} = \frac{D, K W r^3}{EI + 0.0614E'r^3}$ <p>Where:</p> <p>Deflx = Vertical deflection of pipe in inches, (not to exceed 0.015 times the nominal diameter for mortar-lined and coated pipe, 0.025 times the nominal diameter for mortar-lined and dielectric coated pipe and 0.05 times the nominal diameter for dielectric lined and coated pipe.)</p> <p>DL = Deflection lag factor.                      K = Bedding constant                      W = Vertical load on pipe, lb/in.                      r = Mean radius of pipe shell, inches                      EI = Pipe stiffness, lb in.                      E' = Modulus of soil reaction, lb/in<sup>2</sup> A specific, rational method must be used to develop this number for soils at the site. The method must be reviewed.</p>



### Burriss Basin - 48" Line

$$ID = 48''$$

$$OD = 49''$$

$$D_c = 51''$$

$$D = ID + t_L + t_S = 48.5''$$

$$t_S = .5''$$

$$t_L = 1''$$

$$t_L = 0''$$

$$r = .5D = 24.25''$$

$$r_o = .5OD = 24.5''$$

$$H_c = 5.5'$$

$$H_w = 0'$$

$$w = 120 \text{ lb/ft}^2$$

$$D_i = 1.5$$

$$K = .1$$

$$I_x = t_x^3 / 12$$

$$E_s = 30 \times 10^6 \text{ lb/in}^2$$

$$E_c = 4 \times 10^6 \text{ lb/in}^2$$

$$* EI = E_s I_s + E_c (I_L + I_C) \rightarrow 30 \times 10^6 \left( \frac{.5^3}{12} \right) + 4 \times 10^6 \left( \frac{1^3}{12} + 0 \right) \rightarrow 645833$$

$$* E' = 500$$

$$C_n = .55$$

$$\phi_s = .9$$

$$K_v = .74$$

$$FS_B = 2$$

$$\gamma_w = 62.4 \text{ lb/ft}^3$$

$$P_v = 14.7 \text{ lb/in}^2$$

\* Note:  $E'$  taken from table 5-3. Assumes most conservative SC @ 90% Compaction. Apply a F.S. of 2 ( $\frac{1}{2}$ ).

### Earth Load & Live Load

$$W_c = w H_c \left( \frac{D_c}{12} \right) \quad (\text{Eq. 5.3})$$

$$= (120)(5.5) \left( \frac{51}{12} \right) \rightarrow 2805.0 \text{ } \frac{\text{lb}}{\text{ft}} \text{ or } 233.75 \text{ } \frac{\text{lb}}{\text{in}}$$

### Live Load — Cat 657

$$P = 135,000 \text{ lb} \quad (\text{axle load})$$

$$\frac{P}{2} = 67,500 \text{ lb} \quad (\text{single tire})$$

$$\text{tire dimension} = 40.8" \times 24.12"$$

$$\text{Surface Area} = (40.8 \times 24.12) / 144 \rightarrow 6.834 \text{ ft}^2$$

$$\text{Surface Pressure} = (67,500 / 6.834) \rightarrow 9,877.09 \text{ } \frac{\text{lb}}{\text{ft}^2}$$

$$A_T = .5 \left( \frac{40.8}{12} \right) \rightarrow 1.7$$

$$B_T = .5 \left( \frac{24.12}{12} \right) \rightarrow 1.0$$

$$m = A_T / H_c \rightarrow 1.7 / 5.5 \rightarrow .31$$

$$n = B_T / H_c \rightarrow 1.0 / 5.5 \rightarrow .18$$

Use table 5-2 for Newmark Vertical influence Coefficients  
= .026

$$W_L = (4)(.026)(9877.09) \rightarrow 1027.21 \text{ } \frac{\text{lb}}{\text{ft}^2}$$

$$W_y = W_L \left( \frac{D_c}{12} \right) \rightarrow 1027.21 \left( \frac{51}{12} \right) \rightarrow 4365.64 \text{ } \frac{\text{lb}}{\text{ft}} \text{ or } 363.80 \text{ } \frac{\text{lb}}{\text{in}}$$

$$W = W_c + W_L \rightarrow 233.75 \text{ } \frac{\text{lb}}{\text{in}} + 363.80 \text{ } \frac{\text{lb}}{\text{in}} \rightarrow \boxed{597.55 \text{ } \frac{\text{lb}}{\text{in}}}$$

Deflection

$$\Delta x = \left( \frac{D \cdot K \cdot W \cdot r^3}{EI + .61 E' r^3} \right) \quad (\text{Eq. 5.4})$$

$$= \left[ \frac{(1.5)(.1)(597.55)(24.25)^3}{(645833) + (.061(500)(24.25^3))} \right] \dots$$

$$\dots \rightarrow \left( \frac{1278205.667}{1080778.727} \right) \rightarrow 1.18 \text{ in}$$

$$\% \text{ Deflection} = \frac{\Delta x}{OD} \rightarrow \frac{1.18}{49} \rightarrow 2.41\%$$

Buckling

$$q_a = \frac{(1.2 C_n)(EI)^{.33} (\phi_s E' K_v)^{.67} R_H}{(FS_B) r_o}$$

$$= \frac{(1.2(.55))(645833)^{.33} ((.9)(500)(.74))^{.67} R_H}{(2)(24.5)} \dots$$

$$\dots \rightarrow \frac{2672.52 R_H}{49} \rightarrow 54.54 R_H \rightarrow \boxed{52.96 \text{ lb/in}^2}$$

$$R_H = \frac{11.4}{11 + \left(\frac{2r}{H_c}\right)} \rightarrow \frac{11.4}{11 + \left(\frac{2(24.25)}{(5.5 \times 12)}\right)} \rightarrow \frac{11.4}{11.73} \rightarrow .971$$

$$q_a \geq \frac{\delta_w}{1728} H_w + R_w \frac{W_c}{12 D_o} + P_v$$

$$\geq \frac{(62.4)}{1728} (0) + R_w \frac{(233.75 \times 12)}{(12 \times (49))} + (14.7) \dots$$

$$\dots \rightarrow 4.770 R_w + 14.7 \rightarrow \boxed{19.47 \text{ lb/in}^2}$$

$$R_w = 1 - .33 \left(\frac{H_w}{H_c}\right) \rightarrow 1 - .33 \left(\frac{0}{5.5}\right) \rightarrow 1$$

$$52.96 \geq 19.47 \quad \checkmark$$

Table 6-4 Influence coefficients for rectangular areas

$m = A/H$ or $n = B/H$	$n = B/H$ or $m = A/H$								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.005	0.009	0.013	0.017	0.020	0.022	0.024	0.026	0.027
0.2	0.009	0.018	0.026	0.033	0.039	0.043	0.047	0.050	0.053
0.3	0.013	0.026	0.037	0.047	0.056	0.063	0.069	0.073	0.077
0.4	0.017	0.033	0.047	0.060	0.071	0.080	0.087	0.093	0.098
0.5	0.020	0.039	0.056	0.071	0.084	0.095	0.103	0.110	0.116
0.6	0.022	0.043	0.063	0.080	0.095	0.107	0.117	0.125	0.131
0.7	0.024	0.047	0.069	0.087	0.103	0.117	0.128	0.137	0.144
0.8	0.026	0.050	0.073	0.093	0.110	0.125	0.137	0.146	0.154
0.9	0.027	0.053	0.077	0.098	0.116	0.131	0.144	0.154	0.162
1.0	0.028	0.055	0.079	0.101	0.120	0.136	0.149	0.160	0.168
1.2	0.029	0.057	0.083	0.106	0.126	0.143	0.157	0.168	0.178
1.5	0.030	0.059	0.086	0.110	0.131	0.149	0.164	0.176	0.186
2.0	0.031	0.061	0.089	0.113	0.135	0.153	0.169	0.181	0.192
2.5	0.031	0.062	0.090	0.115	0.137	0.155	0.170	0.183	0.194
3.0	0.032	0.062	0.090	0.115	0.137	0.156	0.171	0.184	0.195
5.0	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196
10.0	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196
$\infty$	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196

	1.0	1.2	1.5	2.0	2.5	3.0	5.0	10.0	$\infty$
0.1	0.028	0.029	0.030	0.031	0.031	0.032	0.032	0.032	0.032
0.2	0.055	0.057	0.059	0.061	0.062	0.062	0.062	0.062	0.062
0.3	0.079	0.083	0.086	0.089	0.090	0.090	0.090	0.090	0.090
0.4	0.101	0.106	0.110	0.113	0.115	0.115	0.115	0.115	0.115
0.5	0.120	0.126	0.131	0.135	0.137	0.137	0.137	0.137	0.137
0.6	0.136	0.143	0.149	0.153	0.155	0.156	0.156	0.156	0.156
0.7	0.149	0.157	0.164	0.169	0.170	0.171	0.172	0.172	0.172
0.8	0.160	0.168	0.176	0.181	0.183	0.184	0.185	0.185	0.185
0.9	0.168	0.178	0.186	0.192	0.194	0.195	0.196	0.196	0.196
1.0	0.175	0.185	0.193	0.200	0.202	0.203	0.204	0.205	0.205
1.2	0.185	0.196	0.205	0.212	0.215	0.216	0.217	0.218	0.218
1.5	0.193	0.205	0.215	0.223	0.226	0.228	0.229	0.230	0.230
2.0	0.200	0.212	0.223	0.232	0.236	0.238	0.239	0.240	0.240
2.5	0.202	0.215	0.226	0.236	0.240	0.242	0.244	0.244	0.244
3.0	0.203	0.216	0.228	0.238	0.242	0.244	0.246	0.247	0.247
5.0	0.204	0.217	0.229	0.239	0.244	0.246	0.249	0.249	0.249
10.0	0.205	0.218	0.230	0.240	0.244	0.247	0.249	0.250	0.250
$\infty$	0.205	0.218	0.230	0.240	0.244	0.247	0.249	0.250	0.250

Source: Newmark, N.M., Simplified Computation of Vertical Pressures in Elastic Foundations. *Circ. 24. Engrg. Exp. Stn., Univ. of Illinois (1935).*

Table 6-1 Values\* of modulus of soil reaction,  $E'$  (psi) based on depth of cover, type of soil, and relative compaction

Type of Soil <sup>†</sup>	Standard AASHTO relative compaction <sup>‡</sup>									
	Depth of Cover		85%		90%		95%		100%	
	ft	(m)	psi	(kPa)	psi	(kPa)	psi	(kPa)	psi	(kPa)
Fine-grained soils with less than 25% sand content (CL, ML, CL-ML)	2-5	(0.06-1.5)	500	(3,450)	700	(4,830)	1,000	(6,895)	1,500	(10,340)
	5-10	(1.5-3.1)	600	(4,140)	1,000	(6,895)	1,400	(9,655)	2,000	(13,790)
	10-15	(3.1-4.6)	700	(4,830)	1,200	(8,275)	1,600	(11,030)	2,300	(15,860)
	15-20	(4.6-6.1)	800	(5,520)	1,300	(8,965)	1,800	(12,410)	2,600	(17,930)
Coarse-grained soils with fines (SM, SC)	2-5	(0.06-1.5)	600	(4,140)	1,000	(6,895)	1,200	(8,275)	1,900	(13,100)
	5-10	(1.5-3.1)	900	(6,205)	1,400	(9,655)	1,800	(12,410)	2,700	(18,615)
	10-15	(3.1-4.6)	1,000	(6,895)	1,500	(10,340)	2,100	(14,480)	3,200	(22,065)
	15-20	(4.6-6.1)	1,100	(7,585)	1,600	(11,030)	2,400	(16,545)	3,700	(25,510)
Coarse-grained soils with little or no fines (SP, SM, GP, GW)	2-5	(0.06-1.5)	700	(4,830)	1,000	(6,895)	1,600	(11,030)	2,500	(17,235)
	5-10	(1.5-3.1)	1,000	(6,895)	1,500	(10,340)	2,200	(15,170)	3,300	(22,750)
	10-15	(3.1-4.6)	1,050	(7,240)	1,600	(11,030)	2,400	(16,545)	3,600	(24,820)
	15-20	(4.6-6.1)	1,100	(7,585)	1,700	(11,720)	2,500	(17,235)	3,800	(26,200)

\* Hartley, James D. and Duncan, James M., "E' and its Variation with Depth." *Journal of Transportation*, Division of ASCE, Sept. 1987.

† Soil type symbols are from the Unified Classification System.

‡ *Soil compaction*. When specifying the amount of compaction required, it is very important to consider the degree of soil compaction that is economically obtainable in the field for a particular installation. The density and supporting strength of the native soil should be taken into account. The densification of the backfill envelope must include the haunches under the pipe to control both the horizontal and vertical pipe deflections. Specifying an unobtainable soil compaction value can result in inadequate support and injurious deflection. Therefore, a conservative assumption of the supporting capability of a soil is recommended, and good field inspection should be provided to verify that design assumptions are met.

Table 6-2 Unified soil classification

Symbol	Description
GW	Well-graded gravels, gravel-sand mixtures, little or no fines
GP	Poorly graded gravels, gravel-sand mixtures, little or no fines
GM	Silty gravels, poorly graded gravel-sand-silt mixtures
GC	Clayey gravels, poorly graded gravel-sand-clay mixtures
SW	Well-graded sands, gravelly sands, little or no fines
SP	Poorly graded sands, gravelly sands, little or no fines
SM	Silty sands, poorly graded sand-silt mixtures
SC	Clayey sands, poorly graded sand-clay mixtures
ML	Inorganic silts and very fine sand, silty or clayey fine sands
CL	Inorganic clays of low to medium plasticity
MH	Inorganic silts, micaceous or diatomaceous fine sandy or silty soils, elastic silts
CH	Inorganic clays of high plasticity, fat clays
OL	Organic silts and organic silt-clays of low plasticity
OH	Organic clays of medium to high plasticity
Pt	Peat and other highly organic soils

Source: Classification of Soils for Engineering Purposes. ASTM Standard D2487-69, ASTM, Philadelphia, Pa. (1969).

Client: (Client Name here)  
Project: (Project Name Here)  
Description: (Description of what is being calculated, specific building, system, discipline, etc...)

Sheet: \_\_\_\_\_ of \_\_\_\_\_  
Date: mm/dd/yy  
Job No: xxxxxx  
By: (Author) Chkd By: xxx

Steel Pipe Wall Design - Trench Condition

Steel Pipe Wall Design - Trench Condition  
Steel Cylinder Structural Calculations per AWWA M11 - Fourth Edition (2004)

Input Section		Output Section	
Nominal Diameter of Pipe (DN, in.) =	60.000	Allowable Stress, Working ( $s_w$ , psi), $Y_1/SF_w$ =	16,500
Select type of Lining =	Epoxy	Allowable Stress, Transient ( $s_t$ , psi), $Y_2/SF_s$ =	22,000
Internal Working Pressure ( $p_w$ , psi) =	24.00	Allowable Stress, Test/Shutoff ( $s$ , psi), $Y_3/SF_t$ =	22,000
Test Pressure ( $p_t$ , psi) =	150.00		
Transient Pressure ( $p_r$ , psi) [Limit to 1.33 $p_w$ ] (See note 1) =	31.92		
Pump Shutoff Pressure ( $p_{so}$ , psi) =	300.00		
Specified Minimum Yield Point of Steel ( $Y_s$ , psi) (See note 2) =	33,000	Mortar Lining Thickness ( $t_l$ , in.) =	0.000
Safety Factor, Working ( $SF_w$ ) =	2.0	Internal Diameter (ID, in.) =	60.00
Safety Factor, Transient Pressure ( $SF_s$ ) =	1.5	ID requirement based on (see note 2A) =	MWH
Safety Factor, Test Pressure/Pump Shutoff ( $SF_t$ ) =	1.5		
<b>Minimum Thickness for Internal Pressure (Eqn 4-1, AWWA M11)</b>			
<b>Legend</b>			
Red Numbers = Input required		Input required	

**Sheet Notes:**

- MWH surge allowance is limited to 1.33  $p_w$  - Use actual surge value if higher. (See Hydraulic Lead/Surge report for surge values)
- Yield Stress -  $Y_s$  limited to:  
33,000 psi - Mortar Lined and Coated pipe  
42,000 psi - Mortar Lined - Flexible Coated pipe  
50,000 psi - Flexible Lined and Coated pipe
- Use OD/t = 240 for handling, unless justified otherwise, for mortar lined pipe.
- Use OD/t ≤ 288 for OD up to 54" (M11 Eq 4-5). For OD ≥ 54", use  $t_z$  (OD+20)/400 (M11 Eq 4-6).
- Use the maximum of the wall thicknesses calculated by pressure, handling or the minimum thickness shown for the pipe or fitting.
- Minimum allowable pressure to avoid vapor pressure of fluid and associated cavitation is -5.00 psi

Bedding Constant K	
Bedding Angle (degree)	Bedding Constant
0	0.11
30	0.108
45	0.105
60	0.102
90	0.096
120	0.090
180	0.083

MWH Min. Wall Thickness Requirements	
Fittings and Specials - Thickness	
24" Dia. & under - 3/16" =	0.1875
25" to 48" Dia. - 1/4" =	0.2500
Over 48" Dia. - 5/16" =	0.3125

Min. Pipe Can - Thickness	
ND, (in)	Min. t, (in)
6	0.1345
12	0.1345
18	0.1345
24	0.1345
30	0.1345
36	0.1500
42	0.1750
48	0.2000
54	0.2250
60	0.2500
66	0.2750
72	0.3000
78	0.3250
84	0.3500
90	0.3750
96	0.4000
102	0.4250
108	0.4500
114	0.4750
120	0.5000

**Backfill Materials:**

Table 6-1 Values\* of modulus of soil reaction,  $E'$  (psi) based on depth of cover, type of soil, and relative compaction

Type of Soil†	Depth of Cover	Standard AASHTO relative compaction‡			
		85%	90%	95%	100%
Fine-grained soils with less than 25% sand content (CL, ML, CL-ML)	2-5 (0.6-1.5)	500 (3,450)	700 (4,830)	1,000 (6,895)	1,500 (10,340)
	5-10 (1.5-3.1)	600 (4,140)	1,000 (6,895)	1,400 (9,655)	2,000 (13,790)
	10-15 (3.1-4.6)	700 (4,830)	1,200 (8,275)	1,600 (11,030)	2,300 (15,860)
	15-20 (4.6-6.1)	800 (5,520)	1,300 (8,965)	1,800 (12,410)	2,600 (17,930)
Coarse-grained soils with fines (SM, SC)	2-5 (0.6-1.5)	600 (4,140)	1,000 (6,895)	1,200 (8,275)	1,900 (13,100)
	5-10 (1.5-3.1)	900 (6,205)	1,400 (9,655)	1,800 (12,410)	2,700 (18,615)
	10-15 (3.1-4.6)	1,000 (6,895)	1,500 (10,340)	2,100 (14,480)	3,200 (22,065)
	15-20 (4.6-6.1)	1,100 (7,585)	1,600 (11,030)	2,400 (16,545)	3,700 (25,510)
Coarse-grained soils with little or no fines (SP, SM, GP, GW)	2-5 (0.6-1.5)	700 (4,830)	1,000 (6,895)	1,600 (11,030)	2,500 (17,235)
	5-10 (1.5-3.1)	1,000 (6,895)	1,500 (10,340)	2,200 (15,170)	3,300 (22,750)
	10-15 (3.1-4.6)	1,050 (7,240)	1,600 (11,030)	2,400 (16,545)	3,600 (24,820)
	15-20 (4.6-6.1)	1,100 (7,585)	1,700 (11,720)	2,500 (17,235)	3,800 (26,200)

**Native Soils:**

Table 5-6 Values for the modulus of soil reaction  $E'_s$  for the native soil at pipe zone elevation

Granular		Cohesive		$E'_s$ (psf)
Blows/ft†	Description	$q_u$ (Tons/ft)	Description	
>0-1	very, very loose	>0-0.125	very, very soft	50
1-3	very loose	0.125-0.25	very soft	200
2-4		0.25-0.50	soft	700
4-8	loose	0.50-1.0	medium	1,600
8-15	slightly compact	1.0-2.0	stiff	3,000
15-30	compact	2.0-4.0	very stiff	5,000
30-60	dense	4.0-6.0	hard	10,000
>60	very dense	>6.0	very hard	20,000

**Composite  $E'$  Coefficients:**

Table 5-5 Values for the soil support combining factor  $S_c$

$M_{max}/M_{allow}$	$B_d/D = 1.25$	$B_d/D = 1.5$	$B_d/D = 1.75$	$B_d/D = 2$	$B_d/D = 2.5$	$B_d/D = 3$	$B_d/D = 4$	$B_d/D = 5$
0.005	0.02	0.05	0.08	0.12	0.23	0.43	0.72	1.00
0.01	0.03	0.07	0.11	0.15	0.27	0.47	0.74	1.00
0.02	0.05	0.10	0.15	0.20	0.32	0.52	0.77	1.00
0.05	0.10	0.15	0.20	0.27	0.38	0.58	0.80	1.00
0.1	0.15	0.20	0.27	0.35	0.46	0.65	0.84	1.00
0.2	0.25	0.30	0.38	0.47	0.58	0.75	0.88	1.00
0.4	0.45	0.50	0.56	0.64	0.75	0.85	0.93	1.00
0.6	0.65	0.70	0.75	0.81	0.87	0.94	0.98	1.00
0.8	0.84	0.87	0.90	0.93	0.96	0.98	1.00	1.00
1	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.5	1.40	1.30	1.20	1.12	1.06	1.03	1.00	1.00
2	1.70	1.50	1.40	1.30	1.20	1.10	1.05	1.00
3	2.20	1.80	1.65	1.50	1.35	1.20	1.10	1.00
≥5	3.00	2.20	1.90	1.70	1.50	1.30	1.15	1.00

NOTE: In-between values of  $S_c$  may be determined by straight-line interpolation from adjacent values.

Table 6-3; AWWA M11			
Highway HS-20 Load		Railroad E-80 Load	
Soil Cover	Load	Soil Cover	Load
ft	psf	ft	psf
1	1800	2	3800
2	800	5	2400
3	600	8	1600
4	400	10	1100
5	250	12	800
6	200	15	600
7	176	20	300
8	100	30	100

Note: Neglect live load when less than 100 psf; use dead load only.




Figure 4.3. Trench Condition.

Input Section		Output Section	
Wall thickness to use in design ( $t_w$ , in) =	0.6250	Mean Dia (D, in), OD - $t_s$ - $t_l$ =	60.63
Mortar Coating Thickness ( $t_c$ , in) (See note 7) =	1.00	Cylinder Outside Dia (OD, in), ID + 2 $t_c$ + 2 $t_l$ =	61.25
Soil backfill type	Sand & gravel	Pipe Outside Dia ( $B_o$ , ft), OD + 2 $t_c$ =	5.271
Depth of soil cover (H, ft) =	5.50	Wall stiffness (EI, in <sup>4</sup> /in), $30E10^6 I_s + 4E10^6 (I_c + I_l)$ =	943,685
Distance beyond pipe OD to trench wall (m, ft) =	1.00	Steel moment of inertia ( $I_s$ , in <sup>4</sup> /linear in), $t_s^3/12$ =	0.0203
Trench width at top of the pipe ( $B_d$ , ft) = $B_c + 2m$	7.27	Lining moment of inertia ( $I_l$ , in <sup>4</sup> /linear in), $t_l^3/12$ =	0.0000
Transition width ( $B_{tr}$ , ft) (Go to "transition" tab to calculate $B_{tr}$ )	8.57	Coating moment of inertia ( $I_c$ , in <sup>4</sup> /linear in), $t_c^3/12$ =	0.0833
Included additional load to apply to pipe	distributed load	Mean radius (r, in), D/2 =	30.31
Load, (Y, lbs)	67,500.0	$B_d/B_c$ =	1.38
Length of loaded surface area, a (ft)	3.40	Distributed load impact factor, I =	1.00
Width of loaded surface area, b (ft)	2.01	Surcharge load (W <sub>y</sub> , psf), $Y \cdot I / [(a+H)(b+H)]$ =	1,010
Unit weight of soil (w, pcf) =	120.00	Lane loading (LL, psf) =	0
Height of water surface above top of pipe ( $h_w$ , ft) =	0.00	Wheel load spread width (A, ft), $5.67+H$ =	0.00
Include saturated soil weight in deflection calc (Y/N) (see note 10) =	No	Wheel load spread length (B, ft), $0.83+H$ =	0.00
Live load (HS-20 Single/HS-20 ALT./E80/NA) =	NA	Alternate live load backfill factor (f) =	0.00
Modulus of soil reaction, $E'$ =	Per AWWA M11 500.00	Gov'n dimension parallel to long axis of pipe (L, ft) =	0.00
Modulus of the soil reaction ( $E'$ , psi) (See table 6-1 and note 8) =	500.00	$E'_r/E'_s$ =	NA
Native soil modulus ( $E'_s$ , psi) (See table 5-6) =	0.00	Modulus of soil reaction ( $E'$ , psi) =	500.00
Modulus of the backfill soil ( $E'_b$ , psi) (See table 6-1 and note 8) =	0.00	Bedding constant (K) =	0.110
Soil support combining factor ( $S_c$ ) (See table 5-5) =	0.00		
Deflection lag factor ( $D_L$ , 1.0-1.5) (See note 9) =	1.50		
Select bedding angle ( $\theta$ , degree) =	0		

**Notes for Designer:**

- Limit Mortar Coating to 1" max in  $\Delta x$  Calculations
- Selection of  $E'$  value from Table 6-1 shall be limited to 85% relative compaction effort, unless otherwise approved by Geotechnical Engineer. Coordinate with Geotechnical Report for suitable  $E'$  value for pipeline design.
- The deflection Lag factor is 1.0 for a pressurized pipe, however, if the pipe will sit empty for periods of time the value would be greater than 1.0.
- Saturated soil weight is accounted for using buoyancy reduction factor ( $R_w$ ).

Determination of External Load and Deflection for Trench Condition	
<b>Earth load</b>	
Earth load for trench condition ( $W_c$ , lb/linear in.), Non-saturated soil: $0.0361h_w B_c + R_w H w B_d / 12$ =	289.90
<b>Determination of Live Load for HS-20 wheel Or Cooper E-80 Railroad Loading</b>	
<b>Highway loading per AWWA M11</b>	
Single HS-20 truck live load on pipe from table 6-3 ( $P_L$ , psf) =	0.00
Single HS-20 truck live load on pipe ( $W_L$ , lb/linear in.), $P_L B_c / 12$ =	0.00
<b>Alternate Highway loading per AASHTO</b>	
Impact factor for highway ( $I_h$ , %), $33 \cdot (1 - 0.125H) / 100$ =	0%
Total wheel load applied at the surface ( $P$ , lbs) =	0
Total live load assuming truck travel transverse to pipe centerline ( $W_T$ , lbs), $[P(1+I_h)/(AB)+LL] \cdot A \cdot \text{Min}(B, B_c)$ =	0
Total live load assuming truck travel parallel to pipe centerline ( $W_P$ , lbs), $[P(1+I_h)/(AB)+LL] \cdot B \cdot \text{Min}(A, B_c)$ =	0
HS-20 ALT, Maximum AASHTO HS-20 Passing truck live load on pipe ( $W_L$ , lb/linear in.), $\{ \text{Max}(W_T, W_P) / [L + 1.75(0.75B_c)] \} / 12$ =	0.00
<b>Railroad loading per AWWA M11</b>	
Railroad loading on pipe from table 6-3 ( $W_L$ , lb/linear in.) =	0.00
<b>Surcharge loading</b>	
Surcharge loading on pipe ( $W_y$ , lb/linear in.) =	443.58
<b>Total External Load</b>	Total external load on pipe ( $W$ , lb/linear in.) = 733.48
<b>Deflection Results (Eqn 6-5, AWWA M11)</b>	
Vertical/Horizontal deflection of the pipe ( $\Delta x$ , in), $D_L [KW^3 / (EI + 0.061E'r^3)]$ =	1.88
Percent deflection, $\Delta x/D$ =	3.10%
This is not a standard type of pipe	

**Notes for Designer:**

- Allowable deflections used herein are set at 75% of allowable deflections shown in AWWA M11, consistent with MWH standards.
- Where internal vacuum occurs with cover depth less than 4 ft but not less than 2 ft care should be exercised in defining allowable buckling pressure. (AWWA M11 buckling footnote)
- Design factor  $FS=2.0$  is recommended by AWWA M11 4th Ed for all depths in buckling calculation. AWWA M11 3rd Ed recommended  $FS=3.0$  for  $H/B_c < 2.0$  and  $FS=2.5$  for  $H/B_c \geq 2$ .
- Total negative pressure does not include surcharge load.

**Deflection Result : Deflection is Within Allowable Limits**

Input Section		Output Section	
Include internal vacuum pressure	Yes	Water buoyancy factor ( $R_w$ ), $1 - (0.33(h_w/H))$ =	1.00
Internal vacuum pressure ( $P_v$ , psi) =	14.70	Elastic support coefficient, (B), $1 / (1 + 4e^{-0.0001B})$ =	0.26
Buckling factor of safety based on AWWA M-11 (3rd Ed/4th Ed)	4th Ed (2004)	$H/B_c$ =	1.04
		Buckling factor of safety, FS (See note 13) =	2.0
Allowable buckling pressure ( $q_a$ , psi), $(1/FS) [32 R_w B^2 E' (EI/B_c)]^{0.5}$ =			
Total Negative Pressure, live load condition (psi), $0.0361h_w + R_w W_{clay} / B_c + W_L / B_c$ (See note 14) =			
Total Negative Pressure, vacuum condition (psi), $0.0361h_w + R_w W_{clay} / B_c + P_v$ (See note 14) =			

**Buckling Result : Pipe stiffness acceptable**

Client: *(Client Name here)*  
 Project: *(Project Name Here)*  
 Description: *(Description of what is being calculated, specific building, system, discipline, etc...)*

Sheet: \_\_\_\_\_ of \_\_\_\_\_  
 Date: *mm/dd/yy*  
 Job No: *xxxxxx*  
 By: *(Author)* Chkd By: *xxx*

**Steel Pipe Wall Design - Trench Condition**
**Steel Pipe Wall Design - Trench Condition**

Equations used	
<p><b>Barlow Formula - Hoop Stress</b></p> $t = \frac{pd}{2s}$ <p>Where:  <math>t</math> = minimum pipe wall thickness for the specified internal design pressure, in. (mm)  <math>p</math> = internal design pressure, psi (kPa)  <math>d</math> = outside diameter of pipe steel cylinder (not including coatings), in. (mm)  <math>s</math> = allowable design stress, psi (kPa)</p>	<p><b>EARTH LOADING</b>                      Embankment Condition</p> $W_c = C_c w B_c^2$ <p>Where:  <math>C_c</math> = coefficient for embankment conditions, a function of soil properties.                      For flexible pipe, the settlement ratio (Spangler 1947) is assumed to be zero, in which case</p> <p>Where:  <math>H_c</math> = height of fill above top of pipe in ft (m)</p> <p>Then:</p> $W_c = \frac{H_c}{B_c} w B_c^2 = w H_c B_c$
<p><b>Buckling Equations</b></p> <p>Allowable Buckling Pressure</p> $q_a = \left( \frac{1}{FS} \right) \left( 32 R_w B^3 E' \frac{EI}{D^3} \right)^{1/2}$ <p>Vacuum Pres/Live Load Pressure</p> $\gamma_w h_w + R_w \frac{W_c}{D} + \frac{W_L}{D} \leq \gamma_w h_w + R_w \frac{W_c}{D} + P_v \leq q_a$ <p>Where:  <math>h_w</math> = height of water above conduit in in. (mm)  <math>\gamma_w</math> = specific weight of water = 0.0361 lb/cu in. (0.0098 kPa/mm<sup>3</sup>)  <math>P_v</math> = internal vacuum pressure in psi (kPa) = atmospheric pressure less absolute pressure inside pipe, in psi (kPa)  <math>W_c</math> = vertical soil load on pipe per unit length, in lb/in. (kPa/mm)</p>	<p><b>PIPE DEFLECTION</b></p> $\text{Deflx} = \frac{D, K W r^3}{EI + 0.0614E'r^3}$ <p>Where:</p> <p>Deflx = Vertical deflection of pipe in inches, (not to exceed 0.015 times the nominal diameter for mortar-lined and coated pipe, 0.025 times the nominal diameter for mortar-lined and dielectric coated pipe and 0.05 times the nominal diameter for dielectric lined and coated pipe.)</p> <p>DL = Deflection lag factor.                      K = Bedding constant                      W = Vertical load on pipe, lb/in.                      r = Mean radius of pipe shell, inches                      EI = Pipe stiffness, lb in.                      E' = Modulus of soil reaction, lb/in<sup>2</sup> A specific, rational method must be used to develop this number for soils at the site. The method must be reviewed.</p>



Burriss Basin - 60" line

$$ID = 60''$$

$$OD = 61.25''$$

$$t_s = .6250''$$

$$t_c = 1''$$

$$w = 120 \text{ lb/ft}^2$$

$$H_c = 5.5'$$

$$D_c = 63.25''$$

$$D_1 = 1.5$$

$$K = .1$$

$$r = .5 OD \rightarrow 30.3125''$$

$$D = ID + t_s + t_c \rightarrow 60.625''$$

$$t_L = 0''$$

$$E_s = 30 \times 10^6 \text{ lb/in}^2$$

$$E_c = 4 \times 10^6 \text{ lb/in}^2$$

$$EI = E_s I_s + E_c (I_L + I_c) \rightarrow 30 \times 10^6 \left( \frac{.6250^3}{12} \right) + 4 \times 10^6 \left( \frac{1^3}{12} + 0 \right) \rightarrow 943684 \text{ in}^4$$

$$I = t^3/12$$

$$* E' = 500$$

$$C_n = .55$$

$$\phi_s = .9$$

$$K_v = .74$$

$$FS_B = 2$$

$$r_o = .5 OD \rightarrow 30.625$$

$$\delta_w = 62.4 \text{ lb/ft}^3$$

$$H_w = 0$$

$$P_v = 14.7 \text{ lb/in}^2$$

\* Note E' taken from table 5-3.  
Assume most conservative SC @ 90%  
Compaction. Apply 1/2 F.S.

## Deflection Earth Load & Live Load

$$W_c = w H_c \left( \frac{D_c}{12} \right) \quad (\text{Eq. 5.3})$$

$$= (120)(5.5) \left( \frac{63.25}{12} \right) \rightarrow 3478.75 \text{ lb/ft} \quad \text{or} \\ 289.90 \text{ lb/in}$$

## Live Load — Cat 657

$$P = 135,000 \text{ lb} \quad (\text{axle load})$$

$$\frac{P}{2} = 67,500 \text{ lb} \quad (\text{single tire})$$

$$\text{tire dimension} = 40.8'' \times 24.12''$$

$$\text{Surface Area} = (40.8'' \times 24.12'') \left( \frac{1}{144} \right) \rightarrow 6.834 \text{ ft}^2$$

$$\text{Surface Pressure} = (67,500) / 6.834 \rightarrow 9877.09 \text{ lb/ft}^2$$

$$A_T = .5 \left( \frac{40.8}{12} \right) \rightarrow 1.7$$

$$B_T = .5 \left( \frac{24.12}{12} \right) \rightarrow 1.0$$

$$m = \left( \frac{A_T}{H_c} \right) \rightarrow .31$$

$$n = \left( \frac{B_T}{H_c} \right) \rightarrow .18$$

Use table 5-2 for Newmark Vertical influence Coefficients  
= .026

$$W_L = (4)(.026)(9877.09) \rightarrow 1027.21 \text{ lb/ft}^2 \quad \text{or} \\ 85.60 \text{ lb/in}$$

$$W_y = W_L \left( \frac{D_c}{12} \right) \rightarrow 1027.21 \left( \frac{63.25}{12} \right) \rightarrow 5414.25 \text{ lb/ft} \quad \text{or} \\ 451.19 \text{ lb/in}$$

$$W = W_c + W_y \rightarrow 289.9 + 451.19 \rightarrow \boxed{741.09 \text{ lb/in}}$$

Deflection

$$\Delta x = \left( \frac{D_o K W r^3}{EI + .061 E_i r^3} \right)$$

(Eq. 5.4)

$$= \left[ \frac{(1.5)(.1)(741.09)(30.3125^3)}{(943684 + .061(500)(30.3125^3)} \right] \text{---...}$$

$$\dots \longrightarrow \frac{3096189.119}{1793187.372} \longrightarrow 1.72 \text{ in}$$

$$\% \text{ Deflection} = \frac{\Delta x}{OD} \longrightarrow \frac{1.72}{61.25} \longrightarrow 2.81\%$$

Buckling

$$q_a = \frac{(1.2 C_n)(EI)^{.33} (\phi_s E' K_v)^{.67} R_H}{(FS_B) r_o} \quad (\text{Eq. 5.7})$$

$$= \frac{(1.2(.55))(943684)^{.33} ((.9)(500)(.74))^{.67} R_H}{2(30.625)} \dots$$

$$\dots \rightarrow \frac{3028.83 R_H}{61.25} \rightarrow 49.45 R_H \rightarrow 47.27 \text{ lb/in}^2$$

$$R_H = \frac{11.4}{11 + (2r/H_c)} \rightarrow \frac{11.4}{11 + \frac{2(30.3125)}{(5.5 \times 12)}} \rightarrow \frac{11.4}{11.92} \rightarrow .956$$

$$q_a \geq \frac{\gamma_w}{1.728} H_w + R_w \frac{W_c}{12 D_o} + P_v$$

$$\geq \frac{62.4}{1.728} 0 + R_w \frac{(289.9 \times 12)}{12(61.25)} + (14.7) \dots$$

$$\dots \rightarrow 4.733 R_w + 14.7 \rightarrow 4.733(1) + 14.7 \rightarrow 19.433 \text{ lb/in}^2$$

$$R_w = 1 - .33 \left( \frac{H_w}{H_c} \right) \rightarrow 1 - .33 \left( \frac{0}{5.5} \right) \rightarrow 1$$

$$47.27 \geq 19.433 \quad \checkmark$$

Table 6-4 Influence coefficients for rectangular areas

$m = A/H$ or $n = B/H$	$n = B/H$ or $m = A/H$								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.005	0.009	0.013	0.017	0.020	0.022	0.024	0.026	0.027
0.2	0.009	0.018	0.026	0.033	0.039	0.043	0.047	0.050	0.053
0.3	0.013	0.026	0.037	0.047	0.056	0.063	0.069	0.073	0.077
0.4	0.017	0.033	0.047	0.060	0.071	0.080	0.087	0.093	0.098
0.5	0.020	0.039	0.056	0.071	0.084	0.095	0.103	0.110	0.116
0.6	0.022	0.043	0.063	0.080	0.095	0.107	0.117	0.125	0.131
0.7	0.024	0.047	0.069	0.087	0.103	0.117	0.128	0.137	0.144
0.8	0.026	0.050	0.073	0.093	0.110	0.125	0.137	0.146	0.154
0.9	0.027	0.053	0.077	0.098	0.116	0.131	0.144	0.154	0.162
1.0	0.028	0.055	0.079	0.101	0.120	0.136	0.149	0.160	0.168
1.2	0.029	0.057	0.083	0.106	0.126	0.143	0.157	0.168	0.178
1.5	0.030	0.059	0.086	0.110	0.131	0.149	0.164	0.176	0.186
2.0	0.031	0.061	0.089	0.113	0.135	0.153	0.169	0.181	0.192
2.5	0.031	0.062	0.090	0.115	0.137	0.155	0.170	0.183	0.194
3.0	0.032	0.062	0.090	0.115	0.137	0.156	0.171	0.184	0.195
5.0	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196
10.0	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196
$\infty$	0.032	0.062	0.090	0.115	0.137	0.156	0.172	0.185	0.196

	1.0	1.2	1.5	2.0	2.5	3.0	5.0	10.0	$\infty$
0.1	0.028	0.029	0.030	0.031	0.031	0.032	0.032	0.032	0.032
0.2	0.055	0.057	0.059	0.061	0.062	0.062	0.062	0.062	0.062
0.3	0.079	0.083	0.086	0.089	0.090	0.090	0.090	0.090	0.090
0.4	0.101	0.106	0.110	0.113	0.115	0.115	0.115	0.115	0.115
0.5	0.120	0.126	0.131	0.135	0.137	0.137	0.137	0.137	0.137
0.6	0.136	0.143	0.149	0.153	0.155	0.156	0.156	0.156	0.156
0.7	0.149	0.157	0.164	0.169	0.170	0.171	0.172	0.172	0.172
0.8	0.160	0.168	0.176	0.181	0.183	0.184	0.185	0.185	0.185
0.9	0.168	0.178	0.186	0.192	0.194	0.195	0.196	0.196	0.196
1.0	0.175	0.185	0.193	0.200	0.202	0.203	0.204	0.205	0.205
1.2	0.185	0.196	0.205	0.212	0.215	0.216	0.217	0.218	0.218
1.5	0.193	0.205	0.215	0.223	0.226	0.228	0.229	0.230	0.230
2.0	0.200	0.212	0.223	0.232	0.236	0.238	0.239	0.240	0.240
2.5	0.202	0.215	0.226	0.236	0.240	0.242	0.244	0.244	0.244
3.0	0.203	0.216	0.228	0.238	0.242	0.244	0.246	0.247	0.247
5.0	0.204	0.217	0.229	0.239	0.244	0.246	0.249	0.249	0.249
10.0	0.205	0.218	0.230	0.240	0.244	0.247	0.249	0.250	0.250
$\infty$	0.205	0.218	0.230	0.240	0.244	0.247	0.249	0.250	0.250

Source: Newmark, N.M., Simplified Computation of Vertical Pressures in Elastic Foundations. *Circ. 24, Engrg. Exp. Stn., Univ. of Illinois (1935).*

Table 6-1 Values\* of modulus of soil reaction,  $E'$  (psi) based on depth of cover, type of soil, and relative compaction

Type of Soil <sup>†</sup>	Standard AASHTO relative compaction <sup>‡</sup>									
	Depth of Cover		85%		90%		95%		100%	
	ft	(m)	psi	(kPa)	psi	(kPa)	psi	(kPa)	psi	(kPa)
Fine-grained soils with less than 25% sand content (CL, ML, CL-ML)	2-5	(0.06-1.5)	500	(3,450)	700	(4,830)	1,000	(6,895)	1,500	(10,340)
	5-10	(1.5-3.1)	600	(4,140)	1,000	(6,895)	1,400	(9,655)	2,000	(13,790)
	10-15	(3.1-4.6)	700	(4,830)	1,200	(8,275)	1,600	(11,030)	2,300	(15,860)
	15-20	(4.6-6.1)	800	(5,520)	1,300	(8,965)	1,800	(12,410)	2,600	(17,930)
Coarse-grained soils with fines (SM, SC)	2-5	(0.06-1.5)	600	(4,140)	1,000	(6,895)	1,200	(8,275)	1,900	(13,100)
	5-10	(1.5-3.1)	900	(6,205)	1,400	(9,655)	1,800	(12,410)	2,700	(18,615)
	10-15	(3.1-4.6)	1,000	(6,895)	1,500	(10,340)	2,100	(14,480)	3,200	(22,065)
	15-20	(4.6-6.1)	1,100	(7,585)	1,600	(11,030)	2,400	(16,545)	3,700	(25,510)
Coarse-grained soils with little or no fines (SP, SM, GP, GW)	2-5	(0.06-1.5)	700	(4,830)	1,000	(6,895)	1,600	(11,030)	2,500	(17,235)
	5-10	(1.5-3.1)	1,000	(6,895)	1,500	(10,340)	2,200	(15,170)	3,300	(22,750)
	10-15	(3.1-4.6)	1,050	(7,240)	1,600	(11,030)	2,400	(16,545)	3,600	(24,820)
	15-20	(4.6-6.1)	1,100	(7,585)	1,700	(11,720)	2,500	(17,235)	3,800	(26,200)

\* Hartley, James D. and Duncan, James M., "E' and its Variation with Depth." *Journal of Transportation*, Division of ASCE, Sept. 1987.

<sup>†</sup> Soil type symbols are from the Unified Classification System.

<sup>‡</sup> *Soil compaction*. When specifying the amount of compaction required, it is very important to consider the degree of soil compaction that is economically obtainable in the field for a particular installation. The density and supporting strength of the native soil should be taken into account. The densification of the backfill envelope must include the haunches under the pipe to control both the horizontal and vertical pipe deflections. Specifying an unobtainable soil compaction value can result in inadequate support and injurious deflection. Therefore, a conservative assumption of the supporting capability of a soil is recommended, and good field inspection should be provided to verify that design assumptions are met.

Table 6-2 Unified soil classification

Symbol	Description
GW	Well-graded gravels, gravel-sand mixtures, little or no fines
GP	Poorly graded gravels, gravel-sand mixtures, little or no fines
GM	Silty gravels, poorly graded gravel-sand-silt mixtures
GC	Clayey gravels, poorly graded gravel-sand-clay mixtures
SW	Well-graded sands, gravelly sands, little or no fines
SP	Poorly graded sands, gravelly sands, little or no fines
SM	Silty sands, poorly graded sand-silt mixtures
SC	Clayey sands, poorly graded sand-clay mixtures
ML	Inorganic silts and very fine sand, silty or clayey fine sands
CL	Inorganic clays of low to medium plasticity
MH	Inorganic silts, micaceous or diatomaceous fine sandy or silty soils, elastic silts
CH	Inorganic clays of high plasticity, fat clays
OL	Organic silts and organic silt-clays of low plasticity
OH	Organic clays of medium to high plasticity
Pt	Peat and other highly organic soils

Source: Classification of Soils for Engineering Purposes. ASTM Standard D2487-69, ASTM, Philadelphia, Pa. (1969).

## **BURRIS BASIN GWRS TURNOUT PROJECT**

Appendix D  
July 1, 2019


# **Appendix D**

## **D.1 SCHEMATIC DESIGNS**

**LEGEND**

- 60" CMC&EL STEEL PIPE
- 48" CMC&EL STEEL PIPE
- 36" CMC&EL STEEL PIPE
- ≡≡≡ EXIST 66"/60" GWR LINE

DRAWING: v:\2042\active\2042499004\drawing\model\_files\499004c-pb003.dwg PLOTTED: 7/1/2019 4:20 PM BY: Wagstaff, Matt



EXISTING ACCESS - SWING GATE  
 66X60" ECCENTRIC REDUCER AND 60" TEE  
 STA 650+13

VALVE VAULT WITH 12" DRAIN LINE  
 STA 650+33.00

EXISTING FIBER OPTIC CONDUITS  
 EXISTING FENCING

PREPARED BY:



**Stantec**  
 38 TECHNOLOGY DRIVE, SUITE 100  
 IRVINE, CA 92618  
 949.923.6000    stantec.com

**BURRIS BASIN  
 GROUNDWATER REPLENISHMENT SYSTEM  
 PIPELINE OUTLET PROJECT  
 ALTERNATIVE 1**

DATE:	7/1/2019
SHEET	1
OF	2

JOB NO.  
 2042499004



- (A) — FURNISH AND INSTALL 60" CMC&EL STEEL PIPE (WELDxWELD)
- (B) — FURNISH AND INSTALL 60" CMC&EL 4-PIECE 47.42' BEND, ROTATED VERTICALLY 18.35' (CLASS 150) (WELDxWELD)
- (C) — FURNISH AND INSTALL 60" BUTTERFLY VALVE (FExFE)
- (D1) — FURNISH AND INSTALL 36" CMC&EL 4-PIECE 45' VERT. BEND (CLASS 150) (WELDxWELD)
- (D2) — FURNISH AND INSTALL 48" CMC&EL 4-PIECE 45' VERT. BEND (CLASS 150) (WELDxWELD)
- (E) — FURNISH AND INSTALL 60" SLIP ON FLANGE (WELD)
- (F1) — FURNISH AND INSTALL 60"x36" CMC&EL STEEL TEE
- (H1) — FURNISH AND INSTALL 36" CMC&EL 4-PIECE 45' VERT. BEND (CLASS 150) (WELDxWELD)
- (I1) — FURNISH AND INSTALL 36" SLIP ON FLANGE (WELD)
- (J) — FURNISH AND INSTALL PRESSURE GAUGE AND PRESSURE TRANSMITTER PER DETAIL X, SHEET X-X
- (K) — FURNISH AND INSTALL 48" FLANGED BALL VALVE (CLASS 150) WITH MOTOR OPERATED ACTUATOR AND HANDWHEEL
- (L) — FURNISH AND INSTALL 36" FLANGED BALL VALVE (CLASS 150) WITH MOTOR OPERATED ACTUATOR AND HANDWHEEL
- (M1) — FURNISH AND INSTALL 60"x48" ECCENTRIC REDUCER (FOT)
- (N) — FURNISH AND INSTALL 48" CMC&EL SPOOL. LENGTH AS REQUIRED (CLASS 150) (FExFE)
- (O) — FURNISH AND INSTALL 36" CMC&EL SPOOL. LENGTH AS REQUIRED (CLASS 150) (FExFE)
- (P) — FURNISH AND INSTALL 48" MAGNETIC FLOW METER (CLASS 150), MAX FLOW RATE = 70,000 GPM, WITH STAINLESS STEEL GROUNDING RINGS PER SPECIFICATION
- (Q) — FURNISH AND INSTALL 36" MAGNETIC FLOW METER (CLASS 150), MAX FLOW RATE = 70,000 GPM, WITH STAINLESS STEEL GROUNDING RINGS PER SPECIFICATION
- (R) — FURNISH AND INSTALL 48" CMC&EL SPOOL. LENGTH AS REQUIRED (CLASS 150) (FExPE)
- (S) — FURNISH AND INSTALL 36" CMC&EL SPOOL. LENGTH AS REQUIRED (CLASS 150) (FExPE)
- (T) — FURNISH AND INSTALL 8" COMBINATION AIR AND VACUUM RELEASE VALVE ASSEMBLY PER DETAIL X ON SHEET X (FExFE)
- (U) — FURNISH AND INSTALL PRESSURE GAUGE SIMILAR TO DETAIL X ON SHEET X WITHOUT PRESSURE TRANSMITTER. CAP AT TEE
- (V) — CONSTRUCT AIR-GAP STRUCTURE PER STRUCTURAL SHEETS
- (W) — CONSTRUCT DISSIPATER STRUCTURE PER DETAIL X ON SHEET X
- (X) — FURNISH AND INSTALL ULTRASONIC LEVEL SENSOR PER DETAIL X ON SHEET X

PREPARED BY:



**Stantec**  
 38 TECHNOLOGY DRIVE, SUITE 100  
 IRVINE, CA 92618  
 949.923.6000     stantec.com

**BURRIS BASIN  
 GROUNDWATER REPLENISHMENT SYSTEM  
 PIPELINE OUTLET PROJECT  
 ALTERNATIVE 1**


DATE: 7/1/2019
SHEET <u>2</u> OF <u>2</u>

JOB NO.  
2042499004

**LEGEND**

- 60" CMC&EL STEEL PIPE
- 48" CMC&EL STEEL PIPE
- 36" CMC&EL STEEL PIPE
- ≡≡≡ EXIST 66"/60" GWR LINE

DRAWING: v:\2042\active\2042499004\drawing\model\_files\499004c-pb004.dwg PLOTTED: 7/1/2019 4:21 PM BY: Wagstaff, Matt



EXISTING ACCESS - SWING GATE  
 66X60" ECCENTRIC REDUCER AND 60" TEE  
 STA 650+13

VALVE VAULT WITH 12" DRAIN LINE  
 STA 650+33.00

EXISTING FIBER OPTIC CONDUITS  
 EXISTING FENCING

PREPARED BY:




**Stantec**  
 38 TECHNOLOGY DRIVE, SUITE 100  
 IRVINE, CA 92618  
 949.923.6000    stantec.com

**BURRIS BASIN  
 GROUNDWATER REPLENISHMENT SYSTEM  
 PIPELINE OUTLET PROJECT  
 ALTERNATIVE 2**

DATE:	7/1/2019
SHEET	1
OF	2

JOB NO.  
 2042499004

- (A) — FURNISH AND INSTALL 60" CMC&EL STEEL PIPE (WELDxWELD)
- (B) — FURNISH AND INSTALL 60" CMC&EL 4-PIECE 47.42' BEND, ROTATED VERTICALLY 18.35° (CLASS 150) (WELDxWELD)
- (C) — FURNISH AND INSTALL 60" BUTTERFLY VALVE (FExFE)
- (E) — FURNISH AND INSTALL 60" SLIP ON FLANGE (WELD)
- (F) — CONSTRUCT 14'x14' UNDERGROUND VAULT FOR 60" GWRS APPURTENANCE
- (J) — FURNISH AND INSTALL PRESSURE GAUGE AND PRESSURE TRANSMITTER PER DETAIL X, SHEET X-X
- (K1) — FURNISH AND INSTALL 60" FLANGED BALL VALVE (CLASS 150) WITH MOTOR OPERATED ACTUATOR AND HANDWHEEL
- (P1) — FURNISH AND INSTALL 60" MAGNETIC FLOW METER (CLASS 150), MAX FLOW RATE = 70,000 GPM, WITH STAINLESS STEEL GROUNDING RINGS PER SPECIFICATION
- (R1) — FURNISH AND INSTALL 60" CMC&EL SPOOL. LENGTH AS REQUIRED (CLASS 150) (FExPE)
- (T) — FURNISH AND INSTALL 8" COMBINATION AIR AND VACUUM RELEASE VALVE ASSEMBLY PER DETAIL X ON SHEET X (FExFE)
- (U) — FURNISH AND INSTALL PRESSURE GAUGE SIMILAR TO DETAIL X ON SHEET X WITHOUT PRESSURE TRANSMITTER. CAP AT TEE
- (V) — CONSTRUCT AIR-GAP STRUCTURE PER STRUCTURAL SHEETS
- (W) — CONSTRUCT DISSIPATER STRUCTURE PER DETAIL X ON SHEET X
- (X) — FURNISH AND INSTALL ULTRASONIC LEVEL SENSOR PER DETAIL X ON SHEET X

PREPARED BY:  <b>Stantec</b> <small>38 TECHNOLOGY DRIVE, SUITE 100          IRVINE, CA 92618          949.923.6000     stantec.com</small>	<b>BURRIS BASIN          GROUNDWATER REPLENISHMENT SYSTEM          PIPELINE OUTLET PROJECT          ALTERNATIVE 2</b>	DATE: 7/1/2019	JOB NO. 2042499004
		SHEET <u>2</u> OF <u>2</u>	

## **BURRIS BASIN GWRS TURNOUT PROJECT**

Appendix E  
July 1, 2019

# **Appendix E**

## **E.1 CATALOGUE CUT SHEETS**