

Notice of Determination

Appendix D

To:

Office of Planning and Research
U.S. Mail: Street Address:
P.O. Box 3044 1400 Tenth St., Rm 113
Sacramento, CA 95812-3044 Sacramento, CA 95814

County Clerk
County of: Orange
Address: 601 North Ross Street
Santa Ana, CA 92701

From:

Public Agency: South Coast Water District
Address: 31592 West Street
Laguna Beach, CA 92651
Contact: Taryn Kjolsing, Engineering Manager
Phone: 949-541-1327

Lead Agency (if different from above):
Address:
Contact:
Phone:

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 2022090173

Project Title: Mission Hospital Pipeline Improvements Project

Project Applicant: South Coast Water District

Project Location (include county): Orange County in the City of Laguna Beach, south of 3rd Avenue, north

Project Description:

The South Coast Water District, per it's 2017 Master Plan, proposes pipeline improvements for approximately 2,000 linear feet of 6-inch and 8-inch water main near the Mission Hospital that is unable to provide the required 4,000 gallons per minute (gpm) of fire flow at a 20 pressure-per-square-inch (psi) residual pressure. The Project involves replacing 1,350 linear feet of 8-inch asbestos cement pipe (ACP) water main with 12-inch polyvinyl chloride (PVC) pipe, replacing 160 linear feet of 6-inch ACP water

This is to advise that the South Coast Water District has approved the above (Lead Agency or Responsible Agency)

described project on 11/17/22 and has made the following determinations regarding the above described project.

- 1. The project will not have a significant effect on the environment.
2. An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA. A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures were made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan was adopted for this project.
5. A statement of Overriding Considerations was adopted for this project.
6. Findings were made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the negative Declaration, is available to the General Public at:

https://www.scwd.org/about/district_projects/mission_hospital_pipeline_improvements_project/index.p

Signature (Public Agency): Taryn Kjolsing Title: Engineering Manager

Date: 11/22/22 Date Received for filing at OPR: