

Summary Form for Electronic Document Submittal

Form F

Lead agencies may include 15 hardcopies of this document when submitting electronic copies of Environmental Impact Reports, Negative Declarations, Mitigated Negative Declarations, or Notices of Preparation to the State Clearinghouse (SCH). The SCH also accepts other summaries, such as EIR Executive Summaries prepared pursuant to CEQA Guidelines Section 15123. Please include one copy of the Notice of Completion Form (NOC) with your submission and attach the summary to each electronic copy of the document.

SCH #: _____

Project Title: Victory Pump Station Replacement Project

Lead Agency: Los Angeles Department of Water and Power

Contact Name: Kathryn Laudeman

Email: kathryn.laudeman@ladwp.com

Phone Number: (213)367-6376

Project Location: Los Angeles

City

Los Angeles

County

Project Description (Proposed actions, location, and/or consequences).

LADWP proposes to implement the Victory Pump Station Replacement Project (the Proposed Project), which involves the construction of a new pump station to replace the existing aged, temporary underground pumping facility (the existing facility) at 24661 Victory Boulevard in the West Hills community of Los Angeles. To allow for optimum performance of the proposed new pump station, approximately 1,300 linear feet of eight-inch-diameter pipeline would also be installed along Calvert Street from Sylvan Street to Valley Circle Boulevard, and approximately 500 linear feet of 12-inch diameter pipeline would be installed in Calvert Street from Valley Circle Boulevard to Pat Avenue. The Proposed Project would allow the facility to meet current building, plumbing, mechanical, electrical, green and geological standards, reduce maintenance, and access concerns, increase fire flow requirements, and provide for current and projected system demands for water supply more efficiently and reliably.

Identify the project's significant or potentially significant effects and briefly describe any proposed mitigation measures that would reduce or avoid that effect.

Cultural Resources - Based on archival research, review of previous investigations in the vicinity of the project, and review of the prehistoric context portions of the project area have been identified as having cultural resources sensitivity. An archaeological monitor will be present for ground disturbing work in areas where there is a reasonable likelihood of encountering archaeological resources.

Noise - Construction noise concerns. Public notification and coordination will occur prior to work in any one area. Equipment and work practices will be managed to minimize noise impacts. Temporary barriers will be constructed if work will occur for more than one month within 500 feet of a sensitive receptor.

Tribal Cultural Resources - Based on tribal consultation, a tribal monitor will be invited to monitor any ground disturbing activity that has a reasonable likelihood of encountering tribal cultural resources.

If applicable, describe any of the project's areas of controversy known to the Lead Agency, including issues raised by agencies and the public.

Not Applicable

Provide a list of the responsible or trustee agencies for the project.

Not Applicable