

# Summary Form for Electronic Document Submittal

Form F

Lead agencies may include 15 hardcopies of this document when submitting electronic copies of Environmental Impact Reports, Negative Declarations, Mitigated Negative Declarations, or Notices of Preparation to the State Clearinghouse (SCH). The SCH also accepts other summaries, such as EIR Executive Summaries prepared pursuant to CEQA Guidelines Section 15123. Please include one copy of the Notice of Completion Form (NOC) with your submission and attach the summary to each electronic copy of the document.

SCH #: \_\_\_\_\_

Project Title: \_\_\_\_\_

Lead Agency: \_\_\_\_\_

Contact Name: \_\_\_\_\_

Email: \_\_\_\_\_ Phone Number: \_\_\_\_\_

Project Location: \_\_\_\_\_  
*City* *County*

Project Description (Proposed actions, location, and/or consequences).

Identify the project's significant or potentially significant effects and briefly describe any proposed mitigation measures that would reduce or avoid that effect.

## Document Summary, page 2

### Project Description: (continued)

... **Proposed Facilities.** The primary focus in the Project Report is the evaluation and selection of a treatment alternative to prevent future discharges that are out of compliance with the 2009 Waste Discharge Requirements. According to the Report, the existing WWTP has been plagued with operational issues since it was commissioned in 2010. Due to operational issues, the WWTP has consistently been out of compliance with the WDR limits. In short, the WWTP has not operated as originally designed and this has resulted in secondary treatment capacity not being used and discharge requirements, such as Total Suspended Solids (TSS), Electrical Conductivity (EC), and Total Nitrogen. The net effect of this situation is that the existing WWTP needs to be upgraded or an alternative treatment system needs to be installed. After evaluating four alternatives in the Project Report, Alternative 2, the Biolac Extended Aeration System, was selected as the recommended alternative for treatment and disposal. The Biolac System can meet the nitrogen disposal requirements and eliminates the acquisition of additional crop land and access to supplemental irrigation water.

If applicable, describe any of the project's areas of controversy known to the Lead Agency, including issues raised by agencies and the public.

Provide a list of the responsible or trustee agencies for the project.