

Miller Drilling Co.  
329 N. Main St.  
Templeton, CA 93465  
(805) 434-1888

# Miller Drilling Co.

Contractors License No. 324634

## PUMP TEST REPORT

WELL OWNER: JOHN & JILL BACKER      Pump Set: 300'      Job# 21081  
BILLING ADDRESS: PO BOX 415      Pump Size: 7 1/2 HP      Well #: 5"  
CRESTON, CA 93423      Testing Method: EXISTING PUMP      Well Depth: 455'  
john@augustridge.com      Perf Rec: 295'      455'

Standing Level Before Test: 159.76      LOCATION: 8790 EAST HWY 41

### TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER/BOWLS	GPM
8:35	189.12	CLEAR NO ODOR		86
8:45	194.62	CLEAR NO ODOR		74
9:05	194.71	CLEAR NO ODOR		74
12:20	195.48	CLEAR NO ODOR		74
8:24	195.5	CLEAR NO ODOR		74

Notes: METER START 509735; METER STOP 527743; = 75.03 GPM AVERAGE

STANDING LEVEL AFTER TEST: 165.12 AFTER 10 MINUTES  
FINAL TEST RESULTS:      Produced: 74 GPM for 4 hours on: 8.6.18  
Test Run By:      CHRIS A.

**Abalone Coast Analytical, Inc.**

141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401  
Phone: 595-1080 Fax: 595-1075  
ELAP #2661

Order #: 18-5004  
Date/Time Rec'd: 8/6/18 1358

**Miller Drilling Company**  
301 North Main Street  
Templeton, CA 93465


**Contact: Kurt Bollinger**  
Phone: 434-1888  
Sampler: Chris Andres

Project:

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	#21081, Backer	8/6/18 0910	Total Coliform	SM 9223 B.	Absent	/100ml	1	08/07/18
	8790 E. Hwy 41		E-coli	IDEXX	Absent	/100ml	1	08/07/18

This sample passes water quality standards for Total Coliform and E. Coli Bacteria.

Report Completion Date: 8/7/18

Reviewed By: 

Sean Rogers, Lab Director

**Definitions:**

Absent = Less than 1 CFU/100mLs  
Present = 1 or more CFU/100mLs  
CFU = Colony Forming Unit  
RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.