

# Notice of Intent to Adopt a Mitigated Negative Declaration

Pursuant to California Environmental Quality Act (CEQA) Section 21092 and CEQA  
Guidelines Section 15072

**PROJECT TITLE:** Saxon Reservoir and Replacement Well Project (Project)

**APPLICANT:** Golden State Water Company (GSWC) – South San Gabriel (Applicant)

**WATER SYSTEM NUMBER:** 1910223

**LEAD AGENCY:** State Water Resources Control Board (State Water Board)

**PROJECT LOCATION:** 490 East Saxon Avenue, San Gabriel, CA, 91776, APN: 5370-030-800, Los Angeles County.

**PROJECT DESCRIPTION:** Golden State Water Company (GSWC) – South San Gabriel proposes to construct a 750,000-gallon above-ground potable water storage tank, booster pump station, stationary emergency 450kW diesel generator, and a disinfection system with associated lighting, control panels, and appurtenances at the Saxon Well Site. The proposed Project also includes the construction of a new Saxon Well 5 to replace Saxon Well 3, in which both wells are located on the same site. The existing office/warehouse building at the Project location will be demolished to make room for the new components. The purpose of the Project is to provide potable water to the South San Gabriel System while meeting existing water system demand. The Project is needed to address existing water storage deficiency, add redundancy to the existing system, and maintain an uninterrupted supply of water for the system. The Project is not considered overall capacity increasing because the overall capacity required by the South San Gabriel System would remain the same with the existing conditions. The proposed Project would also be located in a fully developed urban area with a stable customer base. The proposed storage tank would increase storage within the South San Gabriel System to meet an increase in demand.

**COMMENT PERIOD:** 30-Days

**STARTING DATE:** March 14, 2023

**ENDING DATE:** April 13, 2023

**NOTICE IS HEREBY GIVEN** that the State Water Board intends to adopt a Mitigated Negative Declaration for the Project in accordance with CEQA Guidelines.

E. JOAQUIN ESQUIVEL, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

**ADDRESS WHERE COPIES OF THE PROPOSED MITIGATED NEGATIVE DECLARATION,  
INITIAL STUDY, AND REFERENCE ARE AVAILABLE FOR REVIEW:**

State Water Resources Control Board  
Hollywood District Office (07)  
500 North Central Avenue, Suite 500  
Glendale, CA 91203

The Project site is not present on any of the lists enumerated under section 65962.5 of the government code.