

Channel Coast District Damage Assessment

Submitted by: Dexter.Reynolds1

Submitted time: Jan 12, 2023, 1:33:08 PM

Park Unit

Gaviota SP

Title

Hot Springs Water Line Failure

Cause of Damage

Natural (Storm, earthquake, etc)

Is the date of damage known?

Yes

Date of Damage

Jan 9, 2023

Is this a threat to public safety

- **yes**

Does damage require park closure

- **Yes**

Select all that apply

- **public use area**
- **park facility (restroom, lift station, gate, entrance road)**
- **trail**
- **road**
- **public access**

Describe the Area

Single point of damage

Location

Hot Springs Fire Road/Trespass Trail- Lat: 34.50426 Lon: -120.2225

Select BEST Category

F. Public Utilities

Does material need to be removed from property?

no

Is heavy equipment required to fix?

- **Yes**

Is immediate action needed?

YES

Is this damage due to impacts of ocean waves?

no

Is this in or near a fresh water waterway

yes


Was this already partially damaged prior to recent event

no

Is this related to a known existing PID project

No

Upload Photo



upload_photo-20230112-213227.jpg



upload_photo-20230112-213239.jpg

Additional Notes

Waterline has been broken from damage caused from storm rainfall runoff in the Gaviota Creek watershed. The waterline culverts, and road bed is in need of repair and the road condition needs to be further evaluated. This waterline supplies water from our spring source to our water treatment facility and is the primary source of potable water for entire Gaviota State Park campground, public beach access day use area, Hwy 101 Caltrans rest area and several residences. Major public safety concern, loss of revenue, loss of public utility.

Who is the team lead for this assessment

Dex