



May 8, 2023

Via Email

ken@scenicwonders.com

Ken LeBlanc
KL Water and Land LLC
7548 Henness Circle
Yosemite National Park, CA 95389
Re: Fire Flow Analysis

Dear Mr. LeBlanc,

Engineering Fire Protection, LLC (EFP) has been retained by KL Water & Land LLC (Client) to provide fire code analysis for the properties located at 7548 Henness Circle, Yosemite National Park, CA 95389. This report has been prepared to determine the fire flow demand, fire flow volume, fire service line sizing, fire sprinkler system lead-in sizing and domestic water main sizing as well as the building fire separation recommendation.

APPLICABLE STANDARDS AND CODES

- California Fire Code 2022 (CFC)
- California Building Code 2022 (CBC)
- California Residential Code 2022 (CRC)
- NFPA 13D, 2022 Edition
- NFPA 1142, 2022 Edition
- Rural Wildfire Regulations of Mariposa County, including Titles 8, 16, 17
- PRC 4290 codes

Building Information

Eight buildings are currently proposed within the Scenic Wonders properties. Building 1 is proposed to be a single family residence with a building area of 5,000 sqft. Building 2 is proposed to be a single family residence with a building area of 3,850 sqft. Building 3 is proposed to be a mixed-use with a 2-bedroom single family residence, a public laundry room and a commercial garage, the building area will be 3,200 sqft in total. Building 5, Building 7 and Building 8 are proposed to be two-family residences with a building area of 1,150 sqft. Both Building 4 and Building 6 are proposed to be four-family residences with a building area of 2,700 sqft. All the buildings will be built to meet Type VB Construction Type.

Fire Flow Calculation

The public municipal water supply system is unavailable to the property, therefore, a private water supply system is proposed to meet both domestic water demand and fire flow demand. With the approval of the State Fire Marshal Office, NFPA 1142 is allowed to be adopted to determine the fire flow demand for the proposed properties.

Because the buildings are less than 50-ft from each other, Structures with Exposure Hazards method in compliance with NFPA 1142 Section 4.3 is adopted for the fire flow water supply volume calculations.

$$WS_{\min} = \frac{VS_{\text{tot}}}{OHC} (CC) \times 1.5 \quad [4.3.1]$$

where:

WS_{\min} = minimum water supply in gal (For results in L, multiply by 3.785.)

VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)

OHC = occupancy hazard classification number

CC = construction classification number

Based on the calculations, Building 1 has the highest fire flow demand of the eight buildings, a total fire flow volume of 21,500 Gal, and supplied at minimum 1,000 gpm fire flow rate for 21.5 mins. According to the client's provided data, the domestic demand is 190 gpm. Therefore, the tank is required to be sized to provide minimum 21,500 Gal of water for fire fighting purpose while still meeting the 3,800 Gal of domestic water demand. To meet the fire flow/domestic demand, two 25,000 Gal tank are proposed for the property.

In compliance with CFC Table C102.1, for fire flow demand less than 1,750 gpm, one minimum hydrant is required to be installed with 312.5-ft minimum distance between the hydrant and the frontage of the fire access lane serving the buildings. To meet the travel distance requirement, two hydrants are proposed.

Hydrant #1 is proposed to cover Building 1, 2, 4, 5, 6, 7 and 8 with the 220-ft as the maximum travel distance (Hydrant #1 to Building 2). Hydrant #1 has 40-ft elevation difference with the base of the tank, based on the hydraulic calculations, the residual pressure at the outlet of Hydrant #1 when flowing 1,000 gpm is 15 psi (25 psi when the tank is full). The hydrant is proposed to be supplied directly by the dedicated 8-inch private fire main, refer to Attachment #1, Site Sketch for more detail.

Hydrant #2 is proposed to cover Building 1, 2, 3, 5, 6, 7 and 8 with the 265-ft as the maximum travel distance (Hydrant #2 respectively to Building 2 and Building 3). Building 4 is proposed to be built within 15-ft from Hydrant #2, less than 40-ft, the minimum hydrant to building distance in compliance with NFPA 24 Section 7.2.3. However, Hydrant #1 is within 220-ft from Building 4, providing fire fighter a different option when the Hydrant #2 is deemed dangerous to use. Hydrant #2 has 31-ft elevation difference with the base of the tank, based on the hydraulic calculations, the residual pressure at the outlet of Hydrant #2 when flowing 1,000 gpm is 11 psi (21 psi when the tank is full). The hydrant is proposed to be supplied directly by the dedicated 8-inch private fire main, refer to Attachment #1, Site Sketch for more detail.

Fire Sprinkler System Requirement

Fire sprinkler systems are required to be provided throughout the buildings containing Group R occupancies.

In compliance with CBC Section R313.2 and Section R313.3, single-family units and two-family units including Building 1, Building 2, Building 5, Building 7, and Building 8 are required to be protected by a fire sprinkler system designed per NFPA 13D standard.

Fire Barriers designed in compliance with CBC Section 707.3.10 are proposed to the four-unit buildings like Building 4 and Building 6 to separate the four units into two two-unit fire areas. In compliance with CBC Section 903.3.1.3, the two buildings are required to be protected by a fire sprinkler system designed per NFPA 13D standard.

For Building 3 that is considered as a mixed-use building with a single family residence (Group R-3), a public laundry room (Group B) and a commercial garage (Group S-1), a **Fire Wall** design compliance with CBC Section 706 is required to be installed to separate the building into residential building and commercial building. In compliance with CBC Section 903.3.1.3, the residential building portion is required to be protected by a fire sprinkler system designed per NFPA 13D standard. In compliance with CBC Section 903.2.9, the commercial building portion is not required to be protected by a fire sprinkler system.

Water Supply Requirement


The design team proposes 2 inch CPVC pipes as combined supply lead-in for each building along with 4 inch Schedule 80 PVC pipe as the domestic underground to meet both fire sprinkler system demand and domestic demand. The combined fire sprinkler/domestic demand to the discharge side of the boost pump installed at the base on the tank is 220 gpm at 36.5 psi. The fire sprinkler system demand is 30 gpm at 40 psi for any building (it's anticipated to have one building on fire), the combined domestic demand is 190 gpm for all the buildings. Therefore, the domestic boost pumps must be sized to meet the demand of 220 gpm at 36.5 psi. To improve the system reliability, we recommend using redundant pumps in duplex or triplex configurations, the pumping system should alternate pumping cycles between the pumps.

Submitted By:

Yifan Xuan
Fire Protection Consultant

Reviewed By:

Yu Guan, PE
Fire Protection Engineer



Attachment 1: Site Sketch

Attachment 2: Hydrant Demand Hydraulic Calculation Report


Attachment 3: Domestic/Sprinkler Demand Hydraulic Calculation Report

Attachment 4: Fire Flow and Domestic Demand Calculation Spreadsheet

Scenic Wonders Project Attachment 1: Site Sketch

Site Plan, Water System, Fire Hydrants Sheet2

NOTE: This drawing is for information purpose only and is not to be used for construction and/or exact main locations



1000gal Diesel
1000gal Gasoline
Fuel Tanks
w/Containment

Fire Hydrant #2
Elevation 6052

Fire Hydrant #1
Elevation 6044

BLG 3
Commercial Garage
2 Storages
3800sf

BLG 4
Garage
10,184, 18A
22,000sf

BLG 5
Garage
(1) 18A, 18A, 152 sqft
(2) 200, 18A, 18 sqft

BLG 1
Residence
616, 18A
5000sf

BLG 6
Garage
(1) 18A, 18A
52 sqft
(2) 201, 18A
731 sqft

BLG 7
Garage
2 Storages
2200sf



BLG 8
Garage
2 Storages
2200sf

(2) Water Tanks
Phase 1- 25,000gal
Phase 2- 25,000gal
Tank Base Elevation 6085'
Fire Hydrant Water Level 6095.7'
Tank Height 32'

Attachment 1: Site Sketch

Scenic Wonders Project Water System Schematic 3/13/2023

NOTE: This drawing is for information purpose only and is not to be used for construction and/or exact main locations.



Well#4 Notes
Well Depth- 946' Dia 6"
Casing- 11" to 53'
Well Pump- 5hp, 3ph 230v
1 1/2" Discharge
1" water meter onsite
Well Pump Depth- approx. 900'
Water Production- 14GPM in 2022
Static Water Level- 770ft, July, 2021

Phase 1 Buildings

Phase 2 Buildings



Hydraulic Overview



Job Number: 1
Report Description: Residential

Job	
Job Number 1	Design Engineer
Job Name: Drawing1	Phone FAX
Address 1	State Certification/License Number
Address 2	AHJ
Address 3	Job Site/Building

System	
	Hose Streams 1000.00
	Number Of Sprinklers Calculated 0 0
System Pressure Demand 2.995	System Flow Demand 1000.00
Total Demand 1000.00 @ 2.995	Pressure Result +11.258 (79.0%)

Supplies					Check Point Gauges				
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)	Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)
1	Water Supply	1500.00		14.300	14.200				

hydrant.cad Water Supply at Node 1 (1500.00, 0.00, 14.300, 14.200)






Hydraulic Summary

Job Number: 1
Report Description: Residential

Job									
Job Number 1					Design Engineer				
Job Name: Drawing1					State Certification/License Number				
Address 1					AHJ				
Address 2					Job Site/Building				
Address 3					Drawing Name hydrant.cad				
System					Remote Area(s)				
Most Demanding Sprinkler Data K-Factor at					AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area				
Hose Allowance At Source 0.00									
Additional Hose Supplies Node Flow(gpm) Hydrant At Node 3 1000.00									
Total Hose Streams 1000.00									
System Flow Demand 1000.00		Total Water Required (Including Hose Allowance) 1000.00							
Maximum Pressure Unbalance In Loops 0.000									
Maximum Velocity Above Ground									
Maximum Velocity Under Ground 5.64 between nodes 1 and 3									
Volume capacity of Wet Pipes 1305.99gal		Volume capacity of Dry Pipes							
Supplies									
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply		14.300	14.200	1500.00	14.253	1000.00	2.995	11.258
Contractor									
Contractor Number				Contact Name			Contact Title		
Name of Contractor:					Phone		Extension		
Address 1					FAX				
Address 2					E-mail				
Address 3					Web-Site				



Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static: Pressure
14.300

Residual: Pressure
14.200 @ 1500.00

Available Pressure at System Demand
14.253 @ 1000.00

Required Pressure at System Demand
2.995 @ 1000.00

Required Pressure at System Demand (Including Hose Allowance at Source)
2.995 @ 1000.00



Summary Of Outflowing Devices

Job Number: 1

Report Description: Residential

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Hydrant 3	1000.00	1000.00	0	0.000		
⇒ Most Demanding Sprinkler Data						



Node Analysis

Job Number: 1

Report Description: Residential

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	0'-0	S	2.995	1000.00



Hydraulic Analysis

Job Number: 1
Report Description: Residential

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
Route 1							
UG	8.5100	1000.00	5.64	140	0.005082	442'-0	Pf 2.995
3	0'-0	1000.00		0.000	Hydrant,	147'-3	Pe
1	0'-0			2.995	7EE(16'-4½), E(32'-8½), S	589'-3	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)	C Value Multiplier
$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$	Value Of C 100 130 140 150
	Multiplying Factor 0.713 1.16 1.33 1.51

Pipe Type Legend	Units Legend	Fittings Legend
AO Arm-Over	Diameter Inch	ALV Alarm Valve
BL Branch Line	Elevation Foot	AngV Angle Valve
CM Cross Main	Flow gpm	b Bushing
DN Drain	Discharge gpm	BaIV Ball Valve
DR Drop	Velocity fps	BFP Backflow Preventer
DY Dynamic	Pressure psi	BV Butterfly Valve
FM Feed Main	Length Foot	C Cross Flow Turn 90°
FR Feed Riser	Friction Loss psi/Foot	cplg Coupling
MS Miscellaneous	HWC Hazen-Williams Constant	Cr Cross Run
OR Outrigger	Pt Total pressure at a point in a pipe	CV Check Valve
RN Riser Nipple	Pn Normal pressure at a point in a pipe	DeIV Deluge Valve
SP Sprig	Pf Pressure loss due to friction between points	DPV Dry Pipe Valve
ST Stand Pipe	Pe Pressure due to elevation difference between indicated points	E 90° Elbow
UG Underground	Pv Velocity pressure at a point in a pipe	EE 45° Elbow
		Ee1 11¼° Elbow
		Ee2 22½° Elbow
		f Flow Device
		fd Flex Drop
		FDC Fire Department Connection
		fE 90° FireLock(TM) Elbow
		fEE 45° FireLock(TM) Elbow
		flg Flange
		FN Floating Node
		fT FireLock(TM) Tee
		g Gauge
		GloV Globe Valve
		GV Gate Valve
		Ho Hose
		Hose Hose
		HV Hose Valve
		Hyd Hydrant
		LtE Long Turn Elbow
		mecT Mechanical Tee
		Noz Nozzle
		P1 Pump In
		P2 Pump Out
		PIV Post Indicating Valve
		PO Pipe Outlet
		PrV Pressure Relief Valve
		PRV Pressure Reducing Valve
		red Reducer/Adapter
		S Supply
		sCV Swing Check Valve
		SFx Seismic Flex
		Spr Sprinkler
		St Strainer
		T Tee Flow Turn 90°
		Tr Tee Run
		U Union
		WirF Wirsbo
		WMV Water Meter Valve
		Z Cap





Job	
Job Number 1	Design Engineer
Job Name: Drawing1	Phone FAX
Address 1	State Certification/License Number
Address 2	AHJ
Address 3	Job Site/Building

System	
	Hose Streams 1000.00
	Number Of Sprinklers Calculated 0 0
System Pressure Demand 1.857	System Flow Demand 1000.00
Total Demand 1000.00 @ 1.857	Pressure Result +15.396 (89.2%)

Supplies						Check Point Gauges			
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)	Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)
1	Water Supply	1500.00		17.300	17.200				

hydrant-1.cad Water Supply at Node 1 (1500.00, 0.00, 17.300, 17.200)






Hydraulic Summary

Job Number: 1
Report Description: Residential

Job									
Job Number 1					Design Engineer				
Job Name: Drawing1					State Certification/License Number				
Address 1					AHJ				
Address 2					Job Site/Building				
Address 3					Drawing Name hydrant-1.cad				
System					Remote Area(s)				
Most Demanding Sprinkler Data K-Factor at					AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area				
Hose Allowance At Source 0.00									
Additional Hose Supplies									
<u>Node</u>		<u>Flow(gpm)</u>							
Hydrant At Node 3		1000.00							
Total Hose Streams 1000.00									
System Flow Demand 1000.00		Total Water Required (Including Hose Allowance) 1000.00							
Maximum Pressure Unbalance In Loops 0.000									
Maximum Velocity Above Ground									
Maximum Velocity Under Ground 5.64 between nodes 1 and 3									
Volume capacity of Wet Pipes 886.42gal		Volume capacity of Dry Pipes							
Supplies									
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply		17.300	17.200	1500.00	17.253	1000.00	1.857	15.396
Contractor									
Contractor Number			Contact Name			Contact Title			
Name of Contractor:					Phone			Extension	
Address 1					FAX				
Address 2					E-mail				
Address 3					Web-Site				



Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static: Pressure
17.300

Residual: Pressure
17.200 @ 1500.00

Available Pressure at System Demand
17.253 @ 1000.00

Required Pressure at System Demand
1.857 @ 1000.00

Required Pressure at System Demand (Including Hose Allowance at Source)
1.857 @ 1000.00



Summary Of Outflowing Devices

Job Number: 1

Report Description: Residential

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Hydrant 3	1000.00	1000.00	0	0.000		
⇒ Most Demanding Sprinkler Data						



Node Analysis

Job Number: 1

Report Description: Residential

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	0'-0	S	1.857	1000.00





Hydraulic Analysis

Job Number: 1
Report Description: Residential

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
Route 1							
UG	8.5100	1000.00	5.64	140	0.005082	300'-0"	Pf 1.857
3	0'-0"	1000.00		0.000	Hydrant,	65'-5½"	Pe
1	0'-0"			1.857	4EE(16'-4½), S	365'-5½"	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)	C Value Multiplier										
$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$	<table border="1"> <tr> <td>Value Of C</td> <td>100</td> <td>130</td> <td>140</td> <td>150</td> </tr> <tr> <td>Multiplying Factor</td> <td>0.713</td> <td>1.16</td> <td>1.33</td> <td>1.51</td> </tr> </table>	Value Of C	100	130	140	150	Multiplying Factor	0.713	1.16	1.33	1.51
Value Of C	100	130	140	150							
Multiplying Factor	0.713	1.16	1.33	1.51							

Pipe Type Legend	Units Legend	Fittings Legend
AO Arm-Over	Diameter Inch	ALV Alarm Valve
BL Branch Line	Elevation Foot	AngV Angle Valve
CM Cross Main	Flow gpm	b Bushing
DN Drain	Discharge gpm	BaV Ball Valve
DR Drop	Velocity fps	BFP Backflow Preventer
DY Dynamic	Pressure psi	BV Butterfly Valve
FM Feed Main	Length Foot	C Cross Flow Turn 90°
FR Feed Riser	Friction Loss psi/Foot	cplg Coupling
MS Miscellaneous	HWC Hazen-Williams Constant	Cr Cross Run
OR Outrigger	Pt Total pressure at a point in a pipe	CV Check Valve
RN Riser Nipple	Pn Normal pressure at a point in a pipe	DeV Deluge Valve
SP Sprig	Pf Pressure loss due to friction between points	DPV Dry Pipe Valve
ST Stand Pipe	Pe Pressure due to elevation difference between indicated points	E 90° Elbow
UG Underground	Pv Velocity pressure at a point in a pipe	EE 45° Elbow
		Ee1 11¼° Elbow
		Ee2 22½° Elbow
		f Flow Device
		fd Flex Drop
		FDC Fire Department Connection
		fE 90° FireLock(TM) Elbow
		fEE 45° FireLock(TM) Elbow
		flg Flange
		FN Floating Node
		fT FireLock(TM) Tee
		g Gauge
		GloV Globe Valve
		GV Gate Valve
		Ho Hose
		Hose Hose
		HV Hose Valve
		Hyd Hydrant
		LtE Long Turn Elbow
		mecT Mechanical Tee
		Noz Nozzle
		P1 Pump In
		P2 Pump Out
		PIV Post Indicating Valve
		PO Pipe Outlet
		PrV Pressure Relief Valve
		PRV Pressure Reducing Valve
		red Reducer/Adapter
		S Supply
		sCV Swing Check Valve
		SFx Seismic Flex
		Spr Sprinkler
		St Strainer
		T Tee Flow Turn 90°
		Tr Tee Run
		U Union
		WirF Wirsbo
		WMV Water Meter Valve
		Z Cap





Hydraulic Overview

Job	
Job Number 1	Design Engineer
Job Name: Drawing1	Phone FAX
Address 1	State Certification/License Number
Address 2	AHJ
Address 3	Job Site/Building



System	
Hose Streams 220.00	
Number Of Sprinklers Calculated 0	0
System Pressure Demand 36.475	System Flow Demand 220.00
Total Demand 220.00 @ 36.475	Pressure Result +15.631 (30.0%)

Supplies					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	250.00		60.000	50.000

Check Point Gauges			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

domestic demand.cad

Water Supply at Node 1 (250.00, 0.00, 60.000, 50.000)






Hydraulic Summary

Job Number: 1
Report Description: Ordinary Group II

Job																											
Job Number 1					Design Engineer																						
Job Name: Drawing1					State Certification/License Number																						
Address 1					AHJ																						
Address 2					Job Site/Building																						
Address 3					Drawing Name domestic demand.cad																						
System					Remote Area(s)																						
Most Demanding Sprinkler Data K-Factor at					AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area																						
Hose Allowance At Source 0.00																											
Additional Hose Supplies																											
<table border="1"> <thead> <tr> <th>Node</th> <th>Flow(gpm)</th> </tr> </thead> <tbody> <tr><td>Hose At Node 14</td><td>15.00</td></tr> <tr><td>Hose At Node 3</td><td>27.00</td></tr> <tr><td>Hose At Node 15</td><td>15.00</td></tr> <tr><td>Hose At Node 16</td><td>15.00</td></tr> <tr><td>Hose At Node 17</td><td>30.00</td></tr> <tr><td>Hose At Node 18</td><td>53.00</td></tr> <tr><td>Hose At Node 19</td><td>35.00</td></tr> <tr><td>Hose At Node 20</td><td>30.00</td></tr> </tbody> </table>										Node	Flow(gpm)	Hose At Node 14	15.00	Hose At Node 3	27.00	Hose At Node 15	15.00	Hose At Node 16	15.00	Hose At Node 17	30.00	Hose At Node 18	53.00	Hose At Node 19	35.00	Hose At Node 20	30.00
Node	Flow(gpm)																										
Hose At Node 14	15.00																										
Hose At Node 3	27.00																										
Hose At Node 15	15.00																										
Hose At Node 16	15.00																										
Hose At Node 17	30.00																										
Hose At Node 18	53.00																										
Hose At Node 19	35.00																										
Hose At Node 20	30.00																										
Total Hose Streams 220.00																											
System Flow Demand 220.00		Total Water Required (Including Hose Allowance) 220.00																									
Maximum Pressure Unbalance In Loops 0.000																											
Maximum Velocity Above Ground 3.56 between nodes 11 and 19																											
Maximum Velocity Under Ground 5.40 between nodes 6 and 18																											
Volume capacity of Wet Pipes 542.34gal		Volume capacity of Dry Pipes																									
Supplies																											
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)																		
1	Water Supply		60.000	50.000	250.00	52.106	220.00	36.475	15.631																		
Contractor																											
Contractor Number			Contact Name			Contact Title																					
Name of Contractor:					Phone			Extension																			
Address 1					FAX																						
Address 2					E-mail																						
Address 3					Web-Site																						



Water Supply at Node 1



Hydraulic Graph
Water Supply at Node 1

Static: Pressure
60.000

Residual: Pressure
50.000 @ 250.00

Available Pressure at System Demand
52.106 @ 220.00

Required Pressure at System Demand
36.475 @ 220.00

Required Pressure at System Demand (Including Hose Allowance at Source)
36.475 @ 220.00



Summary Of Outflowing Devices

Job Number: 1

Report Description: Ordinary Group II

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Hose	3	27.00	27.00	4.27	45.042		
Hose	14	15.00	15.00	2.37	50.562		
Hose	15	15.00	15.00	2.37	48.387		
Hose	16	15.00	15.00	2.37	49.381		
Hose	17	30.00	30.00	4.74	47.598		
Hose	18	53.00	53.00	8.38	40.000		
Hose	19	35.00	35.00	5.53	47.407		

⇒ Most Demanding Sprinkler Data



Node Analysis

Job Number: 1

Report Description: Ordinary Group II

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	23'-0	S, EE(7'-8)	36.475	220.00
3	-0'-0	Hose(-39.983)(31'-0)	45.042	27.00
14	-11'-0	Hose(-40.058)(31'-0)	50.562	15.00
15	-7'-0	Hose(-40.058)(31'-0)	48.387	15.00
16	-8'-0	Hose(-40.058)(31'-0)	49.381	15.00
17	-6'-0	Hose(-40.058)(31'-0)	47.598	30.00
18	2'-0	Hose(-40.000)(31'-0)	40.000	53.00
19	-6'-0	Hose(-40.058)(31'-0)	47.407	35.00
20	-12'-0	Hose(-40.058)(31'-0)	50.638	30.00
2	23'-0	T(10'-0)	36.041	
4	23'-0	T(10'-0)	36.066	
6	23'-0	T(10'-0)	35.643	
8	23'-0	T(10'-0)	36.121	
9	23'-0	T(10'-0)	35.815	
11	23'-0	T(10'-0)	36.103	



Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Fittings	Eq. Length	Summary
Upstream				Pn		Total Length	
Route 1							
UG	2.0030	53.00	5.40	150	0.022392	165'-0"	Pf 4.747
18	2'-0"	53.00		40.000	Hose(-40.000)(31'-0)	47'-0"	Pe -9.104
6	23'-0"			35.643	3EE(2'-0), T(10'-0)	212'-0"	Pv
UG	4.2300	68.00	1.55	150	0.000932	130'-0"	Pf 0.171
6	23'-0"	15.00		35.643	Flow (q) from Route 5	53'-9½"	Pe
9	23'-0"			35.815	2Ee2(7'-8), T(38'-5)	183'-9½"	Pv
UG	4.2300	98.00	2.24	150	0.001832	96'-0"	Pf 0.288
9	23'-0"	30.00		35.815	Flow (q) from Route 4	61'-5½"	Pe
11	23'-0"			36.103	3EE(7'-8), T(38'-5)	157'-5½"	Pv
UG	4.2300	133.00	3.04	150	0.003223	100'-0"	Pf 0.372
11	23'-0"	35.00		36.103	Flow (q) from Route 3	15'-4½"	Pe
1	23'-0"			36.475	2EE(7'-8), S	115'-4½"	Pv
		0.00			Hose Allowance At Source		
1		220.00					
Route 2							
CM	2.0030	27.00	2.75	150	0.006430	110'-0"	Pf 0.971
3	-0'-0"	27.00		45.042	Hose(-39.983)(31'-0)	41'-0"	Pe -9.971
2	23'-0"			36.041	T(10'-0)	151'-0"	Pv
UG	4.2300	42.00	0.96	150	0.000382	25'-0"	Pf 0.024
2	23'-0"	15.00		36.041	Flow (q) from Route 7	38'-5"	Pe
4	23'-0"			36.066	T(38'-5)	63'-5"	Pv
UG	4.2300	57.00	1.30	150	0.000672	44'-0"	Pf 0.055
4	23'-0"	15.00		36.066	Flow (q) from Route 6	38'-5"	Pe
8	23'-0"			36.121	T(38'-5)	82'-5"	Pv
UG	4.2300	87.00	1.99	150	0.001470	210'-0"	Pf 0.354
8	23'-0"	30.00		36.121	Flow (q) from Route 8	30'-9"	Pe
1	23'-0"			36.475	4Ee2(7'-8)	240'-9"	Pv
Route 3							
CM	2.0030	35.00	3.56	150	0.010392	81'-0"	Pf 1.268
19	-6'-0"	35.00		47.407	Hose(-40.058)(31'-0)	41'-0"	Pe -12.572
11	23'-0"			36.103	T(10'-0)	122'-0"	Pv
Route 4							
CM	2.0030	30.00	3.05	150	0.007814	60'-0"	Pf 0.789
17	-6'-0"	30.00		47.598	Hose(-40.058)(31'-0)	41'-0"	Pe -12.572
9	23'-0"			35.815	T(10'-0)	101'-0"	Pv
Route 5							
CM	2.0030	15.00	1.53	150	0.002167	80'-0"	Pf 0.262
15	-7'-0"	15.00		48.387	Hose(-40.058)(31'-0)	41'-0"	Pe -13.006
6	23'-0"			35.643	T(10'-0)	121'-0"	Pv
Route 6							
CM	2.0030	15.00	1.53	150	0.002167	16'-0"	Pf 0.124
16	-8'-0"	15.00		49.381	Hose(-40.058)(31'-0)	41'-0"	Pe -13.439
4	23'-0"			36.066	T(10'-0)	57'-0"	Pv
Route 7							
CM	2.0030	15.00	1.53	150	0.002167	60'-0"	Pf 0.219
14	-11'-0"	15.00		50.562	Hose(-40.058)(31'-0)	41'-0"	Pe -14.740
2	23'-0"			36.041	T(10'-0)	101'-0"	Pv
Route 8							
CM	2.0030	30.00	3.05	150	0.007814	43'-0"	Pf 0.656
20	-12'-0"	30.00		50.638	Hose(-40.058)(31'-0)	41'-0"	Pe -15.173
8	23'-0"			36.121	T(10'-0)	84'-0"	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

C Value Multiplier

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51





Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap



Revisions include Water Supply Fixture Units (WSFU)

2/18/2023 Scenic Wonders Project- Domestic Water Flows w/o Fire Sprinklers

w/ square footage and volume of each building

BLG1- 7ba, 6bd, 1 kitch		5000sf	66890cf	increased 10% of actual
	GPM	WSFU		
7 WC	8.4	17.5		Structures with Exposure Hazards occupancy hazard classification number 7 construction classification number 1.5
9 BA/Bar sink	10.8	9		
7 tub/shower	12.25	28		
2 washing ma	3.4	8		
2 kitchen sink	3.6	3		
1 Dishwasher	1.7	1.5		
2 hose bibs	34	3.5		
		70.5	BLG1 Total WSFU	
35 BLG1 Total GPM Domestic Water Flow				
21500.36 fire flow volume (gal)				

$$WS_{min} = \frac{VS_{tot}}{OHC}(CC) \times 1.5$$

[4.3.1]

where:
 WS_{min} = minimum water supply in gal (For results in L, multiply by 3.785.)
 VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)
 OHC = occupancy hazard classification number
 CC = construction classification number

BLG2- 5ba, 4bd, 1 kitch		3850sf	40000cf	As is built building
	GPM	WSFU		
5 WC	6	12.5		Structures with Exposure Hazards occupancy hazard classification number 7 construction classification number 1.5
6 BA/Bar sink	7.2	6		
3 tub/shower	5.4	12		
1 Kitchen sink	1.8	1.5		
1 dishwasher	1.2	1.5		
1 shower	1.8	2		
2 laundry wa	3.4	8		
2 hose bibs	34	3.5		
		47	BLG2 Total WSFU	
27 BLG2 Total Domestic Water Flow				
12857.14 fire flow volume (gal)				

$$WS_{min} = \frac{VS_{tot}}{OHC}(CC) \times 1.5$$

[4.3.1]

where:
 WS_{min} = minimum water supply in gal (For results in L, multiply by 3.785.)
 VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)
 OHC = occupancy hazard classification number
 CC = construction classification number

BLG3- Garage, 2ba, 1bd, 1 kitcher		3200sf	34000cf	increased 10%
	GPM	WSFU		
2 WC	2.4	5		Structures with Exposure Hazards occupancy hazard classification number 5 construction classification number 1.5
2 BA sinks	2.4	2		
2 Utility Sink	3.4	3		
1 Kitchen sink	1.8	1.5		
1 dishwasher	1.7	1.5		
1 tub/shower	1.75	4		Commercial Laundry has water storage tank mixing recycled and fresh water, pressure pump, check valve isolation
4 commercial	17	12		
4 hose bibs	68	5.5		
		34.5	BLG3 Total WSFU	
23 BLG3 Total Domestic Water Flow				
15300 fire flow volume (gal)				

$$WS_{min} = \frac{VS_{tot}}{OHC}(CC) \times 1.5$$

[4.3.1]

where:
 WS_{min} = minimum water supply in gal (For results in L, multiply by 3.785.)
 VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)
 OHC = occupancy hazard classification number
 CC = construction classification number

BLG4- (2) 1bd aptamer		1150sf	12900cf	increased 10%
	GPM	WSFU		
2WC	2.4	5		Structures with Exposure Hazards occupancy hazard classification number 7 construction classification number 1.5
2 BA Sinks,	2.4	2		
2 showers	3.5	4		
2 Kitchen sink	3.6	3		
2 dishwasher	3.4	3		
1 hose bib	17	2.5		
		19.5	BLG4 Total WSFU	
15 BLG4 Total Domestic Water Flow				
4146.429 fire flow volume (gal)				

$$WS_{min} = \frac{VS_{tot}}{OHC}(CC) \times 1.5$$

[4.3.1]

where:
 WS_{min} = minimum water supply in gal (For results in L, multiply by 3.785.)
 VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)
 OHC = occupancy hazard classification number
 CC = construction classification number

BLG5- (2) 1bed, (2) 2be 2700sf			32000cf	increased 10%
	GPM	WSFU		
6 WC	7.2	15	Structures with Exposure Hazards occupancy hazard classification number construction classification number	7 1.5
6 BA Sinks	7.2	6		
6 showers	10.5	12		
4 kitchen sink	7.2	6		
4 dishwasher	6.8	6		
3 hose bibs	51	4.5		
1 Laundry Wash	1.7	4		
		53.5	BLG5 Total WSFU	
			30 BLG5 Total Domestic Water Flow	
10285.71 fire flow volume (gal)				

$$WS_{min} = \frac{VS_{tot}}{OHC}(CC) \times 1.5 \quad [4.3.1]$$

where:
 WS_{min} = minimum water supply in gal (For results in L, multiply by 3.785.)
 VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)
 OHC = occupancy hazard classification number
 CC = construction classification number

BLG6- (2) 1bed, (2) 2be 2700sf			32000cf	increased 10%
	GPM	WSFU		
6 WC	7.2	15	Structures with Exposure Hazards occupancy hazard classification number construction classification number	7 1.5
6 BA Sinks	7.2	6		
6 showers	10.5	12		
4 kitchen sink	7.2	6		
4 dishwasher	6.8	6		
3 hose bibs	51	4.5		
1 Laundry Wash	1.7	4		
		53.5	BLG6 Total WSFU	
			30 BLG6 Total Domestic Water Flow	
10285.71 fire flow volume (gal)				

$$WS_{min} = \frac{VS_{tot}}{OHC}(CC) \times 1.5 \quad [4.3.1]$$

where:
 WS_{min} = minimum water supply in gal (For results in L, multiply by 3.785.)
 VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)
 OHC = occupancy hazard classification number
 CC = construction classification number

BLG7- (2) 1bd aptme 1150sf			12900cf	increased 10%
	GPM	WSFU		
2WC	2.4	5	Structures with Exposure Hazards occupancy hazard classification number construction classification number	7 1.5
2 BA Sinks,	2.4	2		
2 showers	3.5	4		
2 Kitchen sin	3.6	3		
2 dishwasher	3.4	3		
1 hose bib	17	2.5		
		19.5		
			15 BLG7 Total Domestic Water Flow	
4146.429 fire flow volume (gal)				

$$WS_{min} = \frac{VS_{tot}}{OHC}(CC) \times 1.5 \quad [4.3.1]$$

where:
 WS_{min} = minimum water supply in gal (For results in L, multiply by 3.785.)
 VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)
 OHC = occupancy hazard classification number
 CC = construction classification number

BLG8- (2) 1bd aptme 1150sf			12900cf	increased 10%
	GPM	WSFU		
2WC	2.4	5	Structures with Exposure Hazards occupancy hazard classification number construction classification number	7 1.5
2 BA Sinks,	2.4	2		
2 showers	3.5	4		
2 Kitchen sin	3.6	3		
2 dishwasher	3.4	3		
1 hose bib	17	2.5		
		19.5		
			15 BLG8 Total Domestic Water Flow	
4146.429 fire flow volume (gal)				

$$WS_{min} = \frac{VS_{tot}}{OHC}(CC) \times 1.5 \quad [4.3.1]$$

where:
 WS_{min} = minimum water supply in gal (For results in L, multiply by 3.785.)
 VS_{tot} = total volume of structure in ft³ (If volume is measured in m³, multiply by 35.3.)
 OHC = occupancy hazard classification number
 CC = construction classification number

	264	Total 8 Buildings WSFU
190	Total 8 Buildings Max domestic water flow rate GPM	
21500.36	Highest Fire Flow Volume	
1000	Highest Fire Flow Demand	

Fixture Flow Rates	
WC	1.28gpc
BA Faucet	1.2 gpm
Shower faucet	1.8
Tub/Shower f	1.75
Kitchen Fauc	1.8
Dishwasher	1.6
Hose Bib 5/8"	17
Laundry Was	1.6
Utility sink Fc	1.8
Average american household flow rate 6 - 12gpm	
3/4" water meter 2-20gpm	
5/8" garden hose 17gpm	
3/8" flex water supply line 1.7 gpm	

WSFU Units	
WC	2.5
Lav/Bar	1
Tub/Shower	4
Shower head	2
Washer	4
Kitchen	1.5
Dish Washer	1.5
Hose Bib	2.5