

# Summary Form for Electronic Document Submittal

**Form F**

Lead agencies may include 15 hardcopies of this document when submitting electronic copies of Environmental Impact Reports, Negative Declarations, Mitigated Negative Declarations, or Notices of Preparation to the State Clearinghouse (SCH). The SCH also accepts other summaries, such as EIR Executive Summaries prepared pursuant to CEQA Guidelines Section 15123. Please include one copy of the Notice of Completion Form (NOC) with your submission and attach the summary to each electronic copy of the document.

SCH #: \_\_\_\_\_

Project Title: Bonita School Drinking Water Improvements Project

Lead Agency: Santa Maria-Bonita School District

Contact Name: Javier Cavazos, Coordinator of Maintenance, Operations, Facilities, Transportation

Email: jcavazos@smbd.net Phone Number: (805) 928-1783

Project Location: unincorporated Santa Barbara  
*City* *County*

Project Description (Proposed actions, location, and/or consequences).

The proposed project consists of the connection of the City of Santa Maria's (City) water system to Bonita Elementary School via approximately 8,100 linear feet of a two-inch diameter service line from the planned terminus of the City's water system near the northeast corner of the Wastewater Treatment Plant to Bonita Elementary School. (The City is currently in the design phase of extending City water service to the City's Wastewater Treatment Plant separately from the proposed project.) To meet peak demand, fire flow requirements, and irrigation demand, the project would also include repurposing the existing on-site 10,000-gallon storage tank and wells and potentially adding a hydropneumatic tank (up to approximately 1,000 gallons in capacity) with appurtenances such as an air compressor and additional above-grade piping and isolation valves. Minor piping modifications to the existing system would be required to disconnect the proposed potable, domestic supply from the existing system. In addition, the project would involve replacing lead service lines in the school's Building K. Other improvements would include installation of blowoffs along the pipeline and other appurtenances on Bonita Elementary School's property.

Identify the project's significant or potentially significant effects and briefly describe any proposed mitigation measures that would reduce or avoid that effect.

The project would result in potentially significant effects to air quality, biological resources, hazards and hazardous materials, hydrology and water quality, noise, and transportation.

However, implementation of mitigation measures would reduce these impacts to less than significant levels:

AQ-1 SBCAPCD Fugitive Dust Control Measures  
 BIO-1 Worker Environmental Awareness Program Training  
 BIO-2 Pre-construction Surveys  
 BIO-3 Construction Site Best Management Practices  
 BIO-4 Avoidance and Minimization Measures for Nesting Birds  
 CR-1 Unanticipated Discovery of Archaeological Resources  
 HAZ-1 Limited Soils Assessment  
 HAZ-2 Site Management Plan  
 HAZ-3 Impacted Soil Disposal  
 HAZ-4 Hazardous Materials Management and Spill Control Plan  
 HAZ-5 Traffic Control Plan  
 NOI-1 Construction Noise Reduction Measures

If applicable, describe any of the project's areas of controversy known to the Lead Agency, including issues raised by agencies and the public.

No areas of controversy are known to the lead agency.

Provide a list of the responsible or trustee agencies for the project.

City of Santa Maria  
Santa Barbara County Local Agency Formation Commission  
California Department of Transportation  
State Water Resources Control Board