




PO Box 391578 Anza, CA 92539 Lic. 813456 C-55, C-57  
 (951) 763-2210 Office (951) 602-6320 Fax  
 heritagewellservice@yahoo.com www.heritagewellservice.com

WELL INSPECTION			
		Report No.	2082
Customer:	Larry Markham	Date:	4/8/2021
Telephone:	909-322-8482	Email:	<a href="mailto:irm@markhamds.com">irm@markhamds.com</a>
Site Address:			
Well Address:	56475 Apple Canyon Rd.Mountain Center, CA.92561		
APN:	568-170-021	GPS Coordinates:	N 33.675918 W -116.680164
Realtor:	N/A	Email:	
Escrow:	N/A	Email:	

Well Production Information				
Observed Total Production:		6291	Gallons	
Average Yield for Pumping Duration:		24.2	GPM*	
Final Observed Yield Rate:		24.2	GPM*	
Pumping Duration:		120	Minutes	
Pump Broke Suction During Test:	YES		NO	X

*\*\*Due to the unknown nature of groundwater and used pumping equipment, this inspection/certification does in no way warranty the condition of the well or its equipment beyond the date of this inspection. The certification reflects the well/well system on the date of the inspection only\*\**





WELL PRODUCTION LOG		
MINUTES	AMPS	GPM
0	11.3	32.2
20	11.4	26.5
40	11.3	24
60	11.3	24
80	11.3	25
100	11.3	25.4
120	11.3	24.6
140	11.3	24.2
160	11.2	24.4
180	11.3	24.2
200	11.4	24.2
220	11.3	24.2
240	11.3	24.2



Part:	Data:	F	D	NO	Picture
	F= Functional	D= Deficient	NO= Not Observed/Not Present		
Water Use:	Potable Water	X			
Well Motor:	2 HP 230V 1 PH	X			
Well Pump:	WT1820 installed 4/2015 by Heritage well	X			
Wire Size:	#10	X			
Pump Saver:	233 Pump Saver set @ 41 mins	X			
Booster Pump:	2 HP Berkeley Booster			X	
Pressure Tank(s):	3-85 Gallon Pressure Tank	X			
Storage Tank(s):	1-5000 Gallon Poly Tank	X			
Filter/Plumbing:	1 1/4" Galv & PVC	X			

Specializing in:

Well Drilling - Submersible Booster Pumps - Storage Tanks - Well Certifications - Filtration - Well Cleaning

Part:	N	F	D	NO	Picture
	F= Functional D= Deficient NO= Not Observed/Not Present				
Float:	Electric	X			
System Pressure:	unknown				
Pressure Switch:	60/80	X			
Electrical Equipment:	2 Hp Control Box	X			
Well Casing:	8 5/8" Steel	X			

Well Water Condition:						
Sulfur Odor:	Yes	X	No	Comments:	N/A	
Iron Visible:	Yes	X	No	Comments:	N/A	
Samples Taken:	n/a					
Water Testing Information (If Applicable):	Babcock & Sons, Inc. 951-653-3351					

**Comments About the System:**  
 System is aged but functional. Booster pump functionality could not be verified due to lack of water in tank. If customer would like a reinspection the fee is \$125 and can be scheduled once the tank is full.

Dated: 4/8/2021

By: Eric J. Haley, Owner/Operator



Specializing in:  
 Well Drilling - Submersible Booster Pumps - Storage Tanks - Well Certifications - Filtration - Well Cleaning



## ***NEW HOMEOWNER ORIENTATION***

*This certificate entitles the new homeowner for this property to a  
New Homeowner Orientation at a rate of **\$100.00**,  
\$25.00 off the regular price of \$125.00*

*Once you have closed escrow, please call 951-763-2210  
to schedule an appointment with us.*

*During your orientation we will go over proper well maintenance,  
the set-up and inner-workings of your well system and  
basic tips for equipment longevity.*

*Specializing in:*

Well Drilling - Submersible Booster Pumps - Storage Tanks - Well Certifications - Filtration - Well Cleaning