

Notice of Intent to Adopt a Negative Declaration

To: Interested Individuals
 State Clearinghouse
 County Clerk
 County of Los Angeles

From: City of Azusa
 213 E Foothill Boulevard
 Azusa, CA 91702

Project Title: Aspan Well Rehabilitation and Treatment Project

Project Location: City of Azusa, 220 N. Aspan Avenue

Applicant: City of Azusa
 213 E Foothill Boulevard
 Azusa, CA 91702

Project Description:

The proposed project consists of the rehabilitation of the Aspan Well which is currently inactive and has experienced deterioration of the well casing. As part of the rehabilitation, the City of Azusa will install a new well casing liner to preserve the well's integrity and will remove the existing welded steel tank and booster pump station from the site.

The current water quality issue for the Aspan Well is the presence of 1,1-DCE in excess of the maximum contaminant level (MCL), the concentration allowed in drinking water by the California State Water Resources Control Board – Division of Drinking Water, which requires the installation of a Liquid Phase Granular Activated Carbon (LGAC) treatment system. The proposed LGAC treatment system will be designed for a flow of approximately 1,800 gallons per minute (gpm) and will include two pairs of 12-foot diameter filtration vessels. In addition, Nitrate has been detected in the past in the Aspan Well, although Nitrate concentrations were recently shown to be below the MCL. If treatment for nitrates is needed, the IX treatment system will be installed downstream of the LGAC system and will feature three vessels working in parallel.

A new 34,000 gallon brine waste tank will be constructed to temporarily hold the brine waste, which will be discharged from the tank to a Los Angeles County Sanitation Districts' (LACSD) sewer line. A new 8-inch diameter PVC brine discharge pipeline will convey brine waste to the LACSD sewer line. Well waste water, well test water, and waste water for testing operations will be discharged through a new drain pipeline that will connect to the existing Los Angeles County Flood Control District (LACFCD) 51-inch diameter storm drain.

THIS NOTICE IS TO ADVISE INTERESTED INDIVIDUALS THAT City of Azusa has prepared a

Negative Declaration

For the project identified above. As mandated by State law, the minimum public review period for this document is:

30 days (ND was submitted to the State Clearinghouse for review)

Begins: June 17, 2024

Ends: July 17, 2024

The Initial Study and the proposed Negative Declaration are available for review at:

City of Azusa
213 E Foothill Boulevard
Azusa, CA 91702

Contact Person: Melissa Barbosa

Written comments regarding the proposed Negative Declaration must be submitted to the City prior to 5:00 p.m. on the last day of the 30-day public review/comment period (July 17, 2024). All written comments should indicate a contact person for your agency or organization, if applicable, and reference the project name. Responsible agencies are requested to indicate their statutory responsibilities in connection with this project when responding.

Signature:
Printed Name:
Title:



Melissa Barbosa
Assistant General Manager- Water Operations
AW

Date: June 13, 2024


KJG
06/13/2024