

Notice of Exemption

To: Office of Planning and Research
P.O. Box 3044, Room 113
Sacramento, CA 95812-3044

From: (Public Agency): San Dieguito Water District
160 Calle Magdalena
Encinitas, CA 92024

(Address)

County Clerk
County of: San Diego
1600 Pacific Hwy #260
San Diego, CA 92101

Project Title: Caudor Street Pressure-Reducing Valve

Project Applicant: San Dieguito Water District

Project Location – Specific:

Eastern terminus of Caudor Street in the Leucadia community of the City of Encinitas, approximately 450 feet east of Barbara Lane and 800 feet east of Interstate 5

Project Location – City: Encinitas Project Location – County: San Diego

Description of Nature, Purpose and Beneficiaries of Project:

The project would replace existing infrastructure in a public water system to meet fire-flow demand in a residential neighborhood. An existing 8" isolation valve would be replaced with an 8" pressure-reducing valve. This would include installation of a new pre-fabricated underground vault accessed by steel hatches, which would be flush with the road surface. Street pavement would be replaced in excavated areas beyond the extent of the vault lid.

Name of Public Agency Approving Project: San Dieguito Water District

Name of Person or Agency Carrying Out Project: Same as above

Exempt Status: (check one):

- Ministerial (Sec. 21080(b)(1); 15268);
 Declared Emergency (Sec. 21080(b)(3); 15269(a));
 Emergency Project (Sec. 21080(b)(4); 15269(b)(c));
 Categorical Exemption. State type and section number: Class 1, minor alteration of existing infrastructure
 Statutory Exemptions. State code number: _____

Reasons why project is exempt:

The project would replace existing components of and install minor additions to existing public water infrastructure for system optimization to meet existing fire-flow demand, with no expansion of use. The project would occur within existing public right-of-way, including a paved residential street and a small area beyond the paved street where a residential yard has encroached into the right-of-way.

Lead Agency
Contact Person: Habib Hariri Area Code/Telephone/Extension: 760-633-2731

If filed by applicant:

1. Attach certified document of exemption finding.
2. Has a Notice of Exemption been filed by the public agency approving the project? Yes No

Signature:  Date: 6/20/2024 Title: Principal Engineer

Signed by Lead Agency Signed by Applicant

Authority cited: Sections 21083 and 21110, Public Resources Code. Date Received for filing at OPR: _____
Reference: Sections 21108, 21152, and 21152.1, Public Resources Code.