

# Summary Form for Electronic Document Submittal

Form F

Lead agencies may include 15 hardcopies of this document when submitting electronic copies of Environmental Impact Reports, Negative Declarations, Mitigated Negative Declarations, or Notices of Preparation to the State Clearinghouse (SCH). The SCH also accepts other summaries, such as EIR Executive Summaries prepared pursuant to CEQA Guidelines Section 15123. Please include one copy of the Notice of Completion Form (NOC) with your submission and attach the summary to each electronic copy of the document.

SCH #: \_\_\_\_\_

Project Title: PA-2300247 Flood Variance

Lead Agency: San Joaquin County - Community Development Department

Contact Name: Alisa Goulart

Email: alisa.goulart@sjgov.org Phone Number: 209-468-0222

Project Location: Stockton, San Joaquin County  
*City* *County*

Project Description (Proposed actions, location, and/or consequences).

A Flood Variance application to reduce the elevation requirements of County Code of Ordinance Title 9, Division 16, Section 9-703.130(c) to authorize an existing boat storage building at an existing boat storage facility to have its lowest floor elevation 5.17 feet below the base flood elevation. The building, constructed in 2006, has incorporated wet floodproofing techniques which were approved by the San Joaquin County Department of Public Works Floodplain Administrator. This Flood Variance application for the existing building is proposed to resolve a violation as reported by FEMA.

Identify the project's significant or potentially significant effects and briefly describe any proposed mitigation measures that would reduce or avoid that effect.

If applicable, describe any of the project's areas of controversy known to the Lead Agency, including issues raised by agencies and the public.

The project site is in a special flood hazard zone. The Flood Variance request is for an existing boat storage building with the lowest floor 5.17 feet below the base flood elevation. FEMA has sent the County a Community Assistance Report identifying the building as a potential violation of the National Flood Insurance Program's requirements. This Flood Variance for the building is proposed to resolve the violation and allow for resolution.

Provide a list of the responsible or trustee agencies for the project.