

Notice of Exemption

Appendix E

To: Office of Planning and Research
P.O. Box 3044, Room 113
Sacramento, CA 95812-3044
County Clerk
County of: Sacramento
3636 American River Drive
Sacramento, CA 95864

From: (Public Agency): City of Rancho Cordova
2729 Prospect Park Drive
Rancho Cordova, CA 95670
(Address)

Project Title: Pump Station Generators

Project Applicant: City of Rancho Cordova

Project Location - Specific:
Four pump stations in Rancho Cordova: Sunriver (38.61923489, -121.282637); Citrus Rd (38.61060377, -121.2644354); West Coloma (38.58824871, -121.3242804); Mather Industrial (38.56290828, -121.3176344)

Project Location - City: Rancho Cordova Project Location - County: Sacramento

Description of Nature, Purpose and Beneficiaries of Project:
This project will mitigate potential impacts to the public due to flooding by installing four diesel-fueled emergency standby generators at four pump station locations. Each will be equipped with above ground double-walled, sub-base diesel fuel tanks. Engine exhaust systems meet Tier 4 emission standards. Wiring will be installed in existing duct banks; no excavation will be required.

Name of Public Agency Approving Project: City of Rancho Cordova

Name of Person or Agency Carrying Out Project: City of Rancho Cordova

Exempt Status: (check one):

- Ministerial (Sec. 21080(b)(1); 15268);
Declared Emergency (Sec. 21080(b)(3); 15269(a));
Emergency Project (Sec. 21080(b)(4); 15269(b)(c));
[X] Categorical Exemption. State type and section number: §15301 Exst facilities, §15303 New const or conv of small struct.
Statutory Exemptions. State code number:

Reasons why project is exempt:
This project is exempt under §15301 because the new emergency backup generators and appurtenances will be installed at existing city-owned facilities, which provide municipal drainage utility service, and no expansion of facility use. This project is also exempt under § 15303 because it proposes minor modification to existing facilities by installing new equipment with electrical service connection. None of the exceptions in CEQA § 15300.2 apply.

Lead Agency Contact Person: Jesse Yabes Area Code/Telephone/Extension: (916) 851-8959

If filed by applicant:

- 1. Attach certified document of exemption finding.
2. Has a Notice of Exemption been filed by the public agency approving the project? [] Yes [] No

Signature: [Signature] Date: 7/25/2024 Title: Associate Civil Engineer

[X] Signed by Lead Agency [] Signed by Applicant

Authority cited: Sections 21083 and 21110, Public Resources Code. Date Received for filing at OPR:
Reference: Sections 21108, 21152, and 21152.1, Public Resources Code.

ENDORSED
SACRAMENTO COUNTY

JUL 26 2024