

**NOTICE OF EXEMPTION**

To:  Office of Planning & Research  
1400 Tenth Street  
Sacramento, CA 95814

From: San Juan Water District  
9935 Auburn-Folsom Road  
Granite Bay, CA 95746

County Clerk  
County of Placer  
2954 Richardson Drive  
Auburn, CA 95603  
(530) 886-5600

Project Title: Water Treatment Plant Filter Backwash Hood Facilities Rehabilitation Project

Project Applicant: San Juan Water District (SJWD)

Project Location - Specific: The Project is located at the San Juan Water District's Water Treatment Plant at 9935 Auburn Folsom Road, Granite Bay, CA 95746

Project Location – Cities: Granite Bay Project Location – Counties: Placer

Description of Nature, Purpose and Beneficiaries of Project: Project includes the rehabilitation of the existing northwest and southwest filter backwash hood facilities and track system. More specifically, the work includes the removal and reinstallation of the facilities from the filter basins; preparation and coating of the backwash hoods; bridge, and pump house; the replacement of piping, fittings, valves, and flowmeters; the replacement of hydraulic system; and the replacement of electrical conduit, wires, motors, variable frequency drives, outlets, lights and panels. Work also includes the replacement of the track system along the filter basins. The purpose of the project is to extend the life and improve the efficiency of the existing northwest and southwest filter backwash hood facilities. These improvements will benefit the District's rate payers.

Name of Public Agency Approving Project: San Juan Water District

Name of Person or Agency Carrying Out Project: San Juan Water District

Exempt Status: (check one)

- Ministerial (Sec. 21080(b)(1); 15268);
- Declared Emergency (Sec. 21080(b)(3); 15269(a));
- Emergency Project (Sec. 21080(b)(4); 15269(b)(c));
- Categorical Exemption (State type and section number); 15061(b)(2)(3); 15301(d); 15302(c)
- Statutory Exemption (State code number);

Reasons why project is exempt: Project involves the rehabilitation of existing facilities having substantially the same purpose, involving no expansion of size or capacity and there is no possibility it would have a significant impact on the environment.

Lead Agency: San Juan Water District

Contact Person: Mark Hargrove

(916) 791-6951

Area Code / Telephone / Extension

If filed by applicant:

1. Attach certified document of exemption finding.
2. Has a Notice of Exemption been filed by the public agency approving the project?  Yes  No

Signature: Mark Hargrove Date: 8/14/2024 Title: Senior Engineer

Signed by Lead Agency  Signed by Applicant

Authority cited: Sections 21083 and 21110, Public Resources Code.  
Reference: Sections 21108, 21152, and 21152.1, Public Resources Code.

Date Received for filing at OPR: \_\_\_\_\_