

NOTICE OF EXEMPTION

TO:
Governor’s Office of Planning and Research
State Clearinghouse
1400 Tenth Street, Room 113
Sacramento, CA 95812

FROM:
State Water Resources Control Board
Division of Drinking Water (DDW)
2375 Northside Drive, Suite 100
San Diego, CA 92108
Chun Y. Huang
Phone: (619) 525-4159

Project Applicant: Western Municipal Water District – Murrieta Division

Project Title: North Well 2 - Water Treatment Plant (Project)

Project Location: 24308 Kentucky Derby Way, Murrieta CA 92562

Project County: Riverside

Project Description: The Project involves construction of a 750 gpm iron and manganese wellhead treatment system at the existing North Well 2 site, consisting of a backwash tank (12 ft. diameter x 20 ft. tall), two tanks that include iron and manganese filters and a pump.

Public Agency Approving the Project: State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued a domestic water supply permit amendment for the above-described Project on September 30, 2024. A record of approval for the Project is available to the general public at the State Water Board, Division of Drinking Water district office listed above.

CATEGORICAL EXEMPTION STATUS:

Class 1: Existing Facilities Cal. Code of Regs., section 15301

Reason Why the Project Is Exempt: The Project is exempt because The Project components meet the criteria under Sections 15301 for operation, maintenance, and minor alteration of an existing structure with no or negligible expansion of use. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

Signature: _____

Title: _____ District Engineer