

NOTICE OF EXEMPTION

TO:

Governor's Office of Planning and Research
State Clearinghouse
1400 Tenth Street, Room 113
Sacramento, CA 95812

FROM:

State Water Resources Control Board
Division of Drinking Water (DDW)
265 West Bullard Ave., STE 101
Fresno, CA, 93704
Sudarshan Poudyal
Phone: (559) 447-3300

Project Applicant: Bluff Pointe Golf Course

Project Title: Operation of Bluff Pointe Golf Course Continuous Chlorination System (Project)

Project Location: 8225 North Milburn Ave., Fresno, 93722, APN: 502-020-43ST

Project County: Fresno

Project Description: The Applicant proposes operating a continuous chlorination treatment system at an existing water treatment facility. The new treatment system will be housed in a new three-foot by three-foot building on an existing concrete pad. A 12.5% liquid chlorine will be used as the treatment media.

Public Agency Approving the Project: State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued a permit amendment for the above-described Project on October 7, 2024. A record of approval for the Project is available to the general public at the State Water Board, Division of Drinking Water district office listed above.

CATEGORICAL EXEMPTION STATUS:

Class 1: Existing Facilities Cal. Code of Regs., section 15301

Reason Why the Project Is Exempt: The Project is exempt because it is the operation of a health protection device used in conjunction with an existing well and treatment system. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

Senior Environmental Scientist