

State of California  
**Well Completion Report**  
 Form DWR 188 Submitted 10/19/2022  
 WCR2022-012271

Owner's Well Number \_\_\_\_\_ Date Work Began 05/23/2022 Date Work Ended 06/07/2022  
 Local Permit Agency County of Riverside Department of Environmental Health  
 Secondary Permit Agency \_\_\_\_\_ Permit Number WP0029992 Permit Date 06/09/2021

Well Owner (must remain confidential pursuant to Water Code 13752)	Planned Use and Activity
Name <u>5 POINTS INC,</u>	Activity <u>New Well</u>
Mailing Address <u>220 N SAN JACINTO</u>	Planned Use <u>Water Supply Domestic</u>
City <u>HEMET</u> State <u>CA</u> Zip <u>92543</u>	

Well Location		
Address _____	APN <u>430-100-002</u>	
City _____ Zip _____ County <u>Riverside</u>	Township <u>04 S</u>	
Latitude <u>33</u> <u>49</u> <u>20.964</u> N Longitude <u>-117</u> <u>1</u> <u>34.5</u> W	Range <u>01 W</u>	
Deg. Min. Sec.	Section <u>18</u>	
Dec. Lat. <u>33.82249</u> Dec. Long. <u>-117.02625</u>	Baseline Meridian <u>San Bernardino</u>	
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____	
Location Accuracy _____ Location Determination Method _____	Elevation Accuracy _____	
	Elevation Determination Method _____	

Borehole Information	
Orientation <u>Vertical</u> Specify _____	
Drilling Method <u>Direct Rotary</u> Drilling Fluid <u>Bentonite</u>	
Total Depth of Boring <u>700</u> Feet	
Total Depth of Completed Well <u>700</u> Feet	

Water Level and Yield of Completed Well	
Depth to first water _____ (Feet below surface)	
Depth to Static _____	
Water Level <u>176</u> (Feet) Date Measured _____	
Estimated Yield* <u>300</u> (GPM) Test Type <u>Pump</u>	
Test Length <u>4</u> (Hours) Total Drawdown _____ (feet)	
*May not be representative of a well's long term yield.	

Geologic Log - Free Form		
Depth from Surface	Feet to Feet	Description
0	24	CLAY
24	44	CLAY, SAND
44	124	CLAY
124	144	CLAY SAND STREAKS
144	164	CLAY
164	184	FIRM CLAY, SOFT SAND
184	224	FINE SAND
224	264	FINE SAND. CLAY
264	284	SAND, HARD CLAY
284	304	FINS SAND, CLAY
304	344	CEMENTED SAND
344	364	SAND, SOME CLAY
364	384	CLAY
384	404	CLAY, FIRM SAND

404	424	FIRM CLAY
424	464	CEMENTED SAND
464	484	FIRM SAND
484	544	FIRM SAND, CLAY STRIPES
544	584	FIRM SAND, CLAY STREAKS
584	644	CLAY SOFT SAND
644	664	CLAY, SOFT SAND
664	684	FIRM SAND, CLAY
684	700	CLAY

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	22	Conductor or Fill Pipe	Other	N/A	0.25	16			STEEL
1	22	700	No Casing Installed	Other	N/A					NONE
2	0	300	Blank	PVC	OD: 8.625 in.   SDR: 17   Thickness: 0.508 in.	0.508	8.625			
2	300	700	Screen	PVC	OD: 8.625 in.   SDR: 17   Thickness: 0.508 in.	0.508	8.625	Milled Slots	0.032	

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	22	Cement	Other Cement		
0	700	Filter Pack	Other Gravel Pack	5	birdseye

**Other Observations:**

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	24	24
24	700	22

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	L O LYNCH QUALITY WELLS & PUMPS INC		
	Person, Firm or Corporation		
856 W 7TH STREET	SAN JACINTO	CA	92582
Address	City	State	Zip
Signed	<i>electronic signature received</i>	10/19/2022	740156
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

DWR Use Only			
CSG #	State Well Number	Site Code	Local Well Number
		N	W
Latitude Deg/Min/Sec		Longitude Deg/Min/Sec	
TRS:			
APN:			