



**Yana Garcia**  
Secretary for  
Environmental Protection



**Department of Toxic Substances Control**

---

Katherine M. Butler, MPH, Director  
8800 Cal Center Drive  
Sacramento, California 95826-3200  
[dtsc.ca.gov](http://dtsc.ca.gov)



**Gavin Newsom**  
Governor

**SENT VIA ELECTRONIC MAIL**

February 28, 2025

Sean White  
Water Resources Director  
City of Ukiah  
300 Seminary Drive  
Ukiah, CA 95482  
[swhite@cityofukiah.com](mailto:swhite@cityofukiah.com)

RE: MITIGATED NEGATIVE DECLARATION FOR CITY OF UKIAH NEW MUNICIPAL WELL PROJECT DATED FEBRUARY 27, 2025, STATE CLEARINGHOUSE NUMBER [2025021131](#)

Dear Sean White,

The Department of Toxic Substances Control (DTSC) reviewed the Mitigated Negative Declaration for City of Ukiah New Municipal Well Project (Project). The purpose of the Proposed Project is to construct a new well with a capacity of approximately 600 to 1,000 gallons per minute to help the City maintain and continue to provide its existing customers with safe and reliable water supply. DTSC recommends and requests consideration of the following comments:

1. If buildings or other structures are to be demolished on any Project sites included in the proposed Project, surveys should be conducted for the presence of lead-based paints or products, mercury, asbestos containing materials, and polychlorinated biphenyl caulk. Removal, demolition, and disposal of any of the above-mentioned chemicals should be conducted in compliance with California environmental regulations and policies. In addition, sampling near current and/or former buildings should be conducted in

accordance with [DTSC's Preliminary Endangerment Assessment \(PEA\) Guidance Manual](#).

2. DTSC recommends that all imported soil and fill material should be tested to assess any contaminants of concern meet screening levels as outlined in [DTSC's PEA Guidance Manual](#). Additionally, DTSC advises referencing the [DTSC Information Advisory Clean Imported Fill Material Fact Sheet](#) if importing fill is necessary. To minimize the possibility of introducing contaminated soil and fill material there should be documentation of the origins of the soil or fill material and, if applicable, sampling be conducted to ensure that the imported soil and fill material are suitable for the intended land use. The soil sampling should include analysis based on the source of the fill and knowledge of prior land use. Additional information can be found by visiting [DTSC's Human and Ecological Risk Office \(HERO\) webpage](#).

DTSC appreciates the opportunity to comment on the MND for City of Ukiah New Municipal Well Project. Thank you for your assistance in protecting California's people and environment from the harmful effects of toxic substances. If you have any questions or would like clarification on DTSC's comments, please respond to this letter or via our [CEQA Review email](#) for additional guidance.

Sincerely,

*Tamara Purvis*

Tamara Purvis  
Associate Environmental Planner  
HWMP - Permitting Division – CEQA Unit  
Department of Toxic Substances Control  
[Tamara.Purvis@dtsc.ca.gov](mailto:Tamara.Purvis@dtsc.ca.gov)

Sean White  
February 28, 2025  
Page 3

cc: (via email)

Governor's Office of Land Use and Climate Innovation  
State Clearinghouse  
[State.Clearinghouse@opr.ca.gov](mailto:State.Clearinghouse@opr.ca.gov)

Steve Brown  
Project manager/Consultant  
SMB Environmental, inc.  
[steve@smbenvironmental.com](mailto:steve@smbenvironmental.com)

Dave Kereazis  
Associate Environmental Planner  
HWMP-Permitting Division – CEQA Unit  
Department of Toxic Substances Control  
[Dave.Kereazis@dtsc.ca.gov](mailto:Dave.Kereazis@dtsc.ca.gov)

Scott Wiley  
Associate Governmental Program Analyst  
HWMP - Permitting Division – CEQA Unit  
Department of Toxic Substances Control  
[Scott.Wiley@dtsc.ca.gov](mailto:Scott.Wiley@dtsc.ca.gov)