


March 7, 2017

**Sound Level Assessment
Supplemental Analysis
OASIS Meeting Center
Old Town Orcutt, CA**

This is an acoustic model showing the attenuation of sound from a limited amplified music performance at the proposed Oasis Center, Old Town Orcutt, CA. At the surrounding first and second story residential sensitive receptors, the sound level will attenuate below average ambient sound level of 50 dBA. Therefore sound level should be inaudible or barely perceptible at any residence. The traffic noise from Clark Ave. or Foxenwood Lane / Hwy 135 interchange is not shown. Traffic noise would serve to further mask sounds from the Oasis Center.



for 45dB Acoustics, LLC
by David Lord

David Lord