

NOTICE OF DETERMINATION

TO: Governor's Office of Planning and Research FROM: State Water Resources Control Board
State Clearinghouse Riverside District
Office P.O. Box 3044 1350 Front Street, Room 2050
Sacramento, CA 95812-3044 San Diego, CA 92101

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 of the Public Resources Code.

SCH#: 2003031121 as amended
WATER SYSTEM #: 3310075

PROJECT TITLE: Riverside-Corona Feeder Project

LEAD AGENCY: Western Municipal Water District
CONTACT PERSON: Jimmy Chen
PHONE NUMBER: 951.571.7100

RESPONSIBLE AGENCY: State Water Resources Control Board (State Water Board)
CONTACT PERSON: J. Steven Williams
PHONE NUMBER: (619) 525-4159

PROJECT LOCATION: Sterling Avenue just outside of the Arlington Desalter facility, Riverside, California

PROJECT DESCRIPTION: An interconnection with WMWD-Main System to deliver treated Metropolitan Water District (MWD) water to the Arlington Desalter distribution system. The newly built La Sierra Pipeline, whose original purpose was to bring Arlington Desalter water into WMWD Main System, has been configured to reverse flow through the La Sierra Pipeline bringing water from the WMWD Main System's Mills Gravity Line (MGL) into the Arlington Desalter distribution pipeline. A Cla-Val has been installed at the Sterling Pump Station that reduces the pressure of MGL water at a flow rate of 2,500 – 7,500 gpm. MGL water is chloraminated, and thus will undergo break point chlorination to convert to free chlorine to be compatible with the other sources in the Arlington distribution system. A 3,000-gallon liquid sodium hypochlorite (12.5%) tank will be used to supply the breakpoint disinfection.

PUBLIC AGENCY APPROVING PROJECT AND CARRYING OUT PROJECT: This is to advise that the State Water Board has issued a water supply permit amendment 05-20-19PA-016 for the above described Project on November 13, 2019, and has made the following determinations regarding the Project:

1. The Project will not have a significant effect on water quality.
2. A Supplemental EIR/EIS and amendments were prepared for this Project pursuant to the provisions of the California Environmental Quality Act (CEQA).
3. Mitigation measures were not made a condition of the issuance of this permit.
4. A mitigation reporting or monitoring plan was not adopted for this Project.
5. Findings were not made pursuant to the provisions of CEQA.
6. A Statement of Overriding Considerations was not adopted for this Project.

This is to certify that the record of permit issuance for the Project is available to the general public at the State Water Board, Division of Drinking Water District office noted above. The EIR/EIS and amendments are available from the lead agency.

Signature:  Date: November 13, 2019
Name: J. Steven Williams, P.E. Title: District Engineer

Governor's Office of Planning & Research

NOV 15 2019

STATE CLEARINGHOUSE